

**Code Administrator Consultation Response Proforma****GC0147: Last resort disconnection of Embedded Generation, enduring solution**

Industry parties are invited to respond to this consultation expressing their views and supplying the rationale for those views, particularly in respect of any specific questions detailed below.

Please send your responses to [grid.code@nationalgrideso.com](mailto:grid.code@nationalgrideso.com) by **5pm on 1 March 2021**. Please note that any responses received after the deadline or sent to a different email address may not receive due consideration by the Workgroup.

If you have any queries on the content of this consultation, please contact Nisar Ahmed [Nisar.ahmed@nationalgrideso.com](mailto:Nisar.ahmed@nationalgrideso.com) or [grid.code@nationalgrideso.com](mailto:grid.code@nationalgrideso.com)

Respondent details	Please enter your details
<b>Respondent name:</b>	Caroline Bragg
<b>Company name:</b>	Association for Decentralised Energy
<b>Email address:</b>	Caroline.bragg@theade.co.uk
<b>Phone number:</b>	0203 031 8740

**For reference the Applicable Grid Code Objectives are:**

- a) *To permit the development, maintenance and operation of an efficient, coordinated and economical system for the transmission of electricity*
- b) *Facilitating effective competition in the generation and supply of electricity (and without limiting the foregoing, to facilitate the national electricity transmission system being made available to persons authorised to supply or generate electricity on terms which neither prevent nor restrict competition in the supply or generation of electricity);*
- c) *Subject to sub-paragraphs (i) and (ii), to promote the security and efficiency of the electricity generation, transmission and distribution systems in the national electricity transmission system operator area taken as a whole;*
- d) *To efficiently discharge the obligations imposed upon the licensee by this license and to comply with the Electricity Regulation and any relevant legally binding decisions of the European Commission and/or the Agency; and*
- e) *To promote efficiency in the implementation and administration of the Grid Code arrangements*

**Please express your views in the right-hand side of the table below, including your rationale.**

Standard Workgroup Consultation questions		
1	Do you believe that the GC0147 Original Proposal or WAGCM1-	The ADE supports WAGCM7.

	7 better facilitates the Applicable Objectives?	<p>Compensation to generation affected by actions taken under GC0147 is important and a clear requirement of the Clean Energy Package.</p> <p>Further, such direct control actions should not be taken before commercial options, such as ODFM or equivalent. Therefore, it is crucial that commercial options are developed as a condition of implementing GC0147. Given that ODFM is likely to be part of ESO's product suite only for one more year and will be replaced thereafter by new reserve products, the condition for implementing a GC0147 solution should be a) only once ODFM has been approved for 2021 and b) thereafter only if an ODFM replacement has emerged from Reserve Reform.</p>
2	Do you support the proposed implementation approach?	On the condition that ODFM or an equivalent is put in place as intended for this year and then an equivalent service emerges from the ESO's reserve reform, the ADE supports the implementation approach.
3	Do you have any other comments?	None.