

# Appendix 1 - Technical requirements and assessment criteria for the ESR Wind Tender 2022

## Executive summary

Each potential Electricity System Restoration (ESR) Service Provider will have a different impact on Great Britain (GB)'s restoration, depending on individual characteristics and network location. Detailed in this document are the required capabilities needed from ESR wind service providers, along with information about how these will be valued and how the tender will be assessed.

For this tender, wind service providers will be treated as primary restoration service providers, providing full service requirements.

## What's inside?

1. **Technical requirements** – These are the minimum requirements that a provider will need to be able to meet – a provider doesn't need to have all of these at the time of tendering, but during the feasibility and tender process they should ensure their tendered solution details how the provider intends to meet these.
2. **Assessment criteria** – The overall assessment will be weighted 50:50 (Commercial: Technical), this is because providers that meet the minimum criteria will provide an acceptable level of service, but we will still value technical capability that contributes to a faster restoration.

## 1. Technical requirements

The primary restoration service provider must be able to meet the technical requirements at one point of connection.

Requirement	Minimum	Definition	Rationale
Time to Connect	≤ 2hours	Time taken to start-up the Restoration Station from shutdown without the use of external power supplies, and to energise part of the NETS, within two hours of receiving an instruction from the Electricity System Operator (ESO) or its delegate.	As per the Grid Code requirement (OC9.4.5.1) <sup>1</sup> .
Service Availability	≥ 80%	The ability to deliver the contracted Restoration Service over 80% of a year.  <i>Notes: It is the responsibility of the Provider to demonstrate its service availability. By submitting a tender, the provider commits to ensuring availability at least 80% of each year of the service.</i>	Primary Restoration Service Providers are expected to have a high restoration service availability so that they can be relied upon in the instance of a Total or Partial shutdown, which could happen at any time.

<sup>1</sup> <https://www.nationalgrid.com/sites/default/files/documents/8589935287-OC9%20Contingency%20Planning.pdf>

Requirement	Minimum	Definition	Rationale
		- <i>In regard to service availability calculations, we will provide more information about this during the next stages of the tender.</i>	
Voltage Regulation	Existent	Ability to create a voltage source and remain connected within acceptable limits during energisation/block loading ( $\pm 10\%$ ).	During events such as load pick-ups, Primary RSPs will need to maintain voltage (within limits) when creating, maintaining, and expanding a power island following instructions from the ESO.
Frequency Regulation	Existent	Ability to manage frequency level when block loading (47.5Hz – 52Hz).	During a restoration event, a Primary RSP will need to maintain frequency within limits when creating, maintaining, and expanding a power island following instructions from the ESO.
Resilience of Supply, Restoration Service	$\geq 10$ hours	When instructed, the minimum time the RSP will deliver the contracted service.	To support restoration of the NETS.
Resilience of Supply, Restoration Auxiliary Unit(s)	$\geq 72$ hours	Run continuously at the output required to support / deliver the contracted restoration Service	The ESO or it's delegate would not instruct all Primary RSPs at the same time therefore this is to allow for Primary RSPs to remain ready and instruct able anytime within the resilience period.
Block Loading Size	$\geq 10$ MW	Capability to accept instantaneous loading of demand blocks.	The restoration approach for GB going forward will be a combination of top-down approach and bottom-up approach. The Primary RSP must be able to match the DNO's ability to segregate and switch the Distribution Network remotely.
Reactive Capability	$\geq 50$ MVA Leading	Ability to energise part of the NETS, managing Voltage with Leading or lagging capability whilst active power is zero.	Primary RSPs must be able to re-energise parts of the National Electricity Transmission System (NETS), with no load. The higher the reactive capability of a provider, the more quickly access to demand can be achieved.
Sequential Restoration attempts	$\geq 3$	Ability to perform at least three sequential start-ups.	To allow for possible tripping of the NETS during the re-instatement period, or trips during the Primary RSP's own starting sequence.
Short-circuit level (SCL) (following the start of a system disturbance)	For $t \leq 80$ ms: $I \geq \frac{240 [MVA]}{\sqrt{3} \cdot U} [kA]$  For $t > 80$ ms: $I \geq \frac{100 [MVA]}{\sqrt{3} \cdot U} [kA]$  $U \equiv$ connection voltage [kV]	Injection of reactive current during a disturbance.	The higher the SCL, the quicker Power Islands are developed.  This requirement can be demonstrated from Fault Ride Through test evidence, or in the case of a synchronous generator, Grid Code DRC schedule1 modelling data being provided as an alternative.

Requirement	Minimum	Definition	Rationale
Inertia Value	≥400 MVA.s	Stored energy available in the RSP for immediate release in response to changes in power levels and thereby helping to maintain frequency and voltage on the power island within acceptable bounds. (This can be real, physical inertia as in a rotating machine, or virtual inertia as in converter-connected resources with suitable control).	If more Inertia is provided, larger active power imbalances may be managed across re-energisation, enabling larger demand blocks and generation that is not synchronous to be restored earlier than would otherwise be possible.

## 2. Type of services to procure

A potential primary restoration service provider must be able to provide all of the minimum technical requirements listed above under the relevant section. They may achieve this through adaptations proposed in the Feasibility Study.

If a potential provider has a limitation on one of the technical requirements, but can meet the others, we will allow Expressions of Interest to be submitted, and where possible will assess whether a provider could contribute, but it will be entirely at the discretion of the ESO to confirm whether a provider not meeting all of the requirements will be eligible to participate.

## 3. Assessment Criteria

We are proposing to assess the tender submissions in line with the assessment criteria outlined below. The technical elements have a range of sub-criteria that make up each element, and the rationale for these is also explained.

Commercial assessment will be based on cost per Settlement Period, based on 87648 SPs (based on a 5-year contract including one leap year), however, at tender submission, a full breakdown of all submitted costs will be required, and the ESO will reserve the right to employ a third party to verify and challenge the costs associated with designs.

<b>Technical 50%</b>	Minimum requirements	Pass/Fail
	Connection to Network	8%
	Time to Connect	5%
	Service Availability	10%
	Power Output	25%
	Block Loading Size	10%
	Resilience of Supply	20%
	Contribution to System Stability	12%
	Contribution to Restoration Time	10%
<b>Commercial 50%</b>	Total costs £/Settlement Period (87,648 SPs)	100%

## 3.1 Requirements

### 3.1.1 Connection to Network

The restoration under the current Restoration Strategy for GB follows a top-down approach: re-energisation of the NETS followed by restoration of demand. The point at, and way in, which a potential contracted provider is connected has an impact on the speed of restoration.

Transmission connected providers are able to progress with the energisation of the NETS without having to energise (part) of a Distribution Network first. This also simplifies the initial stages of restoration and allows for all of the reactive capability of those providers to be used in the expansion of the NETS.

Where a contracted Restoration Service Provider has more than one connection onto the Network, that increases the likelihood of availability of that specific Service Provider under a full or partial National Power Outage event.

Resilience is also affected by geographical locations, and diversification of technologies.

		Score (%)
Connection to the Network (8%)	Transmission Connected	2
	Distribution Connected	0
	Multiple connections to the Network	3
	Single connection to the Network	0
	Other contracted Service Provider(s) in the same Substation (if NO)	3

### 3.1.2 Time to Connect

Contracted providers with the ability to self-start will have different challenges to Start-Up and will be able to contribute to Restoration at different stages.

				Score (%)
Time to Connect (5%)	Phase 1	$0h < t \leq 2h$		5
	Phase 2	$2h < t \leq 24h$		2
	Phase 3	$24h < t \leq 72h$		1

### 3.1.3 Service Availability

Contracted Restoration Service Providers are expected to have a high restoration service availability so that they can be relied upon in the instance of a Total or Partial shutdown, which could happen at any time.

			Score (%)
Service Availability (10%)	$80\% \leq SA < 85\%$		2
	$85\% \leq SA < 90\%$		6
	$SA \geq 90\%$		10

### 3.1.4 Power Output

A higher active and reactive capability will support a faster restoration.

Reactive Capability (10%) (MVar > 0, MW = 0)	MVar	Score (%)
	$50 \leq RC < 100$	2
	$100 \leq RC < 150$	6
	$RC \geq 150$	10
Active Capability (15%)	MW	Score (%)
	$P \leq 100$	2
	$100 < P \leq 200$	6
	$200 < P \leq 350$	10
	$P > 350$	15

### 3.1.5 Block Loading

Blocks of bigger size will require less switching and will contribute to speed up Restoration.

Block Loading Size (10%)	Score (%)	
	$10 \leq BLS < 15$	2
	$15 \leq BLS < 20$	6
	$BLS \geq 20$	10

### 3.1.6 Resilience of Supply

After a shutdown the ESO will work to restore demand as quickly as possible. Returning to a normal system operation will not resume for a while after the event, so the ability of contracted Restoration Service Providers to contribute to different stages of Restoration will be valued.

Restoration Service at Contracted Output	Time (hours)	Score (%)
	$10 \leq t < 24$	2
	$24 \leq t < 72$	6
	$72 \leq t < 120$	10
	$t \geq 120$	15

Electricity System Restoration Auxiliary Unit(s)	Time (hours)	Score (%)
	$72 \leq t < 120$	2
	$t \geq 120$	5

### 3.1.7 Contribution to System Stability

Throughout restoration and particularly during block loading, contracted Restoration Service Providers will need to manage and be able to withstand larger frequency deviations than normal within their power island (47.5Hz – 52Hz). Providers that can contribute to inertia of the power island will reduce the risk of trips/restarts. Also, throughout restoration, the higher the Short-Circuit Level the more robustly voltage and voltage angle movement will be contained across larger network and load energisation, allowing a power island to be developed faster.

#### 3.5.8.1 Short-Circuit Level

**$t \leq 80\text{ms}$  following the start of a system disturbance**

kA	Score (%)
$I \geq \frac{240 \text{ [MVA]}}{\sqrt{3} \cdot U}$	2
$I \geq \frac{360 \text{ [MVA]}}{\sqrt{3} \cdot U}$	3
$I \geq \frac{480 \text{ [MVA]}}{\sqrt{3} \cdot U}$	4

**$> 80\text{ms}$  following the start of a system disturbance**

kA	Score (%)
$I \geq \frac{100 \text{ [MVA]}}{\sqrt{3} \cdot U}$	1
$I \geq \frac{150 \text{ [MVA]}}{\sqrt{3} \cdot U}$	2
$I \geq \frac{200 \text{ [MVA]}}{\sqrt{3} \cdot U}$	3

$U \equiv$  connection voltage [kV]

#### 3.5.8.2 Contribution to Inertia

Inertia	MVA.s	Score (%)
	$400 \leq \text{Inertia} < 800$	1
	$800 \leq \text{Inertia} < 1200$	3
	$\text{Inertia} \geq 1200$	5

### 3.1.8 Contribution to Restoration Time

The ESO's plan, as defined under the current Strategy, is to achieve an average Restoration Time across the year of 24 hours to restore 60% of national demand. To assess that Restoration Time a model has been developed by the ESO (validated by BEIS and Ofgem) and is the tool used to monitor Restoration performance.

By end 2026, the ESO will be obligated to meet the future Electricity System Restoration Standard (ESRS) target to restore 60% of regional demand within 24 hours and 100% within 5 days.

The ESO is considering further developments in the model to accommodate individual contributions from contracted Service Providers to Zonal Restoration Times.

**Primary Restoration Service Providers: 10%**

## Next Steps

Please read all sections within this document, if you have any questions about any of the information provided please submit them using Appendix 4 – Query Form to [manpreet.patel@nationalgrideso.com](mailto:manpreet.patel@nationalgrideso.com) and CC [roopkamal.phull@nationalgrideso.com](mailto:roopkamal.phull@nationalgrideso.com) marked 'Tender Query'.

The EOI stage closes on the **3<sup>rd</sup> February 2023 at 17:00hrs**. All EOI submissions should be emailed to [manpreet.patel@nationalgrideso.com](mailto:manpreet.patel@nationalgrideso.com) and CC [roopkamal.phull@nationalgrideso.com](mailto:roopkamal.phull@nationalgrideso.com) before the deadline. Failure to do so will result in a non compliant submission. For the avoidance of doubt the list of documents that need to be submitted at EOI stage are detailed below.

- Appendix 2 – Wind Tender EOI Tender submission and technical requirement declaration form – Section 1 and 2 Completed
- Appendix 3 Wind Tender Non-disclosure agreement – Completed and signed