



Standards for Transmission Connected Generators

Damian Jackman

Current Situation



- Three separate GB standards
 - Further SO common standards
 - Further standards possible? (OFTOs, new owners?)
-
- Connection costs may vary from region to region – no level playing field
 - Time and cost to check connection design against each region's standards
 - Lack of transparency and governance – justification for variation and updates to the standards?

Example of Variations between Standards

Section	NGET Values	SPT Values
Short Circuit Currents	<p>Section 2.6 Primary Currents</p> <p>400 kV and 275 KV DC time constant is 45ms</p> <p>400 kV / 275 KV short circuit withstand is 63 kA / 40 kA</p>	<p>Section 11.1 Short Circuit Reqs</p> <p>400 kV and 275 KV DC time constant is 60ms</p> <p>400 kV and 275 KV short circuit withstand is 55 kA / 40 kA</p>

Why are short circuit ratings different – is the worst case being applied across entire region?



Sources:

- SPT: "SPTS 1- Ratings and general requirements for Plant, Equipment and Apparatus for connection to The Company's system, BETTA-11-001"
- NGET: "Ratings and Requirements for Plant, Equipment and Apparatus for the National Grid System TS1 2014 Draft"

Potential Solution

- **Single set of Specifications**
- **Variations permitted but**
 - **All listed in a single document**
 - **Justification given for each variation**
- **Specifications held by independent body (e.g ENA)**
- **Written and managed by representatives of each TO**
- **Clear process to record updates and justification for changes**



Thank you

