

List of Users who will be required to provide EMT Models to The Company

Bilateral Connection Agreement Type	Technology	Provision of EMT model
Directly Connected (Bilateral Connection Agreement)	DC Converter Station / HVDC System	Yes
Directly Connected (Bilateral Connection Agreement)	Non- Synchronous Generator	Yes
	OTSDUW	Yes
	Synchronous Generator	Yes
Bilateral Embedded Generator Agreement (BEGA) – Large Power Station	Non- Synchronous Generator	Yes
	Synchronous Generator	Yes
Bilateral Embedded Generator Agreement (BEGA) – Medium Power Station	Non-Synchronous Generator	Yes
	Synchronous Generator	Yes
Bilateral Embedded Generator Agreement (BEGA) – Small Power Station	Non-Synchronous Generator	No
	Synchronous Generator	No
Bilateral Embedded Licence Exemptible Large Power Station Agreement (BELLA)	Non - Synchronous Generator	Yes
	Synchronous Generator	Yes
Embedded Medium Power Stations (LEEMPS— Embedded Medium Power Stations not subject to a Bilateral Agreement) Note: Data to be provided by Network Operator to The Company	Non-Synchronous Generator	Yes
	Synchronous Generator	Yes
Network Operator – Bilateral Connection Agreement (BCA)	Dynamic Reactive Compensation Equipment	Yes
Non-Embedded Customers - Bilateral Connection Agreement (BCA)	Transmission Connected Demand excluding Network Operators, e.g., data centres, electrolyzers etc.	Yes