

National Electricity Transmission System Security and Quality of Supply Standard

Version 2.13

Contents

1. Introduction	3
2. Generation connection Criteria Applicable to the <i>Onshore Transmission System</i>	11
3. Demand Connection Criteria Applicable to the <i>Onshore Transmission System</i>	16
4. Design of the Main Interconnected Transmission System	22
5. Operation of the Onshore Transmission System	26
6. Voltage Limits in Planning and Operating the Onshore Transmission System	30
7. Generation Connection Criteria Applicable to an Offshore Transmission System	37
8. Demand Connection Criteria Applicable to an <i>Offshore Transmission System</i>	45
9. Operation of an Offshore Transmission System	48
10. Voltage Limits in Planning and Operating an <i>Offshore Transmission System</i> ...	50
11. Terms and Definitions.....	51
Appendix A. Recommended Substation Configuration and Switching Arrangements ...	67
Appendix B. Circuit Complexity on the <i>Onshore Transmission System</i>	71
Appendix C. Modelling of Security Planned Transfer	73
Appendix D. Application of the <i>Interconnection Allowance</i>	75
Appendix E. Modelling of <i>Economy Planned Transfer</i>	78
Appendix F. Application of the <i>Boundary Allowance</i>	80
Appendix G. Guidance on Economic Justification	82
Appendix H. Frequency Risk and Control Report Methodology and Application	84
Appendix I. System Restoration Requirements	89
Appendix J. Governance Framework	90

1. Introduction

Role and Scope

- 1.1 Pursuant to conditions, D3 and E16 of the *transmission licences* and condition E7 of the *ESO licence*, this Security and Quality of Supply Standard (the “Standard”) sets out a coordinated set of criteria and methodologies (for example cost-benefit techniques and weather related operation) that *Licensees* shall use in the planning and operation of the *national electricity transmission system of Great Britain*. This Standard is administered by the *NETS SQSS panel* who will consider, develop, and submit to *the Authority*, proposals to modify the contents of the documents as required to ensure its objectives, as defined in licence condition E7 of the *ESO licence*, are met at all times. In developing such proposals, the *NETS SQSS panel* will ensure industry participation. The constitution of the *NETS SQSS panel* and its procedures are set out in Appendix J of this Standard. For the avoidance of doubt the *national electricity transmission system* is made up of both the *onshore transmission system* and the *offshore transmission systems*.
- 1.2 Both planning and operational criteria are set out in this Standard and these will determine the need for services provided to the relevant *Licensees*, e.g. reactive power as well as transmission equipment. The planning criteria set out the requirements for the *transmission capacity* (either investment or purchase of services) for the *national electricity transmission system*. The planning criteria set out the requirements for the *transmission capacity* (either investment or purchase of services) for the *national electricity transmission system*. The planning criteria also require consideration to be given to the operation and maintenance of the *national electricity transmission system* and so refer to the associated operational criteria where appropriate. The operational criteria are used in real time and in the development of plans for using the *national electricity transmission system* to permit satisfactory operation.
- 1.3 Additional criteria, for example covering more detailed and other aspects of quality of supply, are contained in the Grid Code and the SO-TO Code, which should be read in conjunction with this document.
- 1.4 *External interconnections* between the *onshore transmission system* and *external systems* (e.g. in Ireland & France) are covered by separate agreements, which will normally be consistent with this Standard. This Standard may be specifically referenced in the relevant agreements and shall apply to the extent of that reference.
- 1.5 The consideration of *secured events* as defined in this Standard may lead to the identification of inadequate capability of equipment or systems not owned or operated by the *Licensees* (for example, the overloading of lower voltage connections between *grid supply points*). In such cases the *Licensees* will notify the *network operators* affected. Reinforcement or alternative operation of the *national electricity transmission system* to alleviate inadequacies of equipment or systems not owned or operated by the *Licensees* would be undertaken where it is agreed by the *network operators* affected and the relevant *Licensees*.
- 1.6 The criteria presented in this Standard represent the minimum requirements for the planning and operation of the *national electricity transmission system*. While it is a requirement for *transmission capacity* to meet the planning criteria, it does not follow that the *transmission capacity* should be reduced so that it only meets the minimum

requirement of those criteria. For example, it may not be beneficial to reduce the ratings of lines to reflect lower loading levels which have arisen due to changes in the generation or demand patterns.

Document Structure

- 1.7 This Standard contains technical terms and phrases specific to *transmission systems* and the Electricity Supply Industry. The meanings of some terms or phrases in this Standard may also differ from those commonly used. For this reason a 'Terms and Definitions' has been included as Section 11 to this document. All defined terms have been identified in the text by the use of *italics*.
- 1.8 The criteria and methodologies applicable to the *onshore transmission system* differ in certain respects from those applicable to the *offshore transmission systems*. In view of this, the two sets of criteria and methodologies are presented separately for clarity. The criteria and methodologies applicable to the *onshore transmission system* are presented in Sections 2 to 6 and the criteria and methodologies applicable to *offshore transmission systems* are presented in Sections 7 to 10.

Onshore Criteria and Methodologies

- 1.9 For ease of use, the criteria and methodologies relating to the planning of the *onshore transmission system* have been presented according to the functional parts of the *onshore transmission system* to which they primarily apply. These parts are the *generation points of connection* at which *power stations* feed into the *main interconnected transmission system (MITS)* through the remainder of the *MITS* to the *grid supply points (GSP)* where demand is connected. These parts are illustrated schematically in Figure 1.1.




Figure 1.1 The *onshore transmission system* with a directly connected *power station*

- 1.10 The generation connection criteria applicable to the *onshore transmission system*

are set out in Section 2 and cover the connections which extend from the *grid entry points* and reach into the *MITS*. The criteria also cover the risks affecting the *national electricity transmission system* arising from the *generation circuits*.

- 1.11 The demand connection criteria applicable to the *onshore transmission system* are given in Section 3 and cover the connections which extend from the lower voltage side of the *GSP* transformers and again reach into the *MITS*.
- 1.12 Section 4 sets out the criteria for minimum *transmission capacity* on the *MITS*, which extends from the *generation points of connection* through to the *demand points of connection* on the high voltage side of the *GSP* transformers.
- 1.13 The criteria relating to the operation of the *onshore transmission system* are presented in Section 5.

Offshore Criteria and Methodologies

- 1.14 For ease of use, the criteria and methodologies relating to the planning of the *offshore transmission systems* have also been presented according to the functional parts of an *offshore transmission system* to which they primarily apply. An *offshore transmission system* extends from the *offshore grid entry point/s* at which *offshore power stations* feed into the *offshore transmission system* through the remainder of the *offshore transmission system* to the point of connection of the *offshore transmission system* at the *first onshore substation*. This point of connection at the *first onshore substation* is the *interface point* in the case of a direct connection to the *onshore transmission system* or the *user system interface point* in the case of a connection to an onshore *user system*.
- 1.15 The *first onshore substation* may be owned by the *offshore Licensee*, the *onshore Licensee* or onshore *user system* owner. Ownership boundaries are determined by the relevant *Licensees* and/or *distribution licensees* (as the case may be). Normally, and unless otherwise agreed, in the case of there being AC transformation or DC conversion facilities at the *first onshore substation* if the *offshore transmission owner* owns the *first onshore substation*, the *interface point* or *user system interface point* (as the case may be) would be on the HV *busbars*. If the *first onshore substation* is owned by the onshore transmission owner or onshore *user system* owner, the *interface point* or *user system interface point* (as the case may be) would be on the LV *busbars*. In the case of the former, the *first onshore substation* must meet the criteria relating to *offshore transmission systems* and, in the case of the latter the *first onshore substation* must meet the appropriate onshore criteria.
- 1.16 The functional parts of an *offshore transmission system* include:
 - the *offshore* connection facilities on the *offshore platform/s*, which may include:
 - 1.16.1 the *offshore grid entry point/s (GEP)* at which *offshore power stations* feed into an *offshore transmission system*;
 - 1.16.2 any *offshore supply point/s (OSP)* where *offshore power station* demand is supplied from an *offshore transmission system*; or
 - 1.16.3 AC or DC *offshore transmission circuits*.
 - the cable circuit/s which may include:
 - 1.16.4 AC or DC cable *offshore transmission circuits* connecting an *offshore*

platform either directly to an onshore overhead line forming part of the *offshore transmission system* or to onshore connection facilities forming part of the *offshore transmission system*.

an overhead line section, which may include:

- 1.16.5 AC or DC overhead line *offshore transmission circuits* connecting the cable *offshore transmission circuits* either directly to the *first onshore substation* or to onshore AC transformation or AC/DC conversion facilities not forming part of the *first onshore substation*.

onshore connection facilities, which may include:

- 1.16.6 AC/DC conversion facilities connecting DC overhead line or DC cable *offshore transmission circuits* to the *interface point* or *user system interface point* (as the case may be). Such facilities may constitute the *first onshore substation*; or
- 1.16.7 AC transformation facilities connecting AC overhead line or AC cable *offshore transmission circuits* to the *interface point* or *user system interface point* (as the case may be). Such facilities may constitute the *first onshore substation*.

- 1.17 The above functional parts of an *offshore transmission system* are illustrated schematically in Figure 1.2. There are many variations to the form of an *offshore transmission system*. Figure 1.2, and Figure 1.3, illustrate just two such examples. The *offshore generator* has the option to connect to an *offshore transmission system* at a voltage level (in that system) of their choosing. Accordingly, the *offshore GEP* can be at a voltage level of the generator's choosing and the extent of the *offshore* generation connection criteria would vary accordingly. However, under the default arrangements, the *offshore* generator's circuits cannot be wholly or mainly at a voltage level of 132 kV or above since such a combination of circuits would then constitute part of an *offshore transmission system*. Please note that, while Figure 1.2, and Figure 1.3, have been drawn such that they represent the functional parts of an AC *offshore transmission system*, they are equally representative of the functional parts of a DC *offshore transmission system*.




Figure 1.2 An offshore transmission system with a directly connected power station and first onshore substation owned by the offshore transmission owner




Figure 1.3 The offshore transmission system with a directly connected power station and first onshore substation owned by the onshore transmission owner or onshore distribution owner

- 1.18 The boundaries between functional parts of an *offshore transmission system* will vary according to circumstances. In the example illustrated in Figure 1.3, the *first onshore substation* is owned by the *onshore transmission system* owner or *user system* owner. Accordingly, the *interface point* or *user system interface point*, as the case may be, would be at the lower voltage side rather than the higher voltage side of the transformers at the *first onshore substation*. Similarly, the extent of the *offshore* generation and demand connection criteria also move with the *interface point* or *user system interface point*. The *first onshore substation* forms part of the *onshore transmission system* or *onshore user system* as the case may be.
- 1.19 The generation connection criteria applicable to an *offshore transmission system* are set out in Section 7 and cover the connections which extend from the *offshore grid entry points*, through the *offshore transmission system*, to the *interface point* or *onshore user system interface point*, as the case may be.
- 1.20 The demand connection criteria applicable to an *offshore transmission system* are given in Section 8 and cover the connection of station demand at the *offshore platform*. These criteria extend from the *offshore supply point (OSP)* on the *offshore platform* through the *offshore transmission system* to the *onshore interface point* or *onshore user system interface point*, as the case may be.
- 1.21 The criteria relating to the operation of an *offshore transmission system* are presented in Section 9.
- 1.22 Voltage limits for use in planning and operating an *offshore transmission system* are presented in Section 10.

Overlap of Criteria

- 1.23 As described above, and illustrated in Figures 1.1, 1.2 and 1.3, there will be parts of the *national electricity transmission system* where more than one set of criteria apply. In such places the requirements of all relevant criteria must be met. Particular examples are:
- 1.23.1 should an *offshore transmission system* be connected to the onshore *MITS* by two or more *AC offshore transmission circuits* routed to different onshore substations or to separate *busbar* sections at the same onshore substation, those *AC offshore transmission circuits* would parallel the *MITS*. In such cases the onshore criteria would also apply to the relevant sections of the *offshore transmission system*;
- 1.23.2 where sites are composite and have a mixture of demand connections and generation connections, the security afforded to the block of demand customers shall be not less than that provided for a standard demand connection of an identical size. The applicable security standard should therefore be the more secure of the corresponding criteria of Section 2 or Section 3. Specifically excluded from this category is a generation site with on-site station demand. Such sites shall be treated as a generation site connected to the *onshore transmission system* with appropriate security levels; or
- 1.23.3 where some sections of a *transmission licensee's transmission system* extends between *NGET's transmission system* and/or *SPT's transmission system* and/or *SHET's transmission system*, where

different criteria apply, that section would have to meet the criteria applicable to the *transmission systems* it extends between; *NGET's transmission system* and/or *SPT's transmission system* and/or *SHET's transmission system*.

1.24 Directions related to National Security

- 1.24.1 The Secretary of State may issue a direction to the *ISOP* as referred to in condition B4 of the *ESO licence* where in the opinion of the Secretary of State there is a risk relating to national security that may detrimentally impact the resilience, safety or security of the energy system, or the continuity of essential services, and it is in the interest of national security that a direction should be issued to the *ISOP*.
- 1.24.2 The *ISOP* must comply with any such direction that has been issued by the Secretary of State. *Licensees* should note that the *ISOP* is not required to comply with any other obligation in the *ESO licence* where and to the extent that compliance with that obligation would be inconsistent with the requirement to comply with such a direction, for the period set out in the direction. This includes the requirement set out in condition E3 of the *ESO licence* to comply with this Standard.
- 1.24.3 The *ISOP* is required under condition B4 of its *ESO licence* to inform the Secretary of State of any conflict with the obligations as identified in 1.24.2 as soon as reasonably practicable after the conflict is identified. The *ISOP* will include in such a notice, details of any identified impact or non-compliance that will be caused or will be likely to be caused to *Licensees*, and in such a case will also seek clarification of whether this can be shared with the affected *Licensee*.
- 1.24.4 Where reasonably practicable and subject to the agreement of the Secretary of State to share any such specific details, the *ISOP* will inform affected *Licensees* as identified in 1.24.3 of what actions the *ISOP* will or has taken, or not taken, to comply with a direction or amended direction (including when such a direction is revoked) and what identified impact or non-compliance this will or is likely to cause to the *Licensee*.
- 1.24.5 The *ISOP's* obligations under this Standard shall be suspended without liability where and to the extent that compliance with any such obligation would be inconsistent with the requirement upon the *ISOP* to comply with a direction.
- 1.24.6 A *Licensee's* obligations under this Standard shall be suspended without liability where and to the extent that the *Licensee* is unable to comply with any such obligation as a result of any action taken, or not taken, by the *ISOP* to comply with a direction.
- 1.24.7 The Secretary of State may at any time amend or revoke any direction issued to the *ISOP* as referred to in condition B4 of the *ESO licence*.

1.25 Advisory and Information Requests

- 1.25.1 The *ISOP* is required to provide advice, analysis or information to the *Authority* or to a *Minister of the Crown* when requested in accordance

with section 171 of the Energy Act 2023 and condition D1 of the *ESO licence* and *gas system planner licence*.

1.25.2 The *ISOP* may by notice request from Users such information as it reasonably requires in connection with the exercise of any of its functions, in accordance with section 172 of the Energy Act 2023. It will do so by the issue of an *information request notice*. The purposes of this may include to assist in the fulfilment of a request for advice, analysis or information as set out in 1.25.1.

1.25.3 The *ISOP* is required by condition D2 of the *ESO licence* and *gas system planner licence* to prepare, submit for approval by the *Authority* and publish on its website once approved an *information request statement* that sets out further detail on the process the *ISOP* expects to follow when requesting information from other parties.

The *Information request statement* must include, but need not be limited to, the following matters as set out in condition D2(5) of the *ESO licence* and *gas system planner licence*:

(a) the process the *ISOP* expects to follow when issuing an *information request notice*, including any further detail around the expected engagement between the *ISOP* and recipient of an *information request notice*; and

(b) the details to be included in an *information request notice* issued by the *ISOP*.

1.25.4 A User to whom a request is made under 1.25.2 must, so far as reasonably practicable, provide the requested information within such reasonable period, and in such reasonable form and manner, as may be specified in the *information request notice*.

1.25.5 The *ISOP* must, unless the *Authority* otherwise consents, maintain for a period of 6 years and provide to the *Authority* where required a record of information requests as detailed in condition D2.12 of the *ESO licence* and *gas system planner licence* including:

(a) a copy of the *information request notice*;

(b) any subsequent variations to the original information requested;

(c) the recipient's response to the notice, including any refusal or challenges to the notice or requested information;

(d) the time taken for the recipient to provide the requested information;

(e) the manner and form the information was provided in; and

(f) the information provided in response to the notice, and whether such information complied, in the *ISOP*'s view, with the *information request notice*.

1.25.6 For the purpose of paragraph 1.25, "User" means a *Licensee* other than the *ISOP*.

2. Generation connection Criteria Applicable to the *Onshore Transmission System*

- 2.1 This section presents the planning criteria applicable to the connection of one or more power stations to the *onshore transmission system*. The criteria in this section will also apply to the connections from a *GSP* to the *onshore transmission system* by which power stations embedded within a customer's network (e.g. distribution network) are connected to the *onshore transmission system*.
- 2.2 In those parts of the *onshore transmission system* where the criteria of Section 3 and/or Section 4 also apply, those criteria must also be met.
- 2.3 In planning generation connections, this Standard is met if the connection design either:
- 2.3.1 satisfies the deterministic criteria detailed in paragraphs 2.5 to 2.13; or
 - 2.3.2 varies from the design necessary to meet paragraph 2.3.1 above in a manner which satisfies the conditions detailed in paragraphs 2.15 to 2.18.
- 2.4 It is permissible to design to standards higher than those set out in paragraphs 2.5 to 2.13 provided the higher standards can be economically justified. Guidance on economic justification is given in Appendix G.

Limits to *Loss of Power Infeed Risks*

- 2.5 For the purpose of applying the criteria of paragraph 2.6, the *loss of power infeed* resulting from a *secured event* on the *onshore transmission system* shall be calculated as follows:
- 2.5.1 the sum of the registered capacities of the *generating units* disconnected from the system by a *secured event*, plus
 - 2.5.2 the planned import from any external systems disconnected from the system by the same event, less
 - 2.5.3 the forecast minimum demand disconnected from the system by the same event but excluding (from the deduction) any demand forming part of the forecast minimum demand which may be automatically tripped for system frequency control purposes and excluding (from the deduction) the demand of the largest single end customer.
- 2.6 Generation connections shall be planned such that, starting with an *intact system*, the consequences of *secured events* on the *onshore transmission system* shall be as follows:
- 2.6.1 following a *fault outage* of any single *transmission circuit*, no *loss of power infeed* shall occur;
 - 2.6.2 following the *planned outage* of any single section of *busbar* or mesh corner, no *loss of power infeed* shall occur;
 - 2.6.3 following a *fault outage* of any *single generation circuit* or single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the

infrequent infeed loss risk;

- 2.6.4 following the concurrent *fault outage* of any *two transmission circuits*, or any *two generation circuits* on the same *double circuit overhead line*, or the *fault outage* of any single *busbar* coupler circuit breaker or *busbar* section circuit breaker or mesh circuit breaker, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
 - 2.6.5 following the *fault outage* of any single *transmission circuit*, single section of *busbar* or mesh corner, during the *planned outage* of any other single *transmission circuit* or single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
 - 2.6.6 following the *fault outage* of any single *busbar* coupler circuit breaker or *busbar* section circuit breaker or mesh circuit breaker, during the *planned outage* of any single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.
- 2.7 The maximum length of overhead line connections in a *generation circuit* for *generating units* which are directly connected to the *onshore transmission system* shall not exceed:
- 2.7.1 5km for *generating units* of expected annual energy output greater than or equal to 2000GWh; otherwise
 - 2.7.2 20km.

Generation Connection Capacity Requirements

Background conditions

- 2.8 The connection of a particular *power station* shall meet the criteria set out in paragraphs 2.9 to 2.13 under the following background conditions:
- 2.8.1 the active power output of the *power station* shall be set equal to its *registered capacity* or, for the purpose of *sub-synchronous oscillations* studies, that which provides the lowest level of damping for the sub-synchronous mode under consideration;
 - 2.8.2 the reactive power output of the *power station* shall be set to the full leading or lagging output that corresponds to an active power output equal to its *registered capacity*, or for the purpose of assessment of system stability and voltage control issues, that which may reasonably be expected under the conditions described in paragraph 2.8.4;
 - 2.8.3 for connections to an *offshore transmission system*, the reactive power output of the *offshore power station/s* shall normally, and unless otherwise agreed, be set to deliver zero reactive power at the *offshore grid entry point* with active power output equal to its *registered capacity*; and the reactive power delivered at the *interface point* shall be set in accordance with the reactive requirements placed on the *offshore Licensee* set out in Section K of the STC (System Operator – Transmission Owner Code); and
 - 2.8.4 conditions on the *onshore transmission system* shall be set to those

which ought reasonably to be expected to arise in the course of a year of operation. Such conditions shall include forecast demand cycles, typical *power station* operating regimes and typical *planned outage* patterns modified where appropriate by the provisions of paragraph 2.11.

Pre-fault criteria

2.9 The *transmission capacity* for the connection of a *power station* shall be planned such that, for the background conditions described in paragraph 2.8, prior to any fault there shall not be any of the following:

- 2.9.1 equipment loadings exceeding the *pre-fault rating*;
- 2.9.2 voltages outside the *pre-fault planning voltage limits* or *insufficient voltage performance margins*;
- 2.9.3 *system instability*; or
- 2.9.4 *unacceptable sub-synchronous oscillations*.

Post-fault criteria – background condition of no *local system outage*

2.10 The *transmission capacity* for the connection of a *power station* shall also be planned such that for the background conditions described in paragraph 2.8 with no *local system outage* and for the *secured event* of a *fault outage* on the *onshore transmission system* of any of the following:

- 2.10.1 a single *transmission circuit*, a single *generation circuit*, a single *generating unit* (or several *generating units* sharing a common circuit breaker), a single *Power Park Module*, or a single *DC converter*, a reactive compensator or other reactive power provider;
- 2.10.2 a *double circuit overhead line* on the *supergrid*;
- 2.10.3 a *double circuit overhead line* where any part of either circuit is in *NGET's transmission system* or *SHET's transmission system*;
- 2.10.4 a single *transmission circuit* with the prior outage of another *transmission circuit*;
- 2.10.5 a section of *busbar* or mesh corner;
- 2.10.6 a single *transmission circuit* with the prior outage of a *generation circuit*, *generating unit* (or several *generating units*, sharing a common circuit breaker, that cannot be separately isolated), a *power park module*, a *DC converter*, a reactive compensator or other reactive power provider; or
- 2.10.7 a single *generation circuit*, a single *generating unit* (or several *generating units*, sharing a common circuit breaker), a single *Power Park Module*, a single *DC converter*, a reactive compensator or other reactive power provider with the prior outage of a single *transmission circuit*,

there shall not be any of the following:

- 2.10.8 a *loss of supply capacity* except as permitted by the demand connection criteria detailed in Section 3;
- 2.10.9 *unacceptable overloading* of any *primary transmission equipment*;

- 2.10.10 *unacceptable voltage conditions or insufficient voltage performance margins;*
 - 2.10.11 *system instability; or*
 - 2.10.12 *unacceptable sub-synchronous oscillations.*
- 2.11 Under *planned outage* conditions it shall be assumed that the prior circuit outage specified in paragraphs 2.10.3, 2.10.5 and 2.10.6 reasonably forms part of the typical outage pattern referred to in paragraph 2.8.4 rather than in addition to that typical outage pattern.

Post-fault criteria – background condition with a *local system outage*

- 2.12 The *transmission capacity* for the connection of a *power station* shall also be planned such that for the background conditions described in paragraph 2.8 with a *local system outage* on the *onshore transmission system*, the operational security criteria set out in Section 5 and Section 9 can be met.
- 2.13 Where necessary to satisfy the criteria set out in paragraph 2.12, investment should be made in *transmission capacity* except where operational measures suffice to meet the criteria in paragraph 2.12 provided that maintenance access for each *transmission circuit* can be achieved and provided that such measures are economically justified. The operational measures to be considered include rearrangement of transmission outages and appropriate reselection of *generating units* from those expected to be available, for example through *balancing services*. Guidance on economic justification is given in Appendix G.

Switching Arrangements

- 2.14 Guidance on substation configurations and switching arrangements are described in Appendix A. These guidelines provide an acceptable way towards meeting the criteria of paragraph 2.6. However, other configurations and switching arrangements which meet those criteria are also acceptable.

Variations to Connection Designs

- 2.15 Variations, arising from a generation customer's request, to the generation connection design necessary to meet the requirements of paragraphs 2.5 to 2.13 shall also satisfy the requirements of this Standard provided that the varied design satisfies the conditions set out in paragraphs 2.16.1 to 2.16.3. For example, such a generation connection design variation may be used to take account of the particular characteristics of a *power station*.
- 2.16 Any generation connection design variation must not, other than in respect of the generation customer requesting the variation, either immediately or in the foreseeable future:
- 2.16.1 reduce the security of the *MITS* to below the minimum planning criteria specified in Section 4; or
 - 2.16.2 result in additional investment or operational costs to any particular customer or overall, or a reduction in the security and quality of supply of the affected customers' connections to below the planning criteria in this section or Section 3, unless specific agreements are reached with

affected customers; or

- 2.16.3 compromise any *Licensee's* ability to meet other statutory obligations or licence obligations.
- 2.17 Should system conditions subsequently change, for example due to the proposed connection of a new customer, such that either immediately or in the foreseeable future, the conditions set out in paragraphs 2.16.1 to 2.16.3 are no longer satisfied, then alternative arrangements and/or agreements must be put in place such that this Standard continues to be satisfied.
- 2.18 The additional operational costs referred to in paragraph 2.16.2 and/or any potential reliability implications shall be calculated by simulating the expected operation of the *national electricity transmission system* in accordance with the operational criteria set out in Section 5 and Section 9. Guidance on economic justification is given in Appendix G.

3. Demand Connection Criteria Applicable to the *Onshore Transmission System*

- 3.1 This section presents the planning criteria for the connection of *demand groups* to the remainder of the *onshore transmission system*.
- 3.2 In those parts of the *onshore transmission system* where the criteria of Section 2 and/or Section 4 also apply, those criteria must also be met.
- 3.3 In planning demand connections, this standard is met if the connection design either:
 - 3.3.1 satisfies the deterministic criteria detailed in paragraphs 3.5 to 3.12; or
 - 3.3.2 varies from the design necessary to meet paragraph 3.3.1 above in a manner which satisfies the conditions detailed in paragraphs 3.17 to 3.20.
- 3.4 It is permissible to design to standards higher than those set out in paragraphs 3.5 to 3.12 provided the higher standards can be economically justified. Guidance on economic justification is given in Appendix G.

Demand Connection Capacity Requirements

- 3.5 The *group demand* which is applicable for the assessment of connection capacity requirements is dependent on the nature of the associated connections, i.e.:
 - 3.5.1 where the network associated with a transmission connection comprises demand connections and connections to *small power stations* or *medium power stations* (including those in composite-user sites), *group demand* for future years is equal to the *network operator's* estimated maximum demand for the group which they believe could reasonably be imposed on the *onshore transmission system*, after taking due cognisance of demand diversity and the expected operation of any embedded *small* or *medium power stations*.
 - 3.5.2 where the network associated with a transmission connection hosts the connection of one or more *large power stations*, irrespective of whether the *large power station* is connected at the transmission interface point or embedded within the *network operator's* system, the *group demand* at the date and time of the system/site maximum demand or other relevant assessment period is equal to:
 - 3.5.2.1 the *network operator's group demand* in accordance with paragraph 3.5.1, plus:
 - 3.5.2.2 the output of *large power station(s)*.
- 3.6 Where considered appropriate, diversity may be applied to the summation of the power flows arising from consideration of paragraphs 3.5.2.1 and 3.5.2.2.
- 3.7 The *transmission capacity* for the connection of a particular *demand group* shall meet the criteria set out in paragraphs 3.7 to 3.11 under the following background conditions:
 - 3.7.1 when there are no *planned outages*, the demand of the *demand group* shall be set equal to *group demand*;

- 3.7.2 when there is a *planned outage* local to the *demand group*, the demand of the *demand group* shall be set equal to *maintenance period demand*;
 - 3.7.3 the security contribution of *small power stations* and *medium power stations* embedded is implicitly accounted for in the group demand established by the *network operator* as in paragraph 3.5.1 and need not be considered separately;
 - 3.7.4 the security contribution of a *large power station* embedded within a customer's network (e.g. distribution network) or connected at the transmission interface point shall be as specified in paragraphs 3.13 to 3.15 and Table 3.2;
 - 3.7.5 any *transfer capacity* (i.e. the ability to transfer demand from one *demand group* to another) declared by *network operators* shall be represented taking account of any restrictions on the timescales in which the *transfer capacity* applies. Any *transfer capacity* declared by the *network operators* for use in planning timescales must be reflective of that which could practically be used in operational timescales; and
 - 3.7.6 demand and generation outside the *demand group* shall be set in accordance with the *planned transfer conditions* using the appropriate method described in Appendix C.
- 3.8 The *transmission capacity* for the connection of a *demand group* shall be planned such that, for the background conditions described in paragraph 3.7, under intact system conditions there shall not be any of the following:
- 3.8.1 equipment loadings exceeding the *pre-fault rating*;
 - 3.8.2 voltages outside the *pre-fault planning voltage limits* or *insufficient voltage performance margins*; or
 - 3.8.3 *system instability*.
- 3.9 The *transmission capacity* for the connection of a *demand group* shall also be planned such that for the background conditions described in paragraph 3.7 and for the *planned outage* of a single *transmission circuit* or a single section of *busbar* or mesh corner, there shall not be any of the following:
- 3.9.1 a loss of supply capacity for a group demand of greater than 1 MW;
 - 3.9.2 *unacceptable overloading* of any *primary transmission equipment*;
 - 3.9.3 voltages outside the pre-fault planning voltage limits or *insufficient voltage performance margins*; or
 - 3.9.4 *system instability*.
- 3.10 The *transmission capacity* for the connection of a *demand group* shall also be planned such that for the background conditions described in paragraph 3.7 and the initial conditions of:
- 3.10.1 an intact system condition; or
 - 3.10.2 the single planned outage of another *transmission circuit*, a generation circuit, a *generating unit* (or several *generating units*, sharing a common circuit breaker, that cannot be separately isolated), a power park module, a DC converter, a reactive compensator or other reactive power provider,

for the secured event of a fault outage of:

3.10.3 a single *transmission circuit*; or

3.10.4 a single *generation circuit*, a single *generating unit* (or several *generating units* sharing a common circuit breaker), *power park module* or a *DC converter*,

there shall not be any of the following:

3.10.5 a *loss of supply capacity* such that the provisions set out in Table 3.1 are not met;

3.10.6 *unacceptable overloading* of any *primary transmission equipment*;

3.10.7 *unacceptable voltage conditions* or *insufficient voltage performance margins*; or

3.10.8 *system instability*.

3.11 In addition to the requirements of paragraphs 3.7 to 3.9 for the background conditions described in paragraph 3.7, the system shall also be planned such that:

3.11.1 *operational switching* or *infrequent operational switching* shall not cause *unacceptable voltage conditions*.

3.12 For a *secured event* on connections to more than one *demand group*, the permitted *loss of supply capacity* for that *secured event* is the maximum of the permitted *loss of supply capacities* set out in Table 3.1 for each of these *demand groups*.

Table 3.1 Minimum Planning Supply Capacity Following *Secured Events*

Class	Group Demand		Initial System Conditions	
	Minimum	Maximum	Intact System	With Single <i>Planned Outage Note 1</i>
A	0	£1 MW	In repair time <i>Group Demand</i>	Nil
B	>1 MW	£12 MW	Within 3 hours <i>Group Demand</i> minus 1 MW In repair time <i>Group Demand</i>	Nil
C	>12 MW	£60 MW	Within 15 minutes Smaller of (<i>Group Demand</i> minus 12 MW) and two-thirds of <i>Group Demand</i> Within 3 hours <i>Group Demand</i>	Nil
D	>60 MW	£300 MW	Immediately <i>Group Demand</i> minus 20 MW Note 2 Within 3 hours <i>Group Demand</i>	Within 3 hours Smaller of (<i>Group Demand</i> minus 100 MW) and one-third of <i>Group Demand</i> Within time to restore planned outage <i>Group Demand</i>
E	>300 MW	£1500 MW	Immediately <i>Group Demand Note 3</i>	Immediately <i>Maintenance Period Demand</i> Within time to restore planned outage <i>Group Demand</i>
F	>1500 MW	¥	Immediately <i>Group Demand</i>	Immediately <i>Group Demand</i>

Notes

- 1 The *planned outage* may be of a *transmission circuit, generation circuit, generating unit*, reactive compensator or other reactive power provider.
- 2 The *group demand* may be lost for up to 60 seconds if this leads to significant economies.
- 3 Up to 60 MW may be lost for up to 60 seconds if this leads to significant economies.

Assessment of Contribution to Security from Generation

- 3.13 Where network assets are insufficient to meet the security requirements, it is necessary to assess the contribution to security from *large power stations* connected at either the transmission connection interface or embedded within the *Networks Operator's* system. This will identify whether the aggregate generation capacity of the *large power station* connected to the network has the potential to meet any deficit in system security from network assets.
- 3.14 The combined contribution by *large power stations* shall never have a greater impact on system security than the loss of the largest circuit infeed to the group. The contributions from embedded *small power stations* and *medium power stations* provide additional capacity to enable the supply of demand which may not otherwise be met following a *secured event*, but shall not replace the requirement for system connection. The assessment of contribution of generation to group security will therefore consider;
- 3.14.1 the generation *annual load factor*;
 - 3.14.2 the availability of generation under outage conditions;
 - 3.14.3 the fuel source availability, i.e. whether energy is continuous, stored, storable or predictable;
 - 3.14.4 common-mode failure mechanisms such as common fuel source, connections or plant stability / ride-through capability; and
 - 3.14.5 capping of generation contribution in the event that the generation contribution is dominant with respect to circuit infeed capability.
- 3.15 The effective contribution of *large power stations* to *demand group* importing capacity, shall not exceed the levels indicated in Table 3.2 while taking due account of the considerations detailed in paragraph 3.13.

Table 3.2 Effective contribution of embedded *large power stations* to *demand group* importing capacity in *NGET's transmission system*

Expected <i>annual load factor</i> of generation	Initial system conditions	
	<i>Intact system</i>	with single <i>Planned Outage</i>
Over 30%	67% of <i>Registered Capacity</i>	For demand groups greater than 60 MW only 67% of <i>Registered Capacity</i>
Over 10% to 30%	Smaller of 67% of <i>Registered Capacity</i> and 20% of <i>Group Demand</i>	For demand groups greater than 300 MW only Smaller of 67% of <i>Registered Capacity</i> and 13% of <i>Group Demand</i>
up to 10%	Smaller of 67% of <i>Registered Capacity</i> and 10% of <i>Group Demand</i>	For demand groups greater than 300 MW only Smaller of 67% of <i>Registered Capacity</i> and 7% of <i>Group Demand</i>

Switching Arrangements

- 3.16 Guidance on substation configurations and switching arrangements are described in Appendix A. These guidelines provide an acceptable way towards meeting the criteria of this chapter. However, other configurations and switching arrangements

which meet the criteria are also acceptable.

Variations to Connection Designs

- 3.17 Variations, arising from a demand customer's request, to the demand connection design necessary to meet the requirements of paragraphs 3.5 to 3.12 shall also satisfy the requirements of this Standard provided that the varied design satisfies the conditions set out in paragraphs 3.18.1 to 3.18.3. For example, such a demand connection design variation may be used to reflect the nature of connection of embedded generation or particular load cycles.
- 3.18 Any demand connections design variation must not, other than in respect of the demand customer requesting the variation, either immediately or in the foreseeable future:
 - 3.18.1 reduce the security of the *MTS* to below the minimum planning criteria specified in Section 4; or
 - 3.18.2 result in additional investment or operational costs to any particular customer or overall, or a reduction in the security and quality of supply of the affected customers' connections to below the planning criteria in the section or Section 2, unless specific agreements are reached with affected customers; or
 - 3.18.3 compromise any *Licensee's* ability to meet other statutory obligations or licence obligations.
- 3.19 Should system conditions change, for example due to the proposed connection of a new customer, such that either immediately or in the foreseeable future, the conditions set out in paragraphs 3.18.1 to 3.18.3 are no longer satisfied, then alternative arrangements and/or agreements must be put in place such that this Standard continues to be satisfied.
- 3.20 The additional operational costs referred to in paragraph 3.18.2 and/or any potential reliability implications shall be calculated by simulating the expected operation of the *onshore transmission system* in accordance with the operational criteria set out in Section 5 and Section 9. Guidance on economic justification is given in Appendix G.

4. Design of the Main Interconnected Transmission System

- 4.1 This section presents the planning criteria for the *main interconnected transmission system*.
- 4.2 In those parts of the *onshore transmission system* where the criteria of Section 2 and/or Section 3 also apply, those criteria must also be met. In those parts of the *offshore transmission system* where the criteria of Section 7 and/or Section 8 also apply, those criteria must also be met.
- 4.3 In planning the *MITS*, this Standard is met if the design satisfies the minimum deterministic criteria detailed in paragraphs 4.4 to 4.12. It is permissible to design to standards higher than those set out in paragraphs 4.4 to 4.12 provided the higher standards can be economically justified. Guidance on economic justification is given in Appendix G.

Minimum *Transmission Capacity* Requirements

At ACS peak demand with an intact system

- 4.4 The *MITS* shall meet the criteria set out in paragraphs 4.5 to 4.6 under both the Security and Economy background conditions below:

Security Background

- 4.4.1 *generating units'* outputs shall be set to those arising from the *security planned transfer condition* described in Appendix C;
- 4.4.2 power flows shall be set to those arising from the *security planned transfer condition* (using the appropriate method described in Appendix C) prior to any fault, and such power flows modified by an appropriate application of the *interconnection allowance* (using the methods described in Appendix D) under *secured events*;

Economy Background

- 4.4.3 *generating units'* outputs shall be set to those arising from the *economy planned transfer condition* described in Appendix E;
- 4.4.4 power flows shall be set to those arising from the *economy planned transfer condition* (using the appropriate method described in Appendix E) prior to any fault, and such power flows modified by an appropriate application of the *boundary allowance* (using the methods described in Appendix F) under *secured events*;

Security and Economy Backgrounds

- 4.4.5 sensitivity cases on the conditions described in 4.4.2 and 4.4.4 shall comprise *generating units* with output equal to their *registered capacities* such that the required power transfers described in 4.4.2 and 4.4.4 above are approximated by selection of individual units; and
- 4.4.6 the expected availability of generation reactive capability shall be set to that which ought reasonably to be expected to arise. This shall take into account the variation of reactive capability with the active power output (for example, as defined in the machine performance chart). In the

absence of better data the expected available capability shall not exceed 90% of the Grid Code specified capability, (unless modified by a direction of the *Authority*) or 90% of the contracted capability for the active power output level, whichever is relevant.

- 4.5 The minimum *transmission capacity* of the *MITS* shall be planned such that, for the background conditions described in paragraph 4.4, prior to any fault there shall not be:
- 4.5.1 equipment loadings exceeding the *pre-fault rating*;
 - 4.5.2 voltages outside the *pre-fault planning voltage limits* or *insufficient voltage performance margins*;
 - 4.5.3 *system instability*; or
 - 4.5.4 *unacceptable sub-synchronous oscillations*.
- 4.6 The minimum *transmission capacity* of the *MITS* shall also be planned such that for the conditions described in paragraph 4.4 and for the *secured event* of a *fault outage* of any of the following:
- 4.6.1 a single *transmission circuit*, a reactive compensator or other reactive power provider;
 - 4.6.2 a single *generation circuit*, a single *generating unit* (or several *generating units* sharing a common circuit breaker), a single *power park module*, or a single *DC converter*;
 - 4.6.3 a *double circuit overhead line* on the supergrid;
 - 4.6.4 a *double circuit overhead line* where any part of either circuit is in *NGET's* transmission system or *SHET'S* transmission system;
 - 4.6.5 a section of *busbar* or mesh corner; or
 - 4.6.6 provided both the *fault outage* and prior outage involve plant that is wholly in *NGET's* transmission area, any single *transmission circuit* with the prior outage of another *transmission circuit* containing either a transformer in series or a cable section located wholly or mainly outside a substation, or a *generating unit* (or several *generating units*, sharing a common circuit breaker, that cannot be separately isolated), reactive compensator or other reactive power provider,
- there shall not be any of the following:
- 4.6.7 *loss of supply capacity* (except as permitted by the demand connection criteria detailed in Section 3 and Section 8);
 - 4.6.8 *unacceptable overloading* of any *primary transmission equipment*;
 - 4.6.9 *unacceptable voltage conditions* or *insufficient voltage performance margins*;
 - 4.6.10 *system instability*; or
 - 4.6.11 *unacceptable sub-synchronous oscillations*.

Under conditions in the course of a year of operation

- 4.7 The *MITS* shall meet the criteria set out in paragraphs 4.8 to 4.10 under the following background conditions:
- 4.7.1 conditions on the *national electricity transmission system* shall be set to those which ought reasonably to be foreseen to arise in the course of a year of operation. Such conditions shall include forecast demand cycles, typical *power station* operating regimes and typical planned outage patterns; and
 - 4.7.2 the expected availability of generation reactive capability shall be set to that which ought reasonably to be expected to arise. This shall take into account the variation of reactive capability with the active power output (for example, as defined in the machine performance chart). In the absence of better data the expected available capability shall not exceed 90% of the Grid Code specified capability, (unless modified by a direction of the *Authority*) or 90% of the contracted capability for the active power output level, whichever is relevant.
- 4.8 The minimum *transmission capacity* of the *MITS* shall be planned such that, for the background conditions described in paragraph 4.7, prior to any fault there shall not be:
- 4.8.1 equipment loadings exceeding the *pre-fault rating*;
 - 4.8.2 voltages outside the *pre-fault planning voltage limits* or *insufficient voltage performance margins*;
 - 4.8.3 *system instability*; or
 - 4.8.4 *unacceptable sub-synchronous oscillations*.
- 4.9 The minimum *transmission capacity* of the *MITS* shall also be planned such that, for the background conditions described in paragraph 4.7, the operational security criteria set out in Section 5 can be met.
- 4.10 Where necessary to satisfy the criteria set out in paragraphs 4.8 and 4.9, investment should be made in *transmission capacity* except where operational measures suffice to meet the criteria in paragraphs 4.8 and 4.9 provided that maintenance access for each *transmission circuit* can be achieved and provided that such measures are economically justified. The operational measures to be considered include rearrangement of transmission outages and appropriate reselection of *generating units* from those expected to be available, for example through *balancing services*. Guidance on economic justification is given in Appendix G.

General Criteria

- 4.11 In addition to the requirements set out in paragraphs 4.4 to 4.10, the system shall also be planned such that:
- 4.11.1 *operational switching* or *infrequent operational switching* shall not cause *unacceptable voltage conditions*.
- 4.12 *Transmission circuits* comprising the *supergrid* part of the *MITS* shall not exceed the circuit complexity limit defined in paragraphs B.3 to B.7 of Appendix B.

- 4.13 Guidance on complexity of *transmission circuits* on the *MITS* operated at a nominal voltage of 132 kV is given in paragraphs B.8 to B.13 of Appendix B. Relaxation of the restrictions cited in paragraphs B.8 to B.13 may be justified in certain circumstances following appropriate liaison between the relevant *Licensees* responsible for the design of the circuits and their operation.

Switching Arrangements

- 4.14 Guidance on substation configurations and switching arrangements are described in Appendix A. These guidelines provide an acceptable way towards meeting the criteria of this section. However, other configurations and switching arrangements which meet the criteria are also acceptable.

5. Operation of the Onshore Transmission System

Normal Operational Criteria

- 5.1 The *onshore transmission system* shall be operated under *prevailing system conditions* so that for the *secured event* of a *fault outage* on the *onshore transmission system* of any of the following:
- 5.1.1 a single *transmission circuit*, a reactive compensator or other reactive power provider; or
 - 5.1.2 a single *generation circuit*, a single *generating unit* (or several *generating units* sharing a common circuit breaker), a single *power park module*, or a single *DC converter*; or
 - 5.1.3 the most onerous *loss of power infeed*; or
 - 5.1.4 the most onerous loss of power outfeed; or
 - 5.1.5 where the system is designed to be secure against a *fault outage* of a section of *busbar* or mesh corner under *planned outage* conditions, a section of *busbar* or mesh corner,
- there shall not be any of the following:
- 5.1.6 a *loss of supply capacity* except as specified in Table 5.1
 - 5.1.7 *unacceptable frequency conditions*;
 - 5.1.8 *unacceptable overloading* of any *primary transmission equipment*;
 - 5.1.9 *unacceptable voltage conditions*;
 - 5.1.10 *system instability*; or
 - 5.1.11 *unacceptable sub-synchronous oscillations*.
- 5.2 For a *secured event* on the *onshore transmission system* on connections to more than one *demand group* the permitted *loss of supply capacity* for that *secured event* is the maximum of the permitted loss of supply capacities set out in Table 5.1 for each of these *demand groups*.
- 5.3 The *onshore transmission system* shall be operated under *prevailing system conditions* so that for the *secured event* on the *onshore transmission system* of a *fault outage* of:
- 5.3.1 a *double circuit overhead line*; or
 - 5.3.2 a section of *busbar* or mesh corner,
- there shall not be any of the following:
- 5.3.3 a *loss of supply capacity* greater than 1500 MW;
 - 5.3.4 *unacceptable frequency conditions*;
 - 5.3.5 *unacceptable voltage conditions* affecting one or more *grid supply points* for which the total *group demand* is greater than 1500 MW;
 - 5.3.6 *system instability* of one or more *generating units* connected to the *supergrid*; or
 - 5.3.7 *unacceptable sub-synchronous oscillations*.

- 5.4 The *onshore transmission system* shall be operated under *prevailing system conditions* so that for the *secured event* on the *supergrid* of a *fault outage* of:
- 5.4.1 a *double circuit overhead line* where any part of either circuit is in *NGET's transmission system*; or
- 5.4.2 a section of *busbar* or mesh corner in *NGET's transmission system*, there shall not be:
- 5.4.3 *unacceptable overloading of primary transmission equipment* in *NGET's transmission system*; or
- 5.4.4 *unacceptable voltage conditions* in *NGET's transmission system*.

Table 5.1 Maximum permitted *loss of supply capacity* following *secured events*

Group Demand	Initial system conditions	
	<i>Prevailing system conditions with no local system outage</i> Note 1,2	<i>Prevailing system conditions with a local system outage</i> Note 1
over 1500 MW	None	None Note 3
over 300 MW to 1500 MW	None Note 4	None Note 3
over 60 MW to 300 MW	None except that where such facilities and suitable measures for restoration are available, up to 20 MW by automatic disconnection Note 5	Whole group up to <i>Group Demand</i> for up to the operational specified time to restore supply capacity
over 12 MW to 60 MW	None except that where such facilities and suitable measures for restoration are available, up to 12 MW by automatic disconnection for up to 15 minutes.	Whole group up to <i>Group Demand</i>
over 1 MW to 12 MW	Whole group up to <i>Group Demand</i> for up to the operational specified time to restore supply capacity	Whole group up to <i>Group Demand</i>
up to 1 MW	Whole group up to <i>Group Demand</i> for up to the operational specified time to restore supply capacity	Whole group up to <i>Group Demand</i>

Notes

- 1 The time to restore any lost supply capacity shall be as short as practicable. If any part of any lost supply capacity can be restored in less than the specified maximum time to restore all of it, it shall be restored.
- 2 Where the supply capacity was designed in such a way, there should be no *loss of supply capacity*.
- 3 Where the supply capacity to the *grid supply point* was designed in accordance with the demand connection criteria in Section 3 in such a way as to permit it, a *loss of supply capacity* equal to any amount by which the prevailing demand exceeds the *maintenance period demand* may be permitted up to a maximum of 1500 MW for no longer than the operational specified time to restore supply capacity.

- 4 Where the supply capacity to the *grid supply point* was designed in accordance with the demand connection criteria in Section 3 in such a way as to permit it, up to 60 MW may be lost for up to 60 seconds.
- 5 Where the supply capacity to the *grid supply point* was designed in accordance with the demand connection criteria in Section 3 in such a way as to permit it, up to the *group demand* may be lost for up to 60 seconds.

Conditional Further Operational Criteria

5.5 If:

- 5.5.1 there are *adverse conditions* such that the likelihood of a *double circuit overhead line* fault is significantly higher than normal; or
- 5.5.2 there is no significant economic justification for failing to secure the *onshore transmission system* to this criterion and the probability of *loss of supply capacity* is not increased by following this criterion,

the *onshore transmission system* shall be operated under *prevailing system conditions* so that for the *secured event* of:

- 5.5.3 a *fault outage* on the *supergrid* of a *double circuit overhead line*;

there shall not be:

- 5.5.4 where possible and there is no significant economic penalty, any *loss of supply capacity* greater than 300 MW;
- 5.5.5 *unacceptable overloading* of any *primary transmission equipment*;
- 5.5.6 *unacceptable voltage conditions*;
- 5.5.7 *system instability*; or
- 5.5.8 *unacceptable sub-synchronous oscillations*.

- 5.6 During periods of *major system risk*, the *ISOP* may implement measures to mitigate the consequences of this risk. Such measures may include: providing additional reserve; reducing system-to-generator intertrip risks, securing as far as possible appropriate two-circuit combinations, or reducing system transfers, for example through *balancing services*.
- 5.7 In the case that neither of the conditions in paragraphs 5.5.1 and 5.5.2 are met, it is acceptable to utilise short term post fault actions to avoid *unacceptable overloading of primary transmission equipment* which may include a requirement for demand reduction; however, this will not be used as a method of increasing reserve to cover abnormal post fault generation reduction. Where possible these post fault actions shall be notified to the appropriate *network operator* or *Generator*. Normally the provisions of the Grid Code, in respect of Emergency Manual Demand Disconnection and/or, for example through *balancing services*, will be applied. Additional post fault actions beyond the Grid Code provisions may be applied, but only where they have been agreed in advance with the appropriate *network operator* or *Generator*.
- 5.8 The *ISOP* shall use the latest version of the *Frequency Risk and Control Report* as consulted on and approved by the *Authority* to determine the events for which *unacceptable frequency conditions* shall not occur. *The Frequency Risk and Control*

Report assessment includes consideration of any consequential loss of distributed energy resources associated with any such event.

Post-fault Restoration of System Security

- 5.9 Following the occurrence of a *secured event* on the *onshore transmission system*, measures shall be taken to re-secure the system to the above operational criteria as soon as reasonably practicable. To this end, it is permissible to put operational measures in place pre-fault to facilitate the speedy restoration of system security.

Authorised Variations from the Operational Criteria

- 5.10 Provided it is in accordance with the appropriate requirements of the demand connection criteria in Section 3, there may be associated *loss of supply capacity* due to a *secured event*, for example by virtue of the design of the generation connections and/or the designed switching arrangements at the substations concerned.
- 5.11 Exceptions to the criteria in paragraphs 5.1 to 5.7 and 5.9 may be required:
- 5.11.1 where variations to the connection designs as per paragraphs 3.12 to 3.15 have been agreed; or
 - 5.11.2 in relation to 5.1.7 and 5.3.4 only, based on the outcome of an assessment conducted in accordance with the *Frequency Risk and Control Report*.
- 5.12 The principles of these operational criteria shall be applied at all times except in special circumstances where the *ISOP*, following consultation with the appropriate *network operator*, *Generator* or *non-embedded customer*, may need to give instructions to the contrary to preserve overall system integrity.

6. Voltage Limits in Planning and Operating the Onshore Transmission System

Voltage and Voltage Performance Margins in Planning Timescales

6.1. A voltage condition is unacceptable in planning timescales if:

6.1.1. there is any inability to achieve pre-fault steady-state voltages as specified in Table 6.1 at *onshore transmission system* substations or *GSPs*;

or

6.1.2. if, after either:

6.1.2.1. a *secured event*; or

6.1.2.2. *operational switching*,

and the affected site remains directly connected to the *onshore transmission system* in the *steady state* after the relevant event above, any of the following conditions applies:

6.1.2.3. the *voltage step change* at an interface between the *onshore transmission system* and a *user system* exceeds that specified in Table 6.5; or

6.1.2.4. there is any inability following such an event to achieve a *steady state* voltage as specified in Table 6.2 at *onshore transmission system* substations or *GSPs* using manual and/or automatic facilities available, including the switching in or out of relevant equipment;

or

6.1.3. if, pre-fault, or after either:

6.1.3.1. a *secured event*; or

6.1.3.2. *operational switching*.

there are *insufficient voltage performance margins*, as evidenced by:

i) *voltage collapse*;

ii) over-sensitivity of system voltage; or

iii) unavoidably exceeding the continuous reactive capability expected to be available from *generating units* or other reactive sources, so that accessible reactive reserves are exhausted;

under any of the following conditions:

i) *credible demand sensitivities*;

ii) the unavailability of any single reactive compensator or other reactive power provider; or

iii) the loss of any one automatic switching system or any automatic voltage control system for on-load tap changing.

6.2. The *steady state* voltages are to be achieved without widespread post-fault re-

despatch of *generating unit* reactive output or changes to set-points of SVCs or automatic reactive switching schemes and without exceeding the available reactive capability of generation or SVCs. In particular, following a *secured event*, the target voltages at *grid supply points* should be achieved after the operation of local reactive switching and auto-switching schemes, and after the operation of Grid Supply Transformer tap-changers.

- 6.3. The *pre-fault planning voltage limits* and targets on the *onshore transmission system* are as shown in Table 6.1.

Table 6.1: Pre-Fault Steady State Voltage Limits and Requirements in Planning Timescales

(a) Voltage Limits on Transmission Networks			
Nominal Voltage	PU Value (1pu relates to the Nominal Voltage)	Minimum (percentage of Nominal Voltage) Note 1	Maximum (percentage of Nominal Voltage)
Greater than 300kV	0.975pu-1.025pu	-2.5%	+2.5% Note 2
200 kV up to and including 300 kV	0.95pu-1.05pu	-5%	+5%
132 kV up to and including 200 kV	0.95pu-1.05pu	-5%	+5%
(b) Voltages to be Achievable at Interfaces to Distribution Networks and Non-Embedded Customers			
Any Nominal Voltage	1.05pu at forecast <i>Group Demand</i> 1.00pu at <i>forecast Minimum Demand</i> or as otherwise agreed with the relevant <i>network operator</i> or <i>non-embedded customer</i>		

Notes

1. It is permissible to relax these to the limits specified in Table 6.2 if:
 - (i) following a *secured event*, the voltage limits specified in Table 6.2 can be achieved, and
 - (ii) there is judged to be sufficient certainty of meeting Security and Quality of Supply Standards in operational timescales.
 2. It is permissible to relax this to 105% of the nominal voltage if there is judged to be sufficient certainty that the limit of 105% of the nominal voltage can be met in operational timescales.
- 6.4. The voltage limits in Table 6.2 are to be observed following any *secured event*.

Table 6.2 Steady State Voltage Limits and Requirements in Planning Timescales

(a) Voltage Limits on Transmission Networks			
Nominal Voltage	PU Value (1pu relates to the Nominal Voltage)	Minimum (percentage of Nominal Voltage)	Maximum (percentage of Nominal Voltage)
Greater than 300kV	0.95pu-1.025pu	-5% Note 3	+2.5% Note 4
200 kV up to and including 300kV	0.90pu-1.05pu	-10%	+5%
132 kV up to and including 200kV	0.90pu-1.05pu	-10%	+5%
(b) Voltage Limits at Interfaces to Distribution Networks and Non-Embedded Customers			
Any Nominal Voltage	See below for the minimum voltage that must be achievable. Must always exceed lower limits of Table 6.4(b)		+5%
(c) Voltages to be Achievable at Interfaces to Distribution Networks and Non-Embedded Customers			
Any Nominal Voltage	1.00pu at any demand level Note 5 or as otherwise agreed with the relevant <i>network operator</i> or <i>non-embedded customer</i> .		

Notes

3. It is permissible to relax this to 90% of the nominal voltage if the affected substations are on the same radially fed spur post-fault, and:
 - (i) there is no lower voltage interconnection from these substations to other *supergrid* substations; and
 - (ii) no auxiliaries of *large power stations* are derived from them.
 4. It is permissible to relax this to 105% of the nominal voltage if there is judged to be sufficient certainty of meeting Security and Quality of Supply Standards in operational timescales, and operational measures to achieve these are identified at the planning stage.
 5. May be relaxed downwards following a *secured event* involving the outage of a Grid Supply Transformer, provided that there is judged to be sufficient certainty that the limits of Table 6.4(b) can be met in operational timescales.
- 6.5. For a site or a group of sites with a combined *group demand* of less than 1500 MW, operational measures shall be identified at the planning stage to ensure that the requirements of Table 6.3 and 6.4 can be met in operational timescales for all sites remaining connected following any *secured event* for which it is not required to secure the full *group demand*.

Voltage Limits in Operational Timescales

6.6. A voltage condition is unacceptable in operational timescales if:

- 6.6.1. there is any inability to achieve pre-fault *steady-state* voltages as specified in Table 6.3 at *onshore transmission system* substations or *GSPs*; or
- 6.6.2. if, after either:
 - 6.6.2.1. a *secured event*; or
 - 6.6.2.2. *operational switching*,
 and the affected site remains directly connected to the *onshore transmission system* in the *steady state* after the relevant event above, either of the following conditions applies:
 - 6.6.2.3. the *voltage step change* at an interface between the *onshore transmission system* and a *user system* exceeds that specified in Table 6.5; or
 - 6.6.2.4. there is any inability following such an event to achieve a *steady state* voltage as specified in Table 6.4 at *onshore transmission system* substations or *GSPs* using manual and/or automatic facilities available, including the switching in or out of relevant equipment.

Table 6.3 Pre-Fault Steady State Voltage Limits and Targets in Operational Timescales

(a) Voltage Limits on Transmission Networks			
Nominal Voltage	PU Value (1pu relates to the Nominal Voltage)	Minimum (percentage of Nominal Voltage)	Maximum (percentage of Nominal Voltage)
Greater than 300 kV	0.95pu-1.05pu	-5% Note 6	+5%
200 kV up to 300 kV	0.95pu-1.09pu	-5% Note 6	+9%
132 kV up to and including 200 kV	0.95pu-1.10pu	-5% Note 6	+10%
(b) Voltages to be Achievable at Interfaces to Distribution Networks and Non-Embedded Customers			
Any Nominal Voltage	Target voltages and voltage ranges as agreed with the relevant <i>network operators</i> or <i>non-embedded customers</i> , within the limits of Table 6.4		

Notes

6. It is permissible to relax this to 90% at substations if no auxiliaries of *large power stations* are derived from them.

Table 6.4 Steady State Voltage Limits and Targets in Operational Timescales

(a) Voltage Limits on Transmission Networks			
Nominal Voltage	PU Value (1pu relates to the Nominal Voltage)	Minimum (percentage of Nominal Voltage)	Maximum (percentage of Nominal Voltage)
Greater than 300 kV	0.90pu-1.05pu	-10%	+5% Note 7
200 kV up to and including 300kV	0.90pu-1.09pu	-10%	+9%
132 kV up to and including 200 kV	0.90pu-1.10pu	-10%	+10%
(b) Voltage Limits at Interfaces to Distribution Networks and Non-Embedded Customers			
Nominal Voltage			
132 kV	0.90pu-1.10pu	-10%	+10%
At less than 132 kV	0.94pu-1.06pu	-6%	+6%

Notes

7. May be relaxed to 110% for no longer than 15 minutes following a *secured event*.

Voltage Step Change Limits in All Timescales

6.7. *Voltage step change* limits must be observed at every interface point between the *national electricity transmission system* and Users' plant. The *voltage step change* limits do not apply where no User is connected.

6.8. The *voltage step change* limits must be applied with load response taken into account.

Table 6.5 Voltage Step Change Limits in Planning and Operational Timescales

Type of Event	Voltage Fall	Voltage Rise
(a) At substations supplying User Systems at any voltage		
1. Following <i>operational switching</i> at intervals of less than 8 minutes	In accordance with Figure 6.1	
2. Following <i>operational switching</i> at intervals of more than 8 minutes, 3. except for <i>infrequent operational switching</i> events as described below	-3%	+3%
4. Following <i>infrequent operational switching</i> Notes 8, 9	-6%	+6%
5. In planning timescales, following a <i>fault outage of a double circuit supergrid</i> overhead line Note 10	-6%	+6%
6. Following any other <i>secured event</i> , Note 11 except as detailed below:	-6%	+6%
(b) At substations supplying User Systems at voltages above 132 kV		

7. Following a <i>secured event</i> involving a <i>fault outage</i> of a section of <i>busbar</i> or a mesh corner	-12%	+6%
8. In operational timescales, following a <i>secured event</i> involving a <i>fault outage</i> of a <i>double circuit overhead line</i>	-12%	+6%
(c) At substations supplying <i>User Systems</i> at 132 kV As (a) and (b) plus:		
9. Following a <i>secured event</i> involving loss of a double circuit transmission overhead line, and one or more <i>supergrid</i> transformers stepping down to 132 kV	-12%	+6%
10. Following a <i>secured event</i> involving loss of a single <i>transmission circuit</i> and one or more <i>supergrid</i> transformers stepping down to 132 kV, with a prior outage of another circuit connected to the substation or of another mesh corner at the substation	-12%	+6%
11. Following a <i>secured event</i> involving loss of a <i>double circuit</i> transmission overhead line operating at 132 kV Note 12	-12%	+6%
(d) At substations supplying <i>User Systems</i> at voltages below 132 kV As (a), (b) and (c) plus:		
12. Following a <i>secured event</i> involving the loss of one or more Grid Supply Transformers	-12%	+6%

Notes

8. An individual User must not experience voltage steps exceeding $\pm 3\%$ due to infrequent operational switching:

- (i) on a regular basis, and/or
- (ii) at intervals of less than two hours,
- (iii) unless abnormal conditions prevail

Infrequent operational switching would typically include disconnection of circuits for routine maintenance. It would not include switching out of circuits for voltage control, or switching out of circuits to allow safe access to other plant, where it is foreseen that such switching may be a regular practice; such events would be classed as *operational switching*.

9. Voltage steps exceeding $\pm 3\%$ due to *infrequent operational switching* may be accepted only on busbars or circuits fed directly by the *transmission circuits* involved in the *infrequent operational switching*.
10. It is permissible to relax this to -12%, +6% in Scotland if the aggregate demand of sites experiencing voltage falls between 6% and 12% and does not exceed 1500 MW.
11. Operationally, the -6% requirement may be relaxed to -12% at a site or sites with a combined *group demand* of less than 1500 MW, provided all other SQSS requirements are met, if the -6% requirement may only be met by shedding load.

12. In planning timescales, for *demand groups* with aggregate demand less than 1500 MW, this criterion applies to any demand left connected post-fault. Operationally, this criterion only applies for *demand groups* with aggregate demand greater than 1500 MW.




Figure 6.1 Maximum Voltage Step Changes Permitted for Operational Switching derived from EREC P28 B.1.2

7. Generation Connection Criteria Applicable to an Offshore Transmission System

- 7.1 This section presents the planning criteria applicable to the connection of one or more *offshore power stations* to an *offshore transmission system*. The criteria in this section apply from the *offshore grid entry point/s* at which each *offshore power station* connects to an *offshore transmission system*, through the remainder of the *offshore transmission system* to the point of connection at the *first onshore substation*, which is the *interface point* in the case of a direct connection to the *onshore transmission system* or the *user system interface point* in the case of a connection to an onshore *user system*.
- 7.2 Planning criteria are defined for all elements of an *offshore transmission system* including: the *offshore transmission circuits* and equipment on the *offshore platform* (whether AC or DC); the *offshore transmission circuits* from the *offshore platform* to the *interface point* or *user system interface point* (as the case may be) including undersea cables and any overhead lines (whether AC or DC); and any onshore AC voltage transformation facilities or *DC converter* facilities.
- 7.3 In those parts of the *national electricity transmission system* where the criteria of Section 8 and/or Section 4 also apply, those criteria must also be met.
- 7.4 In planning *offshore* generation connections, this Standard is met if the connection design either:
- 7.4.1 satisfies the deterministic criteria detailed in paragraphs 7.6 to 7.18; or
 - 7.4.2 varies from the design necessary to meet paragraph 7.4.1 above in a manner which satisfies the conditions detailed in paragraphs 7.20 to 7.23.
- 7.5 It is permissible to design to standards higher than those set out in paragraphs 7.6 to 7.18 provided the higher standards can be economically justified. Guidance on economic justification is given in Appendix G.

Limits to Loss of Power Infeed Risks

- 7.6 For the purpose of applying the criteria of paragraphs 7.7 to 7.12, the *loss of power infeed* resulting from a *secured event* shall be calculated as follows:
- 7.6.1 the sum of the *registered capacities* of the *offshore power park modules* or *offshore* gas turbines disconnected from the system by a *secured event*, less;
 - 7.6.2 the *forecast minimum demand* disconnected from the system by the same event but excluding (from the deduction) any demand forming part of the *forecast minimum demand* which may be automatically tripped for system frequency control purposes and excluding (from the deduction) the demand of the largest single end customer.

Offshore Platforms (AC and DC)

- 7.7 *Offshore* generation connections on *offshore platforms* shall be planned such that, starting with an *intact system*, the consequences of *secured events* on the *offshore transmission system* shall be as follows;

7.7.1 AC Circuits on an offshore platform

- 7.7.1.1 in the case of *offshore power park module* only connections, and where the *offshore grid entry point capacity* is 90 MW or more, following a *planned outage* or a *fault outage* of a single AC *offshore* transformer circuit on the *offshore platform*, the *loss of power infeed* shall not exceed the smaller of either:
 - 50% of the *offshore grid entry point capacity*; or
 - the full *normal infeed loss risk*.
- 7.7.1.2 in the case of gas turbine only connections, and where the *offshore grid entry point capacity* is 90 MW or more, following a *planned outage* or a *fault outage* of a single AC *offshore transmission circuit* on the *offshore platform*, there shall be no *loss of power infeed*;
- 7.7.1.3 following a *fault outage* of a single AC *offshore transmission circuit* on the *offshore platform*, during a *planned outage* of another AC *offshore transmission circuit* on the *offshore platform*, the further *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.

7.7.2 DC Circuits on an offshore platform

- 7.7.2.1 following a *planned outage* or a *fault outage* of a single *DC converter* on the *offshore platform*, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.7.2.2 following a *fault outage* of a single *DC converter* on the *offshore platform*, during a *planned outage* of another *DC converter* on the *offshore platform*, the further *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.

7.7.3 Busbars and Switchgear on an offshore platform

- 7.7.3.1 following a *planned outage* of any single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *normal infeed loss risk*;
- 7.7.3.2 following a *fault outage* of any single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.7.3.3 following a *fault outage* of any single *busbar* coupler circuit breaker or *busbar* section circuit breaker or mesh circuit breaker, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.7.3.4 following a *fault outage* of any single section of *busbar* or mesh corner, during a *planned outage* of any other single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.7.3.5 following a *fault outage* of any single *busbar* coupler circuit breaker or *busbar* section circuit breaker or mesh circuit

breaker, during a *planned outage* of any single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.

Cable Circuits (AC and DC)

7.8 The transmission connections between one *offshore platform* and another *offshore platform* or from an *offshore platform* to the *interface point* or *user system interface point* at the *first onshore substation* shall be planned such that, starting with an *intact system* and for the full *offshore grid entry point capacity* at the *offshore grid entry point*, the consequences of *secured events* shall be as follows:

- 7.8.1 following a *planned outage* or a *fault outage* of a single cable *offshore transmission circuit*, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*; and
- 7.8.2 following a *fault outage* of a single *cable offshore transmission circuit* during a *planned outage* of another cable *offshore transmission circuit* the further *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.

Overhead Line Sections (AC and DC)

7.9 In the case AC overhead line connections of 132 kV, between the incoming AC cable *offshore transmission circuits* and the *first onshore substation* or the onshore AC transformation facilities (as the case may be), the justification for a minimum of one circuit or two circuits is illustrated in Figure 7.1. In Figure 7.1 the justification is presented as a function of route length and *offshore grid entry point capacity*. The area above the line represents justification for a minimum of two circuits and the area below the line represents justification for a minimum of one circuit.




Figure 7.1 Justification for a Minimum of One Circuit or a Minimum of Two Circuits for 132 kV AC Overhead Lines

- 7.10 In the case of AC overhead line connections of 220 kV or above, between the incoming AC cable *offshore transmission circuits* and the *first onshore substation* or the onshore AC transformation facilities (as the case may be), a single circuit is justified as a minimum for *offshore grid entry point capacities* of 1250 MW or less and two circuits are justified as a minimum for *offshore grid entry point capacities* greater than 1250 MW.
- 7.11 Overhead line (AC or DC) connections between the cable (AC or DC) *offshore transmission circuits* and the *first onshore substation* or the onshore AC transformation facilities or DC conversion facilities, as the case may be, shall be planned such that, starting with an *intact system* and for the full *offshore grid entry point capacity* at the *offshore grid entry point*, the consequences of a *secured event* on the *offshore transmission system* shall be as follows:
- 7.11.1 following a *planned outage* or a *fault outage* of a single overhead line circuit, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
 - 7.11.2 following a *fault outage* of a single overhead line circuit during a *planned outage* of another overhead line circuit, the further *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.

Onshore Connection Facilities (AC and DC)

- 7.12 The transmission connections at the onshore AC transformation or DC conversion facilities shall be planned such that, starting with an *intact system*, the consequences of *secured events* on the *offshore transmission system* shall be as follows;
- 7.12.1 AC Circuits
- 7.12.1.1 in the case of *offshore power park module* only connections, and where the *offshore grid entry point capacity* is 120 MW or more, following a *planned outage* or a *fault outage* of a single AC *offshore* transformer circuit at the onshore AC transformation facilities, *the loss of power infeed* shall not exceed the smaller of either:
 - 50% of the *offshore grid entry point capacity*; or
 - the full *normal infeed loss risk*.
 - 7.12.1.2 in the case of gas turbine only connections, following a *planned outage* or a *fault outage* of a single AC *offshore transmission circuit* at the onshore AC transformation facilities, the *loss of power infeed* shall not exceed the *normal infeed loss risk*;
 - 7.12.1.3 following a *fault outage* of a single AC *offshore transmission circuit* at the onshore AC transformation facilities, during a *planned outage* of another AC *offshore transmission circuit* at the onshore AC transformation facilities, the further *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.

7.12.2 DC Circuits

- 7.12.2.1 following a *planned outage* or a *fault outage* of a single *DC converter* at the onshore DC conversion facilities, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.12.2.2 following a *fault outage* of a single *DC converter* at the onshore DC conversion facilities, during a *planned outage* of another *DC converter* at the onshore DC conversion facilities, the further *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.

7.12.3 Busbars and Switchgear

- 7.12.3.1 in the case of *offshore power park module* connections or multiple gas turbine connections, following a *planned outage* of any single section of *busbar* or mesh corner, *no loss of power infeed* shall occur;
- 7.12.3.2 in the case of a single gas turbine connection, following a *planned outage* of any single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.12.3.3 following a *fault outage* of any single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.12.3.4 following a *fault outage* of any single *busbar* coupler circuit breaker or *busbar* section circuit breaker or mesh circuit breaker, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.12.3.5 following a *fault outage* of any single section of *busbar* or mesh corner, during a *planned outage* of any other single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*;
- 7.12.3.6 following a *fault outage* of any single *busbar* coupler circuit breaker or *busbar* section circuit breaker or mesh circuit breaker, during a *planned outage* of any single section of *busbar* or mesh corner, the *loss of power infeed* shall not exceed the *infrequent infeed loss risk*.

Generation Connection Capacity Requirements

Background conditions

- 7.13 The connection of a particular *offshore power station* shall meet the criteria set out in paragraphs 7.14 to 7.23 under the following background conditions:
 - 7.13.1 the active power output of the *offshore power station* shall be set to deliver active power at the *offshore grid entry point* equal to its *registered capacity* or, for the purpose of *sub-synchronous oscillations* studies, that which provides the lowest level of damping for the sub-synchronous mode under consideration;

- 7.13.2 the reactive power output of the *offshore power station* shall normally, and unless otherwise agreed, be set to deliver zero reactive power at the *offshore grid entry point* with active power output equal to *registered capacity*; and the reactive power delivered at the *interface point* shall be set in accordance with the reactive requirements placed on the *offshore Licensee* set out in Section K of the STC (System Operator – Transmission Owner Code); and
- 7.13.3 conditions on the *national electricity transmission system* shall be set to those which ought reasonably to be expected to arise in the course of a year of operation. Such conditions shall include forecast demand cycles, typical *power station* operating regimes and typical *planned outage* patterns modified where appropriate by the provisions of paragraph 7.16.

Pre-Fault Criteria – background conditions of no *local system outage*

- 7.14 The *transmission capacity* of the *offshore transmission circuits* for the connection of one or more *offshore power stations* shall be planned such that, for the background conditions described in paragraph 7.13, with *no local system outage* and prior to any fault, there shall not be any of the following:
 - 7.14.1 equipment loadings exceeding the *pre-fault rating*;
 - 7.14.2 voltages outside the *pre-fault planning voltage limits* or *insufficient voltage performance margins*;
 - 7.14.3 *system instability*; or
 - 7.14.4 *unacceptable sub-synchronous oscillations*.

Post-Fault Criteria – background conditions of no *local system outage*

- 7.15 The *transmission capacity* of the *offshore transmission circuits* for the connection of one or more *offshore power stations* shall also be planned such that for the background conditions described in paragraph 7.13 with *no local system outage* and for the *secured event* on the *offshore transmission system* of any of the following:
 - 7.15.1 in the case of an *offshore power park module* connection with an *OffGEP capacity* of 90 MW or more, with the *OffGEP capacity* reduced by 50%, a *fault outage* or *planned outage* of a single AC *offshore transmission circuit* on the *offshore platform*;
 - 7.15.2 in the case of an *offshore power park module* connection with an *OffGEP capacity* of 120 MW or more, with the *OffGEP capacity* reduced to 50%, a *fault outage* or a *planned outage* of a single AC *offshore transmission circuit* at the onshore transformation facilities,

And in all cases other than specified in 7.15.1 and 7.15.2 above:

- 7.15.3 a *fault outage* or a *planned outage* of a single *offshore transmission circuit*;

And in all cases:

- 7.15.4 a *fault outage* or a *planned outage* of a *generation circuit*, a *generating unit* (or several *generating units* sharing a common circuit breaker), a *power park module*, a *DC converter*, single reactive compensator or other reactive provider;
- 7.15.5 a *fault outage* of a single *offshore transmission circuit* during a *planned outage* of another *offshore transmission circuit*; *generation circuit*, a *generating unit* (or several *generating units* sharing a common circuit breaker), a *power park module*, a *DC converter*, a reactive compensator or other reactive power provider;
- 7.15.6 a *fault outage* or a *planned outage* of a single section of *busbar* or mesh corner;

There shall not be any of the following:

- 7.15.7 a *loss of supply capacity* except as permitted by the demand connection criteria detailed in Section 8;
 - 7.15.8 *unacceptable overloading* of any *primary transmission equipment*;
 - 7.15.9 *unacceptable voltage conditions* or *insufficient voltage performance margins*;
 - 7.15.10 *system instability*; or
 - 7.15.11 *unacceptable sub-synchronous oscillations*.
- 7.16 Under planned outage conditions it shall be assumed that the planned outage specified in paragraphs 7.15.5 reasonably forms part of the typical outage pattern referred to in paragraph 7.13.3 rather than in addition to the typical outage pattern.

Post-fault criteria – background conditions with a *local system outage*

- 7.17 The *transmission capacity* of the *offshore transmission circuits* for the connection of one or more *offshore power stations* to an *offshore transmission system* shall also be planned such that, for the background conditions described in paragraph 7.13 with a *local system outage*, the operational security criteria set out in Section 9 can be met.
- 7.18 Where necessary to satisfy the criteria set out in paragraph 7.17, investment should be made in *transmission capacity* except where operational measures suffice to meet the criteria in paragraph 7.17 provided that maintenance access for each *offshore transmission circuit* can be achieved and provided that such measures are economically justified. The operational measures to be considered include rearrangement of transmission outages and appropriate reselection of *generating units* from those expected to be available, for example through *balancing services*. Guidance on economic justification is given in Appendix G.

Switching Arrangements

- 7.19 Guidance on *offshore* substation configurations and switching arrangements are described in Appendix A. These guidelines provide an acceptable way towards meeting the criteria of paragraphs 7.7 to 7.12. However, other configurations and switching arrangements which meet those criteria are also acceptable.

Variations to Connection Designs

- 7.20 Variations, arising from a generation customer's request, to the generation connection design necessary to meet the requirements of paragraphs 7.6 to 7.18 shall also satisfy the requirements of this Standard provided that the varied design satisfies the conditions set out in paragraphs 7.21.1 to 7.21.3. For example, such a generation connection design variation may be used to take account of the particular characteristics of an *offshore power station*.
- 7.21 Any generation connection design variation must not, other than in respect of the generation customer requesting the variation, either immediately or in the foreseeable future:
- 7.21.1 reduce the security of the *MITS* to below the minimum planning criteria specified in Section 4; or
 - 7.21.2 result in additional investment or operational costs to any particular customer or overall, or a reduction in the security and quality of supply of the affected customers' connections to below the planning criteria in this section or Section 8, unless specific agreements are reached with affected customers; or
 - 7.21.3 compromise any *Licensee's* ability to meet other statutory obligations or licence obligations.
- 7.22 system conditions subsequently change, for example due to the proposed connection of a new customer, such that either immediately or in the foreseeable future, the conditions set out in paragraphs 7.21.1 to 7.21.3 are no longer satisfied, then alternative arrangements and/or agreements must be put in place such that this Standard continues to be satisfied.
- 7.23 The additional operational costs referred to in paragraph 7.21.2 and/or any potential reliability implications shall be calculated by simulating the expected operation of the *national electricity transmission system* in accordance with the operational criteria set out in Section 5 and Section 9. Guidance on economic justification is given in Appendix G.

8. Demand Connection Criteria Applicable to an Offshore Transmission System

- 8.1 This section presents the planning criteria applicable to the connection of *offshore power station demand groups* to the remainder of the *national electricity transmission system*.
- 8.2 In those parts of an *offshore transmission system* where the criteria of Section 7 also apply, those criteria must also be met.
- 8.3 In planning demand connections, this Standard is met if the connection design either:
 - 8.3.1 satisfies the deterministic criteria detailed in paragraphs 8.5 to 8.10; or
 - 8.3.2 varies from the design necessary to meet paragraph 8.3.1 above in a manner which satisfies the conditions detailed in paragraphs 8.12 to 8.15.
- 8.4 It is permissible to design to standards higher than those set out in paragraphs 8.5 to 8.10 provided the higher standards can be economically justified. Guidance on economic justification is given in Appendix G.

Offshore Power Station Demand Connection Capacity Requirements

- 8.5 The connection of a particular *offshore power station demand group* shall meet the criteria set out in paragraphs 8.6 to 8.10 under the following background conditions:
 - 8.5.1 when the power output of the *offshore power station* is set to zero and there are no *planned outages*, the demand of the *offshore power station demand group* shall be set equal to *group demand*; and
 - 8.5.2 demand and generation outside the *offshore power station demand group* shall be set in accordance with the *planned transfer conditions* using the appropriate method described in Appendix C.
- 8.6 The *transmission capacity* for the connection of an *offshore power station demand group* shall be planned such that, for the background conditions described in paragraph 8.5, under *intact system* conditions there shall not be any of the following:
 - 8.6.1 equipment loadings exceeding the *pre-fault rating*;
 - 8.6.2 voltages outside the *pre-fault planning voltage limits* or *insufficient voltage performance margins*; or
 - 8.6.3 *system instability*.
- 8.7 The *transmission capacity* for the connection of an *offshore power station demand group* shall also be planned such that for the background conditions described in paragraph 8.5 and for the *planned outage* of a single *transmission circuit* or a single section of *busbar* or mesh corner, there shall not be any of the following:
 - 8.7.1 a *loss of supply capacity* for a *group demand* of greater than 1 MW;
 - 8.7.2 *unacceptable overloading* of any *primary transmission equipment*;
 - 8.7.3 voltages outside the *pre-fault planning voltage limits* or *insufficient voltage performance margins*; or

8.7.4 *system instability.*

8.8 The *transmission capacity* for the connection of an *offshore power station demand group* shall also be planned such that for the background conditions described in paragraph 8.5 and the initial conditions of

8.8.1 an *intact system* condition; or

8.8.2 the single *planned outage* of another *transmission circuit* or a *generating unit* (or several *generating units*, sharing a common circuit breaker, that cannot be separately isolated), a *power park module*, or a *DC converter*, a reactive compensator or other reactive power provider,

for the *secured event* of a *fault outage* of

8.8.3 a single *transmission circuit*, or

8.8.4 a single generating unit (or several *generating units* sharing a common circuit breaker), a single *power park module*, or a single *DC converter*

there shall not be any of the following:

8.8.5 a *loss of supply capacity* such that the provisions set out in Table 8.1 are not met;

8.8.6 *unacceptable overloading* of any *primary transmission equipment*;

8.8.7 *unacceptable voltage conditions* or *insufficient voltage performance margins*; or

8.8.8 *system instability.*

8.9 In addition to the requirements of paragraphs 8.6 to 8.8, for the background conditions described in paragraph 8.5, the system shall also be planned such that operational switching does not cause *unacceptable voltage conditions*.

8.10 For a *secured event* on connections to more than one *offshore power station demand group*, the permitted *loss of supply capacity* for that *secured event* is the maximum of the permitted *loss of supply capacities* set out in Table 8.1 for each of these *offshore power station demand groups*.

Table 8.1 Minimum planning supply capacity following *secured events*

<i>Group Demand</i>	Initial system conditions	
	<i>Intact system</i>	With single <i>planned outage</i> Note 1
over 1 MW to 12 MW	Within 3 hours <i>Group Demand</i> minus 1 MW In repair time <i>Group Demand</i>	Nil
up to 1 MW	In repair time <i>Group Demand</i>	Nil

Notes

- The planned outage may be of a *transmission circuit*, *generating unit*, reactive compensator or other reactive power provider.

Switching Arrangements

8.11 Guidance on substation configurations and switching arrangements are described in Appendix A. These guidelines provide an acceptable way towards meeting the

criteria of this chapter. However, other configurations and switching arrangements which meet the criteria are also acceptable.

Variations to Connection Designs

- 8.12 Variations, arising from a *generator's* request, to the demand connection design necessary to meet the requirements of paragraphs 8.5 to 8.10 shall also satisfy the requirements of this Standard provided that the varied design satisfies the conditions set out in paragraphs 8.13.1 to 8.13.3. For example, such a demand connection design variation may be used to limit overall costs.
- 8.13 Any demand connection design variation must not, other than in respect of the *generator* requesting the variation, either immediately or in the foreseeable future:
- 8.13.1 reduce the security of the *MITS* to below the minimum planning criteria specified in Section 4; or
 - 8.13.2 result in additional investment or operational costs to any particular customer or overall, or a reduction in the security and quality of supply of the affected customers' connections to below the planning criteria in this section or Section 7, unless specific agreements are reached with affected customers; or
 - 8.13.3 compromise any *Licensee's* ability to meet other statutory obligations or licence obligations.
- 8.14 Should system conditions change, for example due to the proposed connection of a new customer, such that either immediately or in the foreseeable future, the conditions set out in paragraphs 8.13.1 to 8.13.3 are no longer satisfied, then alternative arrangements and/or agreements must be put in place such that this Standard continues to be satisfied.
- 8.15 The additional operational costs referred to in paragraph 8.13.2 and/or any potential reliability implications shall be calculated by simulating the expected operation of the *national electricity transmission system* in accordance with the operational criteria set out in Section 5 and Section 9. Guidance on economic justification is given in Appendix G.

9. Operation of an Offshore Transmission System

Normal Operational Criteria

- 9.1 An *offshore transmission system* shall be operated under *prevailing system conditions* so that for the *secured event* on the *offshore transmission system* of a *fault outage* of any of the following:
- 9.1.1 a single *transmission circuit*, a reactive compensator or other reactive power provider; or
 - 9.1.2 a single generation circuit, a *single generating unit* (or several *generating units* sharing a common circuit breaker), a single *power park module*, or a *single DC converter*, or
 - 9.1.3 the most onerous *loss of power infeed*; or
 - 9.1.4 the most onerous loss of power outfeed; or
 - 9.1.5 a section of *busbar* or mesh corner; or
 - 9.1.6 a *double circuit overhead line*,
- there shall not be any of the following:
- 9.1.7 a *loss of supply capacity* except as specified in Table 9.1;
 - 9.1.8 *unacceptable frequency conditions*;
 - 9.1.9 *unacceptable overloading* of any *primary transmission equipment*;
 - 9.1.10 *unacceptable voltage conditions*;
 - 9.1.11 *system instability*; or
 - 9.1.12 *unacceptable sub-synchronous oscillations*.

Table 9.1 Maximum permitted *loss of supply capacity* following *secured events*

Group Demand	Initial system conditions	
	<i>Prevailing system conditions with no local system outage</i>	<i>Prevailing system conditions with a local system outage</i>
over 1 MW to 12 MW	Whole group up to <i>Group Demand</i> for up to the operational specified time to restore supply capacity	Whole group up to <i>Group Demand</i>
up to 1 MW	Whole group up to <i>Group Demand</i> for up to the operational specified time to restore supply capacity	Whole group up to <i>Group Demand</i>

Notes

1. The time to restore any lost supply capacity shall be as short as practicable. If any part of any lost supply capacity can be restored in less than the specified maximum time to restore all of it, it shall be restored.

Conditional Further Operational Criteria

- 9.2 The *ISOP* shall use the latest version of the *Frequency Risk and Control Report* as consulted on and approved by the *Authority* to determine the events for which *unacceptable frequency conditions* shall not occur. The *Frequency Risk and Control Report* assessment includes consideration of any consequential loss of distributed energy resources associated with any such event.

Post-fault Restoration of System Security

- 9.3 Following the occurrence of a *secured event*, measures shall be taken to re-secure an *offshore transmission system* to the above operational criteria as soon as reasonably practicable. To this end, it is permissible to put operational measures in place pre-fault to facilitate the speedy restoration of system security.

Authorised Variations from the Operational Criteria

- 9.4 Exceptions to the criteria in paragraphs 9.1 and 9.3 may be required:
- 9.4.1 where variations to the connection designs as per paragraphs 7.21 to 7.24 and paragraphs 8.12 to 8.15 have been agreed; or
 - 9.4.2 in relation to 9.1.8 only, based on the outcome of an assessment conducted in accordance with the *Frequency Risk and Control Report*.
- 9.5 The principles of these operational criteria shall be applied at all times except in special circumstances where *ISOP*, following consultation with the appropriate *Generator*, may need to give instructions to the contrary to preserve overall system integrity.

10. Voltage Limits in Planning and Operating an Offshore Transmission System

Voltage Limits

10.1 The pre-fault planning voltage limits and steady state voltage limits on an *offshore transmission system* are as shown in Table 10.1.

Table 10.1 *Pre-fault planning voltage limits and steady state voltage limits in both planning and operational timescales*

Nominal voltage	Minimum	Maximum
400 kV Note 1	- 10%	+ 5%
Less than 400 kV down to 132 kV inclusive	- 10%	+ 10%
Less than 132 kV	- 6%	+ 6%

Notes

1. For 400 kV, the maximum limit is aligned with the equivalent onshore limit pending review in the light of technological developments.
- 10.2 A voltage condition on an *offshore transmission system* is unacceptable in both planning and operational timescales if, after either:
- 10.2.1 a *secured event*, or
 - 10.2.2 *operational switching*,
- and the affected site remains directly connected to the *national electricity transmission system* in the *steady state* after the relevant event above, the following condition applies:
- 10.2.3 there is any inability following such an event to achieve a *steady state* voltage as specified in Table 10.1 at *offshore transmission system* substations or *OSPs* using manual and/or automatic facilities available, including the switching in or out of relevant equipment.
- 10.3 In planning timescales, the *steady state* voltages are to be achieved without widespread post-fault generation transformer re-tapping or post-fault adjustment of SVC set points to increase the reactive power output or to avoid exceeding the available reactive capability of generation or SVCs.

11. Terms and Definitions

ACS Peak Demand	The estimated unrestricted winter peak demand (MW and MVar) on the total system for the <i>average cold spell</i> (ACS) condition. This represents the demand to be met by <i>large power stations</i> (directly connected or embedded), <i>medium power stations</i> (directly connected or embedded) and <i>small power stations</i> (directly connected or embedded) and by electricity imported into the <i>onshore transmission system</i> from <i>external systems</i> across <i>external interconnections</i> (and which is not adjusted to take into account demand management or other techniques that could modify demand).
Adverse Conditions	For the purpose of this Standard, those conditions that significantly increase the likelihood of an overhead line fault, e.g. high winds, lightning, very high or very low ambient temperatures, high precipitation levels, high insulator or atmospheric pollution, flooding.
Ancillary Services	This means: (a) such services as any authorised electricity operator may be required to have available as <i>ancillary services</i> pursuant to the Grid Code; and (b) such services as any authorised electricity operator or person making transfers on <i>external interconnections</i> may have agreed to have available as being <i>ancillary services</i> pursuant to agreement made with the <i>ISOP</i> and which may be offered for purchase by the <i>ISOP</i> .
Annual Load Factor	The ratio of the actual energy output of a <i>generating unit</i> , CCGT module or <i>power station</i> (as the case may be) to the maximum possible energy output of that <i>generating unit</i> , CCGT module or <i>power station</i> (as the case may be) over a year. It is often expressed in percentage terms.
Assimilated Law	Has the same meaning as that given by section 6(7) of the European Union (Withdrawal) Act 2018.
Authority	This means the Gas and Electricity Markets Authority established by section 1(1) of the Utilities Act 2000.
Authority Guidance on Code Modification Prioritisation	means the guidance published by the Authority from time to time on code modification prioritisation.
Average Cold Spell (ACS)	A particular combination of weather elements which give rise to a level of peak demand within a financial year (1 April to 31 March) which has a 50% chance of being exceeded as a result of weather variation alone.
Balancing Mechanism	This is the mechanism for the making and acceptance of offers and bids pursuant to the arrangements contained in the Balancing and Settlement Code (BSC)
Balancing Services	This means: a) <i>Ancillary services</i> ; b) Offers and bids in the <i>Balancing Mechanism</i> ; and c) Other services available to the <i>ISOP</i> , which serve to assist the <i>ISOP</i> in operating the <i>national electricity transmission system</i> in accordance with the Electricity Act 1989 (Act) and the Conditions of the <i>ESO licence</i> or in doing so efficiently and economically.
Boundary Allowance	An allowance in MW to be added in whole or in part to transfers arising out of the <i>economy planned transfer condition</i> to take some account of year round variations in levels of generation and demand. This allowance is calculated by an empirical method described in Appendix F of this Standard.

Busbar	The common connection point of two or more <i>transmission circuits</i> .
Business Day	Any weekday (other than a Saturday) on which banks are open for domestic business in the City of London.
Chairperson	The <i>Chairperson</i> of the <i>Panel</i> appointed in accordance with paragraph J.15-17.
Competitively Appointed Transmission Owner (CATO)	A person who is a holder of a <i>transmission licence</i> (as defined in Section 6(1)(b) of the Electricity Act 1989) to own and operate an <i>onshore transmission system</i> that has been granted on the basis of competitive tendering undertaken pursuant to Section 6C of the Electricity Act 1989.
Core Industry Documents	Shall have the same definition as in Standard Condition A1 of the <i>transmission licence</i> and licence condition A1.4 of the <i>ESO licence</i> .
Corrective Action	Manual and automatic action taken after an outage or switching action to assist recovery of satisfactory system conditions; for example, tap changing or switching of plant.
Credible Demand Sensitivities	Such variations in demands above those forecast as are appropriate to the locations and the forecast error for the number of years ahead for which the forecast has been produced, e.g. that which corresponds to an 80% demand forecast confidence level.
DC Converter	Any apparatus used as part of the <i>national electricity transmission system</i> to convert alternating current electricity to direct current electricity, or vice-versa. A <i>DC converter</i> is a standalone operative configuration at a single site comprising one or more converter bridges, together with one or more converter transformers, converter control equipment, essential protective and switching devices and auxiliaries, if any, used for conversion. In a bipolar arrangement, a <i>DC converter</i> represents the bipolar configuration.
Demand Group	A site or group of sites which collectively take power from the remainder of the <i>onshore transmission system</i> .
Demand Point of Connection	For the purpose of defining the boundaries between the <i>MITS</i> and <i>grid supply point</i> transformer circuits, the <i>demand point of connection</i> is taken to be the <i>busbar</i> clamp in the case of an air insulated substation, gas zone separator in the case of a gas insulated substation, or other equivalent point as may be determined by the relevant <i>Licensees</i> for new types of substation
Distribution Licensee	Means the holder of a distribution licence in respect of an onshore distribution system granted under Section 6 (1) (c) of the Electricity Act 1989 (as amended under the Utilities Act 2000 and the Energy Act 2004).
Double Circuit Overhead Line	In the case of the <i>onshore transmission system</i>, this is a transmission line which consists of two circuits sharing the same towers for at least one span in <i>SHET's transmission system</i> or <i>NGET's transmission system</i> or for at least 2 miles in <i>SPT's transmission system</i>. In the case of an <i>offshore transmission system</i>, this is a transmission line which consists of two circuits sharing the same towers for at least one span.
Economy Planned Transfer Conditions	The condition arising from scaling the <i>registered capacity</i> of each <i>power station</i> according to the type of generation such that the total of the scaled capacities is equal to the <i>ACS peak demand</i> . This scaling shall follow the techniques described in Appendix E.

Electricity System Operator (ESO) Licence	A licence granted or treated as granted under section 6(1)(da) of the Electricity Act 1989.
External Interconnection	Apparatus for the transmission of electricity to or from the <i>onshore transmission system</i> into or out of an <i>external system</i> .
External System	A transmission or distribution system located outside the <i>national electricity transmission system operator area</i> , which is electrically connected to the <i>onshore transmission system</i> by an <i>external interconnection</i>
Fault Outage	An outage of one or more items of <i>primary transmission equipment</i> and/or user equipment, which may or may not result in a loss of power infeed or loss of power outfeed, initiated by automatic action unplanned at that time, and which may or may not involve the passage of fault current.
First Onshore Substation	The <i>first onshore substation</i> defines the onshore limit of an <i>offshore transmission system</i>. An <i>offshore transmission system</i> cannot extend beyond the <i>first onshore substation</i>. Accordingly, the security criteria relating to an <i>offshore transmission system</i> extend from the <i>offshore GEP</i> up to the <i>interface point</i> or <i>user system interface point</i> (as the case may be), which is located at the <i>first onshore substation</i>. The security criteria relating to the <i>onshore transmission system</i> extend from the <i>interface point</i> located at the <i>first onshore substation</i> and extend across the remainder of the <i>onshore transmission system</i>. The security criteria relating to an onshore <i>user system</i> extend from the <i>user system interface point</i> located at the <i>first onshore substation</i> and extend across the remainder of the relevant <i>user system</i>. The <i>first onshore substation</i> will comprise, inter alia, facilities for the connection between, or isolation of, <i>transmission circuits</i> and/or distribution circuits. These facilities will include at least one <i>busbar</i> to which the <i>offshore transmission system</i> connects and one or more circuit breakers and disconnectors. For the avoidance of doubt, if the substation does not include these elements, then it does not constitute the <i>first onshore substation</i>. The <i>first onshore substation</i> may be owned by the <i>offshore transmission owner</i>, the onshore transmission owner or onshore <i>user system</i> owner as determined by the relevant <i>Licensee</i> and/or <i>distribution licensee</i> as the case may be. Normally, in the case of there being transformation facilities at the <i>first onshore substation</i> and unless otherwise agreed, if the <i>offshore transmission owner</i> owns the <i>first onshore substation</i>, the <i>interface point</i> would be on the HV <i>busbars</i> and, if the <i>first onshore substation</i> is owned by the onshore transmission owner or onshore <i>user system</i> owner, the <i>interface point</i> or <i>user system interface point</i> (as the case may be) would be on the LV <i>busbars</i>.
Forecast Minimum Demand	This is the minimum demand level expected at a <i>GSP</i> or <i>OSP</i> or a group of <i>GSPs</i> or group of <i>OSPs</i> . Unless more specific data are available, this is the expected demand at the time of the annual minimum demand on the <i>national electricity transmission system</i> as provided under the Grid Code. In the case of a group of <i>GSPs</i>

	or group of <i>OSPs</i> , the demand diversity within the group should be taken into account.
Frequency Risk and Control Report	The periodic report setting out the results of an assessment of the operational frequency risks on the system produced by the <i>ISOP</i> and approved by the <i>Authority</i> and as set out in the SQSS Appendix H, and prepared in accordance with the <i>Frequency Risk and Control Report Methodology</i> as also prepared and approved as set out in the SQSS Appendix H. The report shall include an assessment of the magnitude, duration and likelihood of transient frequency deviations, forecast impact and the cost of securing the system and confirm which risks will or will not be secured operationally by the <i>ISOP</i> in accordance with paragraphs 5.8, 5.11.2, 9.2 and 9.4.2.
Frequency Risk and Control Report Methodology	The methodology by which a <i>Frequency Risk Control Report</i> will be developed, consulted on and approved by the <i>Authority</i> , and as set out in the SQSS Appendix H.
Gas System Planner Licence	A licence granted or treated as granted under section 7AA(1) of the Gas Act 1986.
Generating Plant Type	A type of <i>generating unit</i> classified by the type of prime move, e.g. thermal hydro.
Generating Units	An <i>onshore generating unit</i> or an <i>offshore generating unit</i> .
Generation Circuit	The sole electrical connection between one or more <i>generating units</i> and the <i>main interconnected transmission system</i> i.e. a radial circuit which if removed would disconnect the <i>generating units</i> .
Generation Point of Connection	For the purpose of defining the boundaries between the <i>MITs</i> and <i>generation circuits</i> , the <i>generation point of connection</i> is taken to be the <i>busbar</i> clamp in the case of an air insulated substation, gas zone separator in the case of a gas insulated substation, or other equivalent point as may be determined by the relevant <i>Licensees</i> for new types of substation.
Generator	A person who generates electricity under licence or exemption under the Electricity Act 1989 as amended by the Utilities Act 2000 and the Energy Act 2004 as a <i>generator</i> in <i>Great Britain</i> or <i>Offshore</i> .
Governance Framework	Means the SQSS Governance Framework as contained in Appendix J.
Great Britain (GB)	The landmass of England and Wales and Scotland, including internal waters.
Grid Entry Point (GEP)	A point at which a <i>generating unit</i> or a CCGT module or an <i>offshore power park module</i> , as the case may be, which is directly connected to the <i>national electricity transmission system</i> , connects to the <i>national electricity transmission system</i> . The default point of connection is taken to be the <i>busbar</i> clamp in the case of an air insulated substation, gas zone separator in the case of a gas insulated substation, or equivalent point as may be determined by the relevant <i>Licensees</i> for new types of substation.
Grid Supply Point (GSP)	A point of supply from the <i>onshore transmission system</i> to <i>network operators</i> or <i>non-embedded customers</i> .
Group Demand	For a single <i>GSP</i> or <i>OSP</i> : The forecast maximum demand for the <i>GSP</i> or <i>OSP</i> provided in accordance with the requirements of the Grid Code by the <i>network operators</i> or <i>non-embedded customers</i> taking demand from the <i>national electricity transmission system</i> . For multiple <i>GSPs</i> or <i>OSPs</i> : The sum of the forecast maximum demands for the <i>GSPs</i> or <i>OSPs</i> as provided by the <i>network operators</i> or <i>non-embedded customers</i> taking demand from the <i>national electricity transmission system</i> .

Independent System Operator and Planner (<i>ISOP</i>)	Means a person designated by the Secretary of State under section 162 of the Energy Act 2023 as the holder of the <i>ESO licence</i> , and the <i>gas system planner licence</i> , for the time being that person is the NESO.
Information Request Notice	A notice that will be issued by the <i>ISOP</i> to a relevant party setting out the <i>ISOP</i> 's reasonable requirements for relevant information in accordance with section 172 of the Energy Act 2023. This will be prepared in accordance with the <i>ISOP</i> 's published information request statement.
Information Request Statement	A statement prepared and published by the <i>ISOP</i> , in accordance with section 172 of the Energy Act 2023 and condition D2.5 of its <i>ESO licence</i> and <i>gas system planner licence</i> , setting out the process that the <i>ISOP</i> will follow when requesting information from relevant parties by the issue of an <i>information request notice</i> .
Infrequent Infeed Loss Risk	Until 31st March 2014, this is a <i>loss of power infeed</i> risk of 1320 MW. From April 1st 2014, this is a <i>loss of power infeed</i> risk of 1800 MW.
Infrequent Operational Switching	<i>Operational switching</i> associated with rare or infrequent events rather than routine management of the system. <i>Infrequent operational switching</i> includes, for example, isolation of circuits for maintenance and subsequent re-energisation, and operation of intertrip schemes consequent upon <i>secured events</i> . It would not include switching out of circuits for voltage control, or switching out of circuits to allow safe access to other plant, where it is foreseen that such switching may be a regular practice; such events would be classed as <i>operational switching</i> .
Insufficient Voltage Performance Margins	In all timescales and in particular the post-fault periods (i.e. before, during and after the automatic controls take place), there are <i>insufficient voltage performance margins</i> when the following occurs: i) <i>voltage collapse</i>; ii) over-sensitivity of system voltage; or iii) unavoidably exceeds the reactive capability of <i>generating units</i> such that accessible reactive reserves are exhausted; under any of the following conditions: i) <i>credible demand sensitivities</i>; ii) the unavailability of any single reactive compensator or other reactive power provider; or iii) the loss of any one automatic switching system or any automatic voltage control system for on-load tap changing.
Intact System	This is the <i>national electricity transmission system</i> with no system outages i.e. with no <i>planned outages</i> (e.g. for maintenance) and no <i>unplanned outages</i> (e.g. subsequent to a fault).
Interconnection Allowance	An allowance in MW to be added in whole or in part to transfers arising out of the <i>security planned transfer condition</i> to take some account of non-average conditions (e.g. <i>power station</i> availability, weather and demand). This allowance is calculated by an empirical method described in Appendix D of this Standard.
Interface Point (IP)	A point at which an <i>offshore transmission system</i> , which is directly connected to an <i>onshore transmission system</i> , connects to the <i>onshore transmission system</i> . The <i>Interface Point</i> is located at the <i>first onshore substation</i> which the <i>offshore transmission circuits</i> reach onshore. The default point of connection, within the <i>first onshore substation</i> , is taken to be the <i>busbar</i> clamp in the case of an air insulated substation, gas zone separator in the case of a gas insulated substation, on either the lower voltage (LV) <i>busbars</i>

	or the higher voltage (HV) <i>busbars</i> as may be determined by the relevant <i>Licensees</i>. Normally, and unless otherwise agreed, if the <i>offshore transmission owner</i> owns the <i>first onshore substation</i>, the <i>interface point</i> would be on the HV <i>busbars</i> and, if the <i>first onshore substation</i> is owned by the <i>onshore transmission owner</i>, the <i>interface point</i> would be on the LV <i>busbars</i>.
Large Power Station	A <i>power station</i> which is: 1. directly connected to: a) <i>NGET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of 100 MW or more; b) <i>SPT's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of 30 MW or more; or c) <i>SHET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of 10 MW or more; Or 2. Embedded within a <i>user system</i> (or part thereof) where such <i>user system</i> (or part thereof) is connected under normal operating conditions to: a) <i>NGET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of 100 MW or more; or b) <i>SPT's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of 30 MW or more; or c) <i>SHET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of 10 MW or more. Or 3. In <i>offshore waters</i>, a <i>power station</i> connected to an <i>offshore transmission system</i> with a <i>registered capacity</i> of 10 MW or more.
Licensee	Means the holder, for the time being, of a <i>Transmission Licence</i> or the <i>ISOP</i> as the holder of the <i>ESO licence</i>, and in each case being a party that is required by their licence to comply with the Security and Quality of Supply Standard as approved by the <i>Authority</i>, and shall be construed accordingly.
Local System Outage	In the context of a <i>demand group</i> or <i>offshore power station demand group</i>, a <i>planned outage</i> or <i>unplanned outage</i> local to a <i>demand group</i> or <i>offshore power station demand group</i>, as the case may be, such that it has a direct effect on the supply capacity to that <i>demand group</i> or <i>offshore power station demand group</i>. In the context of planning generation connections, a <i>planned outage</i> local to a <i>power station</i> such that it has a direct effect on the generation connection capacity requirements for that <i>power station</i>.
Loss of Power Infeed	The output of a <i>generating unit</i> or a group of <i>generating units</i> or the import from <i>external systems</i> disconnected from the <i>national electricity transmission system</i> by a <i>secured event</i>, less the demand disconnected from the <i>national electricity transmission system</i> by the same <i>secured event</i>. For the avoidance of doubt if, following such a <i>secured event</i>, demand associated with the normal operation of the affected <i>generating unit</i> or <i>generating units</i> is automatically transferred to a supply point which is not disconnected from the system, e.g. the station board, then this shall not be deducted from the total <i>loss of power infeed</i> to the system. For the purpose of the operational criteria:

	i) the <i>loss of power infeed</i> includes the output of a single <i>generating unit</i>, CCGT Module, boiler, nuclear reactor or import from an <i>external system</i> via a HVDC Link. ii) In the case of an <i>offshore generating unit</i> or group of <i>offshore generating units</i>, the <i>loss of power infeed</i> is measured at the <i>interface point</i>, or <i>user system interface point</i>, as appropriate. iii) In the case of an <i>offshore generating unit</i> or group of <i>offshore generating units</i> for which infeed will be automatically re-distributed to one or more <i>interface points</i> or <i>user system interface points</i> through one or more interlinks, the re-distribution should be taken into account in determining the total generation capacity that is disconnected. However, in assessing this re-distribution, consequential losses of infeed that might occur in the re-distribution timescales due to wider generation instability or tripping, including losses at distribution voltage levels, should be taken into account.
Loss of Power Outfeed	The load taken by storage units, <i>non-embedded customers</i>, <i>grid supply points</i>, or the export to <i>external systems</i> disconnected from the <i>national electricity transmission system</i> by a <i>secured event</i>, less the generation disconnected from the <i>national electricity transmission system</i> by the same <i>secured event</i>. For the avoidance of doubt if, following such a <i>secured event</i>, demand associated with the normal operation of the affected outfeed is automatically transferred to a <i>grid supply point</i> which is not disconnected from the <i>national electricity transmission system</i>, then this shall not be added to the total <i>loss of power outfeed</i> to the system. For the purpose of the operational criteria: i) the <i>loss of power outfeed</i> includes demand from pump storage, battery storage and other storage, <i>non-embedded customers</i>, and export to <i>external systems</i> via a HVDC Link. ii) In the case of an <i>offshore transmission system</i>, the <i>loss of power outfeed</i> is measured at the <i>interface point</i>, or <i>user system interface point</i>, as appropriate.
Loss of Supply Capacity	This is the reduction in the supply capacity at a <i>grid supply point</i> or <i>offshore supply point</i> as a result of the <i>Licensees' failure</i> to maintain the potential to provide the supply capacity in full. For the avoidance of doubt, where the <i>Licensees</i> do maintain the potential to provide a supply but, following an outage, demand is lost because of circuit configurations not under the control of the <i>Licensees</i>, that lost supply does not constitute <i>loss of supply capacity</i>.
Main Interconnected Transmission System (MITS)	This comprises all the 400 kV and 275 kV elements of the <i>onshore transmission system</i> and, in Scotland, the 132 kV elements of the <i>onshore transmission system</i> operated in parallel with the <i>supergrid</i>, and any elements of an <i>offshore transmission system</i> operated in parallel with the <i>supergrid</i>, but excludes <i>generation circuits</i>, transformer connections to lower voltage systems, <i>external interconnections</i> between the <i>onshore transmission system</i> and <i>external systems</i>, and any <i>offshore transmission systems</i> radially connected to the <i>onshore transmission system</i> via single <i>interface points</i>.
Maintenance Period Demand	This is the demand level experienced at a <i>GSP</i> and is the maximum demand level expected during the normal maintenance period. This level is such that the period in which maintenance

	could be undertaken is not unduly limited. Unless better data are available this should be 67% of the <i>group demand</i> .
Major System Fault	An event or sequence of events so fast that it is not practically possible to re-secure the system between each one, more onerous than those included in the normal set of <i>secured events</i> .
Major System Risk	A period of major system risk is one in which <i>secured events</i> are judged to be significantly more likely than under the circumstances addressed by the normal criteria of this Standard, or they are judged to have a significantly greater impact than normal, or events not normally secured against are judged to be significantly more likely than normal such that measures should be taken to mitigate their impact.
Marshalling Substation	A substation which connects circuits from more than two line routes.
Medium Power Station	A <i>power station</i> which is: 1. directly connected to <i>NGET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of 50 MW or more, but less than 100 MW; or 2. embedded within an <i>user system</i> (or part thereof) where such <i>user system</i> (or part thereof) is connected under normal operating conditions to <i>NGET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of 50 MW or more but less than 100 MW; The <i>medium power station</i> category does not exist in <i>SPT's transmission system</i> and <i>SHET's transmission system</i>.
Member	A person duly appointed in accordance with paragraph 4.6 to be a Member of the <i>Panel</i> .
Minister of the Crown	As defined in the <i>ESO licence</i> .
National Electricity Transmission System	The <i>national electricity transmission system</i> comprises the <i>onshore transmission system</i> and the <i>offshore transmission systems</i> .
National Electricity Transmission System Operator Area	Has the meaning set out in Schedule 1 of <i>ESO licence</i>
NESO	The company with registered number 11014226 as the designated <i>ISOP</i> and holder of the <i>ESO licence</i> and the <i>gas system planner licence</i> .
National Electricity Transmission System Security and Quality of Supply Standard (NETS SQSS or SQSS)	National Electricity Transmission System Security and Quality of Supply Standard. The SQSS sets out a coordinated set of criteria and methodologies that the <i>Licensees</i> shall use in the planning and operation of the <i>National Electricity Transmission System</i> .
Network Operator	A person with a system directly connected to the <i>onshore transmission system</i> to which customers and/or <i>power stations</i> (not forming part of that system) are connected, acting in its capacity as an operator of that system, but shall not include a person who operates an <i>external system</i> .
NGET	National Grid Electricity Transmission plc (No. 2366977) whose registered office is 1-3 Strand, London WC2N 5EH
Non-Embedded Customer	A customer, except for a <i>network operator</i> acting in its capacity as such receiving electricity direct from the <i>national electricity transmission system</i> irrespective of from whom it is supplied.
Normal Infeed Loss Risk	Until 31st March 2014, this is a <i>loss of power infeed</i> risk of 1000 MW. From April 1st 2014, this is a <i>loss of power infeed</i> risk of 1320 MW.

Offshore	Means wholly or partly in <i>offshore waters</i> , and when used in conjunction with another term and not defined means that the associated term is to be read accordingly.
Offshore Generating Unit	Any apparatus, which produces electricity including, a synchronous <i>offshore generating unit</i> and non-synchronous <i>offshore generating unit</i> and which is located in <i>offshore waters</i> .
Offshore Grid Entry Point Capacity (OffGEP Capacity)	The cumulative <i>registered capacity</i> of all <i>offshore power stations</i> connected at a single <i>offshore grid entry point</i> and/or the cumulative <i>registered capacity</i> of all <i>offshore power stations</i> connected to all the <i>offshore grid entry points</i> of an <i>offshore transmission system</i>
Offshore Licensee	Means the holder of a <i>Transmission Licence</i> in respect of an <i>offshore transmission system</i> granted under Section 6 (1) (b) of the Electricity Act 1989 (as amended by the Utilities Act 2000 and the Energy Act 2004)
Offshore Platform	A platform, located in <i>offshore waters</i> , which contains plant and apparatus associated with the generation and/or transmission of electricity including high voltage electrical circuits which form part of an <i>offshore transmission system</i> and which may include one or more <i>offshore grid entry points</i>
Offshore Power Park Module	A collection of one or more <i>offshore power park strings</i> , located in <i>offshore waters</i> , registered as an <i>offshore power park module</i> under the provisions of the Grid Code. There is no limit to the number of <i>offshore power park strings</i> within the <i>offshore power park module</i> , so long as they either: a) connect to the same <i>busbar</i> which cannot be electrically split; or b) connect to a collection of directly electrically connected <i>busbars</i> of the same nominal voltage and are configured in accordance with the operating arrangements set out in the relevant Bilateral Agreement.
Offshore Power Park String	A collection of non-synchronous <i>offshore generating units</i> , located in <i>offshore waters</i> that are powered by an intermittent power source joined together by cables with a single point of connection to an <i>offshore transmission system</i> .
Offshore Power Station	An installation, located in <i>offshore waters</i> , comprising one or more <i>offshore generating units</i> or <i>offshore power park modules</i> or <i>offshore gas turbines</i> (even where sited separately) owned and/or controlled by the same <i>generator</i> , which may reasonably be considered as being managed as one <i>offshore power station</i> .
Offshore Power Station Demand Group	An <i>offshore</i> site or group of <i>offshore</i> sites located on an <i>offshore platform/s</i> which collectively take power from the remainder of an <i>offshore transmission system</i> for the purpose of supplying <i>offshore power station demand</i> .
Offshore Supply Point (OSP)	A point of supply from an <i>offshore transmission system</i> to an <i>offshore power station</i> .
Offshore Transmission Circuit	Part of an <i>offshore transmission system</i> between two or more circuit-breakers which includes, for example, transformers, reactors, cables, overhead lines and <i>DC converters</i> but excludes <i>busbars</i> and <i>onshore transmission circuits</i> .
Offshore Transmission Owner (OFTO)	A <i>Licensee</i> in relation to whose <i>Transmission Licence</i> the Standard Conditions in Section E (offshore transmission owner standard conditions) have been given effect.
Offshore Transmission System	A system consisting (wholly or mainly) of high voltage lines of 132 kV or greater owned and/or operated by an <i>offshore Licensee</i> and used for the transmission of electricity to or from an <i>offshore power station</i> to or from an <i>interface point</i> , or <i>user system interface point</i> if embedded, or to or from another <i>offshore power station</i> and includes equipment, plant and apparatus and meters

	owned or operated by an <i>offshore Licensee</i> in connection with the transmission of electricity. An <i>offshore transmission system</i> extends from the <i>interface point</i> or <i>user system interface point</i> , as the case may be, to the <i>offshore grid entry point/s</i> and may include plant and apparatus located onshore and <i>offshore</i> . For the avoidance of doubt, the <i>offshore transmission systems</i> , together with the <i>onshore transmission system</i> , form the <i>national electricity transmission system</i> .
Offshore Waters	Has the meaning given to “ <i>offshore waters</i> ” in Section 90(9) of the Energy Act 2004.
Onshore Generating Unit	Any apparatus which produces electricity including a synchronous <i>generating unit</i> and non-synchronous <i>generating unit</i> but excluding an <i>offshore generating unit</i> .
Onshore Interface Point	An electrical point of connection between the <i>transmission systems</i> of two <i>onshore licencees</i> .
Onshore Licensee	<i>NGET, SPT, SHET's</i> , and any <i>transmission licensee</i> appointed as a <i>competitively appointed transmission owner</i> and such other person who is the holder of a <i>transmission licence</i> in respect of an onshore transmission system granted under Section 6 (1) (b) of the Electricity Act 1989.
Onshore Power Park Module	A collection of non-synchronous <i>generating units</i> (registered as a <i>power park module</i> under the Planning Code in the Grid Code) that are powered by an intermittent power source, joined together by a system with a single point of electrical connection to the <i>onshore transmission system</i> (or <i>user system</i> if embedded). The connection to the <i>onshore transmission system</i> (or <i>user system</i> if embedded) may include a <i>DC converter</i> .
Onshore Power Station	An installation comprising one or more <i>onshore generating units</i> or <i>onshore power park module</i> (even where sited separately) owned and/or controlled by the same <i>generator</i> , which may reasonably be considered as being managed as one <i>onshore power station</i> .
Onshore Transmission Circuit	Part of the <i>onshore transmission system</i> between two or more circuit-breakers which include, for example, transformers, reactors, cables and overhead lines and <i>DC converters</i> , but excludes <i>busbars, generation circuits</i> and <i>offshore transmission circuits</i> .
Onshore Transmission System	The system consisting (wholly or mainly) of high voltage electric lines owned or operated by <i>onshore Licensees</i> and used for the transmission of electricity from one <i>power station</i> to a substation or to another <i>power station</i> or between substations or to or from <i>offshore transmission systems</i> or to or from any <i>external interconnections</i> and includes any plant and apparatus and meters owned or operated by <i>onshore Licensees</i> within <i>Great Britain</i> in connection with the transmission of electricity. The <i>onshore transmission system</i> does not include any <i>remote transmission assets</i> . For the avoidance of doubt, the <i>onshore transmission system</i> , together with the <i>offshore transmission systems</i> form the <i>national electricity transmission system</i> .
Operational Intertripping	The automatic tripping of circuit breakers to remove <i>generating units</i> and/or demand. It does not provide additional <i>transmission capacity</i> and must not lead to <i>unacceptable frequency conditions</i> for any <i>secured event</i> .
Operational Switching	Operation of plant and/or apparatus within the <i>onshore transmission system</i> or <i>offshore transmission system</i> to the instruction of the relevant control engineer. For the avoidance of doubt, <i>operational switching</i> includes manual actions and automatic actions including

	tap-changing, auto-switching schemes and automatic reactive switching schemes.
Panel	The SQSS <i>panel</i> established by the <i>ISOP</i> , <i>NGET</i> , <i>SHET</i> and <i>SPT</i> which shall be constituted in accordance with Appendix J.
Planned Outage	An outage of one or more items of primary transmission apparatus and/or generation plant, initiated by manually instructed action which has been subject to the recognised <i>national electricity transmission system operator area</i> outage planning process.
Planned Transfer Conditions	The condition arising from scaling the <i>registered capacities</i> of each <i>power station</i> such that the total of the scaled capacities is equal to the <i>ACS peak demand</i> minus imports from <i>external systems</i> . This scaling shall follow the techniques described in Appendix C.
Plant Margin	The amount by which the total installed capacity of <i>power stations</i> exceeds the net amount of the <i>ACS peak demand</i> minus the total imports from <i>external systems</i> . This is often expressed as a percentage (e.g. 20%) or as a decimal fraction (e.g. 0.2) of the net amount of the <i>ACS peak demand</i> minus the total imports from <i>external systems</i> .
Power Park Module	An <i>onshore power park module</i> and/or an <i>offshore power park module</i>
Power Station	Means an <i>onshore power station</i> or an <i>offshore power station</i> .
Pre-Fault Planning Voltage Limits	The voltage limits for use in planning timescales for circumstances before a fault.
Pre-Fault Rating	The specified pre-fault capability of transmission equipment. Due allowance shall be made for specific conditions (e.g. ambient/seasonal temperature), agreed time-dependent loading cycles of equipment and any additional relevant procedures. In operational timeframes dynamic ratings may also be used where available.
Prevailing System Conditions	These are conditions on the <i>national electricity transmission system</i> prevailing at any given time and will therefore normally include <i>planned outages</i> and <i>unplanned outages</i> .
Primary Transmission Equipment	Any equipment installed on the <i>national electricity transmission system</i> to enable bulk transfer of power. This will include <i>transmission circuits</i> , <i>busbars</i> , and switchgear.
Prioritisation Category	Has the meaning given to that term by the Authority Guidance on Code Modification Prioritisation.
Prioritisation Criteria	Has the meaning given to that term by the Authority Guidance on Code Modification Prioritisation.
Registered Capacity	a) In the case of a <i>generating unit</i> other than that forming part of a CCGT module or <i>power park module</i>, the normal full load capacity of a <i>generating unit</i> as declared by the <i>generator</i>, less the MW consumed by the <i>generating unit</i> through the <i>generating unit's</i> unit transformer when producing the same (the resultant figure being expressed in whole MW). b) In the case of a CCGT module or <i>offshore</i> gas turbine or <i>power park module</i>, the normal full load capacity of the CCGT module or <i>offshore</i> gas turbine or <i>power park module</i> (as the case may be) as declared by the <i>generator</i>, being the active power declared by the <i>generator</i> as being deliverable by the CCGT module or <i>offshore</i> gas turbine or <i>power park module</i> at the <i>GEP</i> (or in the case of a CCGT module or <i>offshore</i> gas turbine or <i>power park module</i> embedded in a <i>user system</i>, at the <i>user system</i> entry point), expressed in whole MW. c) In the case of a <i>power station</i>, the maximum amount of active power deliverable by the <i>power station</i> at the <i>GEP</i> (or in the case

	of a <i>power station</i> embedded in a <i>user system</i>, at the <i>user system</i> entry point), as declared by the <i>generator</i>, expressed in whole MW. The maximum active power deliverable is the maximum amount deliverable simultaneously by the <i>generating units</i> and/or CCGT modules and/or <i>offshore</i> gas turbines and/or <i>power park modules</i> less the MW consumed by the <i>generating units</i> and/or CCGT modules and/or <i>offshore</i> gas turbines and/or <i>power park modules</i> in producing that active power. d) In the case of a <i>DC converter</i> at a <i>DC converter</i> station, supplying active power to the <i>national electricity transmission system</i>, or a <i>user system</i>, from an <i>external system</i> or <i>generating unit(s)</i>, the normal full load amount of active power transferable from a <i>DC converter</i> at the <i>GEP</i> (or in the case of an embedded <i>DC converter</i> station at the <i>user system</i> entry point), as declared by the <i>DC converter</i> station owner, expressed in whole MW, or in MW to one decimal place. e) In the case of a <i>DC converter</i> station supplying active power to the <i>national electricity transmission system</i>, or a <i>user system</i>, from an <i>external system</i> or <i>generating unit(s)</i>, the maximum amount of active power transferable from a <i>DC converter</i> station at the <i>GEP</i> (or in the case of an embedded <i>DC converter</i> station at the <i>user system</i> entry point), as declared by the <i>DC converter</i> station owner, expressed in whole MW, or in MW to one decimal place.
Restoration Contractor	As defined in the Grid Code.
Restoration Plan	A plan produced, agreed and signed by the <i>ISOP</i> , <i>network operators</i> , <i>restoration contractors</i> and <i>Licensees</i> to restart the system in the event of a total or partial shutdown.
Secretary	The secretary of the <i>Panel</i> appointed in accordance with Appendix J.
Secured Event	A contingency which would be considered for the purposes of assessing system security and which must not result in the remaining <i>national electricity transmission system</i> being in breach of the security criteria. <i>Secured events</i> are individually specified throughout the text of this Standard. It is recognised that more onerous unsecured events may occur and additional operational measures within the requirements of the Grid Code may be utilised to maintain overall <i>national electricity transmission system</i> integrity.
Security Planned Transfer Conditions	The condition arising from scaling the <i>registered capacity</i> of each <i>power station</i> that is considered able to reliably contribute to peak demand security such that the total of the scaled capacities is equal to the <i>ACS peak demand</i> . Generation powered by intermittent sources (e.g. wind, wave, solar) and imports from <i>external systems</i> are not included in this condition. This scaling shall follow the techniques described in Appendix C.
SHET	Scottish Hydro-Electric Transmission plc (No. SC213461) whose registered office is situated at Inveralmond HS, 200 Dunkeld Road, Perth, Perthshire PH1 3AQ.
Small Power Station	A <i>power station</i> which is: 1. directly connected to: a. <i>NGET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of less than 50 MW; or b. <i>SPT's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of less than 30 MW; c. <i>SHET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of less than 10 MW; Or

	2. embedded within a <i>user system</i> (or part thereof) where such <i>user system</i> (or part thereof) is connected under normal operating conditions to: a. <i>NGET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of less than 50 MW; b. <i>SPT's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of less than 30 MW; c. <i>SHET's transmission system</i> where such <i>power station</i> has a <i>registered capacity</i> of less than 10 MW; Or 3. In <i>offshore waters</i>, a <i>power station</i> connected to an <i>offshore transmission system</i> with a <i>registered capacity</i> of less than 10 MW
SPT	SP Transmission Limited (No. SC189126) whose registered office is situated at 1 Atlantic Quay, Robertson Street, Glasgow G2 8SP.
Steady State	A condition of a power system in which all automatic and manual <i>corrective actions</i> have taken place and all of the operating quantities that characterise it can be considered constant for the purpose of analysis.
Sub-Synchronous Oscillations	Power system oscillations at frequencies that are less than the power frequency. They arise from modes of oscillation associated with interactions between certain elements on the system such as generator rotor circuits, generator shaft systems, series compensated lines, excitation system controllers, power system stabilisers, converter controllers of power park modules and converter controllers of DC interconnectors and links.
Supergrid	That part of the <i>national electricity transmission system</i> operated at a nominal voltage of above 200 kV.
System Instability	i) poor damping - where electromechanical oscillations of <i>generating units</i> are such that the resultant peak deviations in machine rotor angle and/or speed at the end of a 20 second period remain in excess of 15% of the peak deviations at the outset (i.e. the time constant of the slowest mode of oscillation exceeds 12 seconds); or ii) pole slipping - where one or more transmission connected synchronous <i>generating units</i> lose synchronism with the remainder of the system to which it is connected For the purpose of assessing the existence of <i>system instability</i>, a <i>fault outage</i> is taken to include a solid three phase to earth fault (or faults) anywhere on the <i>national electricity transmission system</i> with an appropriate clearance time. The appropriate clearance time is identified as follows: i) In <i>NGET's transmission system</i> and on other circuits identified by agreement between the relevant <i>Licensees</i>, clearance times consistent with the fault location together with the worst single failure in the main protection system should be used; ii) elsewhere, clearance times should be consistent with the fault location and appropriate to the actual protection, signalling equipment, trip and interposing relays, and circuit breakers involved in clearing the fault.
Transfer Capacity	That circuit capacity from adjacent <i>demand groups</i> which can be made available within the times stated in Table 3.1
Transient Time Phase	The time within which fault clearance or initial system switching, the transient decay and recovery, auto switching schemes, <i>generator</i> inter-tripping, and fast, automatic responses of controls

	such as <i>generator</i> AVR and SVC take place. Load response may be assumed to have taken place. Typically 0 to 5 seconds after an initiating event.
Transmission Area	Has the meaning set out in the <i>transmission licence</i> of a <i>transmission licensee</i> .
Transmission Capacity	The ability of a network to transmit electricity. It does not include the use of <i>operational intertripping</i> except in respect of paragraph 2.13 in Section 2, paragraph 4.10 in Section 4 and paragraphs 7.7 to 7.13 & 7.16 in Section 7.
Transmission Circuit	This is either an <i>onshore transmission circuit</i> or an <i>offshore transmission circuit</i> .
Transmission Licence	Means a transmission licence granted or treated as granted under Section 6(1)(b) of the Electricity Act 1989.
Transmission System	Has the same meaning as the term “<i>Licensee’s transmission system</i>” in the <i>Transmission licence</i> of a <i>Licensee</i> and in the <i>ESO licence</i>. Where references are made in this document to <i>NGET’s</i>, <i>SPT’s</i>, or <i>SHET’s transmission system</i>, such reference shall be deemed to include: • a <i>CATO’s transmission system</i> where that <i>CATO’s transmission system</i> has <i>onshore interface point(s)</i> with only one of <i>NGET’s</i>, <i>SPT’s</i>, or <i>SHET’s transmission systems</i>; or • elements of a <i>CATO’s transmission system</i> located within <i>NGET’s</i>, <i>SPT’s</i>, or <i>SHET’s transmission area</i> where the <i>CATO’s transmission system</i> has <i>onshore interface point(s)</i> with more than one of <i>NGET’s</i>, <i>SPT’s</i> and/or <i>SHETL’s transmission systems</i>.
Unacceptable Frequency Conditions	These are conditions where: i) the <i>steady state</i> frequency falls outside the statutory limits of 49.5Hz to 50.5Hz; or ii) a transient frequency deviation on the <i>MITS</i> does not meet the criteria below. Transient frequency deviations outside the limits of 49.5Hz and 50.5Hz shall: - only occur at intervals which ought to reasonably be considered as infrequent. - only persist for a duration which ought to reasonably be considered as tolerable; and - only deviate by a magnitude which ought to reasonably be considered as tolerable. The <i>Frequency Risk and Control Report</i> will define what is considered reasonable, infrequent and tolerable for each of these criteria for transient frequency deviations. It is not possible to be prescriptive with regard to the type of <i>secured event</i> which could lead to transient frequency deviations since this will depend on the extant frequency response characteristics of the system which the <i>ISOP</i> adjust from time to time to meet the security and quality requirements of this Standard.
Unacceptable Overloading	The overloading of any <i>primary transmission equipment</i> beyond its specified time-related capability. Due allowance shall be made for specific conditions (e.g. ambient/seasonal temperature), pre-fault loading, agreed time-dependent loading cycles of equipment

	and any additional relevant procedures. In operational timeframes dynamic ratings may also be used where available.
Unacceptable Sub-Synchronous Oscillations	<i>Sub-synchronous oscillations</i> with the relevant modes of oscillation having negative or insufficient net damping. <i>Unacceptable sub-synchronous oscillations</i> may have a significant effect on generating units including a significant reduction in the lifetime of the machine shaft system due to fatigue or the failure of some of its electrical components due to high voltages and / or currents.
Unacceptable Voltage Conditions	Voltages out with those specified in Section 6, Voltage Limits in Planning and Operating the <i>Onshore Transmission System</i> and/or outside the limits specified in Section 10, Voltage Limits in Planning and Operating an <i>Offshore Transmission System</i> , as applicable.
Unacceptably High Voltage	Steady state voltages above the maximum values specified in Section 6, Voltage Limits In Planning and Operating the <i>Onshore Transmission System</i> and/or above the maximum values specified in Section 10, Voltage Limits In Planning and Operating an <i>Offshore Transmission System</i> , as applicable.
Unplanned Outage	An outage of one or more items of <i>primary transmission apparatus</i> and/or generation plant, initiated by manually instructed action which has not been subject to the recognised <i>national electricity transmission system operator area</i> outage planning process
User System	Any system owned or operated by a user of the <i>national electricity transmission system</i> other than a <i>Licensee</i> comprising: a) <i>generating units</i>; and/or b) systems consisting wholly or mainly of electric circuits used for the distribution of electricity from <i>grid supply points</i> or <i>offshore supply points</i> or <i>generating units</i> or other entry points to the point of delivery to customers or other users. and plant and/or apparatus connecting: c) the system described above; or d) <i>non-embedded customers'</i> equipment; to the <i>national electricity transmission system</i> or to the relevant other <i>user system</i>, as the case may be. The <i>user system</i> includes any <i>remote transmission assets</i> operated by such user or other person and any plant and/or apparatus and meters owned or operated by the user or other person in connection with the distribution of electricity but do not include any part of the <i>national electricity transmission system</i>.
User System Interface Point (USIP)	A point at which an <i>offshore transmission system</i> , which is directly connected to a <i>user system</i> , connects to the <i>user system</i> . The <i>user system interface point</i> is located at the <i>first onshore substation</i> which the <i>offshore transmission circuits</i> reach onshore. The default point of connection, within the <i>first onshore substation</i> , is taken to be the <i>busbar</i> clamp in the case of an air insulated substation, gas zone separator in the case of a gas insulated substation, or equivalent point on either the lower voltage (LV) busbars or the higher voltage (HV) <i>busbars</i> as may be determined by the relevant <i>Licensee</i> and <i>distribution licensee</i> . Normally, and unless otherwise agreed, if the <i>offshore transmission owner</i> owns the <i>first onshore substation</i> , the <i>user system interface point</i> would be on the HV <i>busbars</i> and if the <i>first onshore substation</i> is owned by the onshore distribution owner, the <i>user system interface point</i> would be on the LV <i>busbars</i> .
Voltage Collapse	Where progressive, fast or slow voltage decrease or increase develops such that it can lead to either tripping of <i>generating units</i> and/or loss of demand.

Voltage Step Change	The difference in voltage between that immediately before a <i>secured event</i> or operational switching and that at the end of the <i>transient time phase</i> after the event.
---------------------	---

Appendix A. Recommended Substation Configuration and Switching Arrangements

Part 1 – Onshore Transmission System

- A.1 The recommendations set out in paragraphs A.2 to A.6 apply to the *onshore transmission system*
- A.2 The key factors which must be considered when planning the *onshore transmission system* substation include:
- A.2.1 Security and Quality of Supply - Relevant criteria are presented in Sections 2, 3 and 4.
 - A.2.2 Extendibility - The design should allow for the forecast need for future extensions.
 - A.2.3 Maintainability - The design must take account of the practicalities of maintaining the substation and associated circuits.
 - A.2.4 Operational Flexibility - The physical layout of individual circuits and groups of circuits must permit the required power flow control.
 - A.2.5 Protection Arrangements - The design must allow for adequate protection of each system element.
 - A.2.6 Short Circuit Limitations - In order to contain short circuit currents to acceptable levels, *busbar* arrangements with sectioning facilities may be required to allow the system to be split or re-connected through a fault current limiting reactor.
 - A.2.7 Land Area - The low availability and/or high cost of land particularly in densely populated areas may place a restriction on the size and consequent layout of the substation.
 - A.2.8 Cost
- A.3 Accordingly the design of a substation is a function of prevailing circumstances and future requirements as perceived in the planning time phase. This appendix is intended as a functional guidance for substation layout design and switchgear arrangements. Variations away from this guidance are permissible provided that such variations comply with the requirements of the criteria set out in the main text of this Standard.

Generation Point of Connection Substations

- A.4 In accordance with the planning criteria for generation connection set out in Section 2, *generation point of connection* substations should:
- A.4.1 have a double *busbar* design (i.e. with main and reserve *busbars* such that *generation circuits* and *onshore transmission circuits* may be selected to either);
 - A.4.2 have sufficient *busbar* sections to permit the requirements of paragraph 2.6 to be met without splitting the substation during maintenance of *busbar* sections;
 - A.4.3 have sufficient *busbar* coupler and/or *busbar* section circuit breakers so that each section of the main and reserve *busbar* may be energised

- using either a *busbar* coupler or *busbar* section circuit breaker;
- A.4.4 have *generation circuits* and *onshore transmission circuits* disposed between *busbar* sections such that the main *busbar* may be operated split for fault level control purposes; and
- A.4.5 have sufficient facilities to permit the transfer of *generation circuits* and *onshore transmission circuits* from one section of the main *busbar* to another.

Marshalling Substations

A.5 Marshalling substations should:

- A.5.1 have a double *busbar* design (i.e. with main and reserve *busbars* such that *onshore transmission circuits* may be selected to either);
- A.5.2 have sufficient *busbar* sections to permit the requirements of paragraphs 2.6, 4.6 and 4.9 to be met;
- A.5.3 have *onshore transmission circuits* disposed between *busbar* sections such that the main *busbar* may be operated split for fault level control purposes; and
- A.5.4 have sufficient facilities to permit the transfer of *onshore transmission circuits* from one section of *busbar* to another.

Grid Supply Point Substations

A.6 In accordance with the planning criteria for demand connection set out in Section 3, *GSP* substations configurations range from a single transformer teed into an *onshore transmission circuit* to a four switched mesh substation or a double *busbar* substation. The choice and need for the extendibility will depend on the circumstances as perceived in the planning time phase.

Part 2 – Offshore Transmission Systems

- A.7 The recommendations set out in paragraphs A.7 to A.15 apply to *offshore transmission systems*
- A.8 The key factors which must be considered when planning an *offshore transmission system* substation include:
 - A.8.1 Security and Quality of Supply - Relevant criteria are presented in Sections 7 and 8.
 - A.8.2 Maintainability - The design must take account of the practicalities of maintaining the substation and associated circuits.
 - A.8.3 Operational Flexibility - The physical layout of individual circuits and groups of circuits must permit the required power flow control.
 - A.8.4 Protection Arrangements - The design must allow for adequate protection of each system element.
 - A.8.5 Short Circuit Limitations - In order to contain short circuit currents to acceptable levels, *busbar* arrangements with sectioning facilities may be required to allow the system to be split or re-connected through a fault current limiting reactor.

- A.8.6 Available Area –The high cost of the *offshore platform* may place a restriction on the size and consequent layout of the substation.
- A.8.7 Cost.
- A.9 Accordingly the design of a substation is a function of prevailing circumstances and future requirements as perceived in the planning time phase. This appendix is intended as a functional guidance for substation layout design and switchgear arrangements. Variations away from this guidance are permissible provided that such variations comply with the requirements of the criteria set out in the main text of this Standard.

Offshore Transmission System Substations

Offshore GEP Substations (on an Offshore Platform)

- A.10 In accordance with the planning criteria for *offshore* generation connection set out in Section 7, the substation should:
 - A.10.1 have sufficient *busbar* sections to permit the requirements of paragraph 7.8 to be met without splitting the substation during maintenance of *busbar* sections; and
 - A.10.2 have sufficient *busbar* coupler and/or *busbar* section circuit breakers so that each *busbar* section may be energised using either a *busbar* coupler or *busbar* section circuit breaker.

IP and USIP Substations

- A.11 The following recommendations apply equally to substations at the:
 - A.11.1 In the case of an offshore transmission system at the Onshore Interface Point (at the First Onshore Substation); and
 - A.11.2 Onshore User System Interface Point (at the First Onshore Substation)
- A.12 In accordance with the planning criteria for *offshore* generation connection set out in Section 7, the substation should in the case of an *offshore power park module* and multiple gas turbine connections:
 - A.12.1 have a double *busbar* design (i.e. with main and reserve *busbars* such that *offshore generation circuits* owned by the *generator* and *offshore transmission circuits* may be selected to either);
 - A.12.2 have sufficient *busbar* sections to permit the requirements of paragraph 7.13 to be met without splitting the substation during maintenance of *busbar* sections;
 - A.12.3 have sufficient *busbar* coupler and/or *busbar* section circuit breakers so that each section of the main and reserve *busbar* may be energised using either a *busbar* coupler or *busbar* section circuit breaker; and
 - A.12.4 have sufficient facilities to permit the transfer of *offshore generation circuits* owned by the *generator* and *offshore transmission circuits* from one section of the main *busbar* to another.
- A.13 In the case of a single gas turbine connection and in accordance with the planning criteria for *offshore* generation connection set out in Section 7, the substation should have a single *busbar* design;

Marshalling Substations

- A.14 The following recommendations apply to *offshore marshalling substations*, which interconnect *offshore transmission circuits* from two or more *offshore platforms*, where *offshore grid entry points* are located, and the *first onshore substation*, where the *interface point* or *user system interface point* is located.
- A.15 *Marshalling Substations* should:
- A.15.1 have a double *busbar* design (i.e. with main and reserve *busbars* such that *offshore transmission circuits* may be selected to either);
 - A.15.2 have sufficient *busbar* sections to permit the requirements of Section 7 to be met;
 - A.15.3 have *transmission circuits* disposed between *busbar* sections such that the main *busbar* may be operated split for fault level control purposes; and
 - A.15.4 have sufficient facilities to permit the transfer of *offshore transmission circuits* from one section of *busbar* to another.

Offshore Supply Point Substations

- A.16 *Offshore supply point substations* should be designed to meet the requirements of Section 8. The actual design will depend on the circumstances as perceived in the planning time phase.

Appendix B. Circuit Complexity on the ***Onshore Transmission System***

- B.1 This appendix defines restrictions to be applied by the relevant *onshore Licensee* when *onshore transmission circuits* are designed, constructed or extended. These restrictions are intended to ensure that the time required to isolate and earth circuits in preparation for maintenance work is kept to a minimum and is not disproportionate to the time required to carry out maintenance work. The restrictions also limit the potential for human error.
- B.2 This appendix is divided into two parts. The first defines those restrictions that apply to *transmission circuits* on the *supergrid* part of the *MITS*. The second gives guidance on those restrictions that may be applied to *transmission circuits* on that part of the *MITS* operated at a nominal voltage of 132 kV.

Restrictions for *Transmission Circuits* on the *Supergrid*

- B.3 The three restrictions to be applied to *transmission circuits* on the *supergrid* part of the *MITS* are as follows.
- B.3.1 The facilities, for the isolation and earthing of *transmission circuits* and transmission equipment, shall not be located at more than three individual sites;
- B.3.2 The normal operational procedure, for the isolation and earthing of *transmission circuits* and transmission equipment, shall not require the operation of more than five circuit-breakers; and
- B.3.3 No more than three transformers shall be connected together and controlled by the same circuit breaker.
- B.4 A site, in this context, is defined as being where the points of isolation at one end of a *transmission circuit* are within the same substation such that only one authorised person is required, at the site, to enable the efficient and effective release and restoration of the circuit.
- B.5 If the design of a substation is such that two circuit-breakers of the same voltage are used to control a circuit (e.g. in a mesh type of substation), for the purposes of the above restrictions the two circuit-breakers are to be considered as a single circuit breaker. This also applies where duplicate circuit-breakers control a circuit including those used for *busbar* selection.
- B.6 Switch disconnectors that are not rated for fault breaking duty should not be included in the design of new *transmission circuits* and substations for the purpose of reducing complexity. Where the extension of an existing *transmission circuit* includes an existing switch disconnector and that switch disconnector is not rated for fault breaking duty, that switch disconnector can be considered for use in planned switching procedures only.
- B.7 For the purposes of restriction in B.3.3 a transformer which includes two low voltage windings in its construction shall be considered as single transformer.

Guidance for *Transmission Circuits* Operated at a Nominal Voltage of 132 kV

- B.8 The restrictions recommended below should be regarded as being in general the limits of good planning. The majority of 132 kV circuits do not reach this limit nor will they be expected to do so.

- B.9 Any proposals which would result in these limits being exceeded should be fully explained and agreed with operational engineers.
- B.10 Care must be observed in the application of these recommendations to “Active Circuits” to ensure that protective gear clearance times and discrimination are satisfactory and that the security of lower voltage connected generation is not unduly prejudiced.

Restriction A

- B.11 The normal operating procedure or protective gear operation for making dead any 132 kV circuit shall not require the opening of more than seven circuit-breakers. These circuit-breakers shall not be located on more than four different sites.
 - B.11.1 The circuit-breakers to be counted include all those which connect the circuit to other parts of the system.
 - B.11.2 In a mesh or similar type substation, two circuit-breakers of the same voltage in the mesh controlling a circuit count as one circuit-breaker.
 - B.11.3 Where a circuit is controlled by two circuit-breakers which select between main and reserve *busbars*, these count as one circuit-breaker.
 - B.11.4 Switching isolators are not regarded as circuit-breakers for the purpose of this restriction.

Restriction B

- B.12 Not more than three transformers shall be banked together on any one circuit at any one site.
 - B.12.1 A transformer with two lower voltage windings counts as one transformer.

Restriction C

- B.13 No item of equipment shall have isolating facilities on more than four different sites.
 - B.13.1 Isolating facilities will normally be provided by means of circuit-breakers and their associated isolators.
 - B.13.2 Points of isolation on a circuit within an agreed reasonable walking distance to permit the efficient and effective use of one authorized person only at those points during the release and restoration of the circuit shall be regarded as being on one site.
 - B.13.3 Switching isolators having a “fault make, load break” capability shall be regarded as circuit-breakers for the purpose of this restriction.
 - B.13.4 In special circumstances a plain-break normally-open isolator may be counted as an isolating facility for the equipment on either side of it. An example of this is an isolator in the route of a circuit bridging two *supergrid* zones which would be closed only for emergencies of greater severity than those covered by the security standards for 132 kV planning.

Appendix C. Modelling of Security Planned Transfer

- C.1 There are two techniques relevant to the determination of *Security planned transfer conditions*. For circumstances in which apparent future *plant margins* exceed 20%, the 'Ranking Order technique' should be applied. Where the apparent future *plant margin* is 20% or less, the 'Straight Scaling Technique' should be applied. These techniques are described below.
- C.2 Imports from *external systems* (e.g. in France or Ireland) shall not be scaled under either of these two scaling techniques because they result from tranches of generation rather than single *power stations*.

Availability Factors

- C.3 In derivation of *Security planned transfer conditions*, the registered capacities of *power stations* are scaled by availability factors, known as A_T , for classes T of *power station*. For the *Security planned transfer condition*, these factors are set as follows:
- C.3.1 For stations powered by wind, wave, or tides, $A_T = 0$. This zero factor is set for the *Security planned transfer condition* so that there is confidence that there is sufficient *transmission capacity* to meet demand securely in the absence of this class of generation.
- C.3.2 For imports or exports from / to *external systems*, $A_T = 0$.
- C.3.3 For all other *power stations*, $A_T = 1.0$

Ranking Order Technique

- C.4 In some circumstances apparent future *plant margins* may exceed 20%. This may arise where the *ISOP* has been notified of increases in future generation capacity but has not yet been formally notified of future reductions in generation capacity due to plant closures. The ranking order technique maintains the output of *power stations* considered more likely to operate at times of *ACS peak demand* at more realistic levels and treats those less likely to operate as non-contributory.
- C.5 This is achieved by ranking all directly connected *power stations*, embedded *large power stations*, and groups of embedded *medium power stations* and embedded *small power stations* aggregated based on their generation technology and their location in order of likelihood of operation at times of *ACS peak demand*. Those *power stations* considered least likely to operate at peak are progressively removed and treated as non-contributory until a *plant margin* of 20% or just below is achieved. The output of the remainder is then calculated using the same scaling method as used in the straight scaling technique described in paragraphs C.5 and C.6 below.

Straight Scaling Technique

- C.6 In this technique, all *power stations* at the time of the *ACS peak demand* are considered contributory and their output is calculated by applying a scaling factor to their *registered capacity* proportional to an availability representative of the *generating plant type* at the time of *ACS peak demand* such that their aggregate output is equal to the forecast *ACS peak demand* minus total imports from *external systems*.

C.7 Thus,

$$P_{T_i} = S \cdot A_T \cdot R_{T_i}$$

Where

$$S = \frac{P_{\text{loss}} + \sum_j L_j}{\sum_T \left(A_T \cdot \sum_i R_{T_i} \right)}$$

and

- P_{T_i} = the output of the *i*th power station of generating plant type *T*
- A_T = an availability representative of generating plant type *T* at the time of ACS peak demand
- R_{T_i} = the registered capacity of the *i*th power station of generating plant type *T*
- P_{loss} = total national electricity transmission system active power losses at time of ACS peak demand
- L_j = the active power demand at the *j*th national electricity transmission system demand site at the time of ACS peak demand

Appendix D. Application of the *Interconnection Allowance*

- D.1 This appendix outlines the techniques underlying the use of the *interconnection allowance* under paragraphs 4.4.2 and 4.4.5.
- D.2 The modification of the MITS Security planned transfer condition power flow pattern to reflect an interconnection allowance shall apply to the national electricity transmission system divided into any two contiguous parts provided that
- D.2.1 the smaller part contains more than 1500 MW of demand at the time of the *ACS peak demand*; and
 - D.2.2 the boundary between the two parts lies on the boundary between *SHET's transmission system* and *SPT's transmission system*, or between *SPT's transmission system* and *NGET's transmission system*, or entirely within *NGET's transmission system*.
- D.3 The *interconnection allowance* is then applied by:-
- D.3.1 summing the demand and the total active power generation output (including imports from *external systems*) under the *Security planned transfer condition* within the smaller of the two parts and expressing this sum as a percentage of twice the *ACS peak demand*;
 - D.3.2 using Figure D.1, traditionally known as the 'Circle Diagram', to determine the *interconnection allowance* (in MW) by taking the appropriate percentage of the *ACS peak demand*;
 - D.3.3 finding the total active power generation output and total demand in each part of the system when applying the *interconnection allowance* or half *interconnection allowance* (as appropriate) as described in paragraphs D.4 and D.5;
 - D.3.4 for the conditions described under paragraph 4.4.2, proportionally scaling all the generation and demand in both parts of the system, as described in paragraphs D.4 and D.5 below, such that the transfer between the two parts increases by: first, the full *interconnection allowance* when considering the single *fault outages* in 4.6.1; and second, half the *interconnection allowance* for all other *secured events* in paragraph 4.6;
 - D.3.5 for the conditions described under paragraph 4.4.5, proportionally scaling demand in both parts of the system and setting *generating units* with their outputs such that their totals are as described in paragraphs D.4 and D.5 below such that the transfer between the two parts increases by: first, the full *interconnection allowance* when considering the single *fault outages* in item 4.6.1; and second, half the *interconnection allowance* for all other *secured events* in paragraph 4.6.
- D.4 Suppose that the two contiguous parts of the system in question are areas 1 and 2 and that area 1 exports to area 2. Let G_1 and G_2 be the total generation in areas 1 and 2 respectively and D_1 and D_2 be the total demand in areas 1 and 2 under the *Security planned transfer condition*. Let I be the transfer required in addition to that under the *Security planned transfer condition* (i.e. the value of I is equal to the *interconnection allowance* or half the *interconnection allowance* as specified in

paragraphs D.3.4 and D.3.5).

- D.5 The additional transfer is proportionally divided between the generation and demand in the two areas as follows:

the total demands after application of the *interconnection allowance* or half *interconnection allowance* in areas 1 and 2 are:

$$D_1' = k_{d1}D_1$$

$$D_2' = k_{d2}D_2$$

and the total amounts of generation in areas 1 and 2 are:

$$G_1' = k_{g1}G_1$$

$$G_2' = k_{g2}G_2$$

where:


$$k_{d1} = 1 - \frac{I}{D_1 + G_1}$$

$$k_{g1} = 1 + \frac{I}{D_1 + G_1}$$

and:

$$k_{d2} = 1 + \frac{I}{D_2 + G_2}$$

$$k_{g2} = 1 - \frac{I}{D_2 + G_2}$$



Notes

1. 'Demand' shall comprise all components of ACS peak demand
2. 'Generation' shall comprise
 - a) the output from *large power stations*, *medium power stations*, and *small power stations* whether these are embedded or directly connected to the *national electricity transmission system*
 - b) imports into the *national electricity transmission system* from *external systems*

Sum of demand and generation in the smaller area as a percentage of twice the total ACS peak demand

Figure D.1 *Interconnection allowance* as a function of area size (the 'circle diagram')

Appendix E. Modelling of *Economy Planned Transfer*

- E.1 For the determination of *economy planned transfer conditions* plant is categorised in three groups:
 - E.1.1 non-contributory generation. This plant, such as OCGTs, does not form part of the generation background
 - E.1.2 directly scaled plant. The output of plant in this category is determined by a fixed scaling factor, described in E.3
 - E.1.3 variably scaled plant. The output of plant in this category is uniformly scaled by a variable factor that is calculated to ensure that generation and demand balance. This is described in E.5.
- E.2 The *ISOP* will from time-to-time review, consult on, and publish the categorisation of plant.

Directly Scaled Plant

- E.3 In the *Economy planned transfer condition* the *registered capacities* of certain classes of *power station* are scaled by fixed factors, known as D_T , for classes T of *power station*. These factors are set as follows:
 - E.3.1 For nuclear stations, and for coal-fired and gas-fired stations fitted with Carbon Capture and Storage, $D_T = 0.85$
 - E.3.2 For stations powered by wind, wave, or tides, $D_T = 0.70$.
 - E.3.3 For pumped storage based stations, $D_T = 0.5$
 - E.3.4 For interconnectors to *external systems* regarded as importing into GB at the time of peak demand, $D_T = 1.0$
- E.4 The *ISOP* will review the appropriateness of these factors and revise them where necessary, based on alignment with cost benefit analysis. The period between reviews shall be no more than five years, but may be less if required.

Variably Scaled Plant

E.5 All remaining *power stations* and on the system at the time of the *ACS peak demand* are considered contributory and their output is calculated by applying a scaling factor to their *registered capacity* such that their aggregate output is equal to the forecast *ACS peak demand* minus the total output of directly scaled plant.

E.6 Thus,

$$P_{T_i} = \begin{cases} 0 & \text{for non - contributory plant} \\ D_T \times R_{DT_i} & \text{for directly scaled plant} \\ S \times R_{VT_i} & \text{for variably scaled plant} \end{cases}$$

where

$$S = \frac{P_{\text{loss}} + \sum_j L_j - \sum_{DT} \left(\sum_k (D_T \times R_{DT_k}) \right)}{\sum_{VT} \left(\sum_n R_{VTn} \right)}$$

and

- P_{T_i} = the output of the i^{th} *power station* of generation plant type T
- D_T = the direct scaling factor for directly scaled generation of plant type T
- R_{DT_k} = the *registered capacity* of the k^{th} *power station* of generation plant type DT in the directly scaled category
- R_{VTn} = the *registered capacity* of the n^{th} *power station* of generation plant type VT in the variably scaled category
- P_{loss} = total *national electricity transmission system* active power losses at time of *ACS peak demand*
- L_j = the active power demand at the j^{th} *national electricity transmission system* demand site at the time of *ACS peak demand*

Appendix F. Application of the *Boundary Allowance*

- F.1 This appendix outlines the techniques underlying the use of the *boundary allowance* under paragraphs 4.4.4 and 4.4.5.
- F.2 The modification of the *MITS Economy planned transfer condition* power flow pattern to reflect a *boundary allowance* shall apply to the *national electricity transmission system* divided into any two contiguous parts, irrespective of the size or location of the parts.
- F.3 The *boundary allowance* is applied by:-
- F.3.1 summing the demand and the total active power generation output (including imports from *external systems*) under the *Economy planned transfer condition* within the smaller of the two parts;
 - F.3.2 using Figure F.1 to determine the *boundary allowance* (in MW);
 - F.3.3 finding the total active power generation output and total demand in each part of the system when applying the *boundary allowance* or half *boundary allowance* (as appropriate) as described in paragraphs F.4 and F.5;
 - F.3.4 for the conditions described under paragraph 4.4.4, proportionally scaling all the generation and demand in both parts of the system, as described in paragraphs F.4 and F.5 below, such that the transfer between the two parts increases by: first, the full *boundary allowance* when considering the single *fault outages* in 4.6.1; and second, half the *boundary allowance* for all other *secured events* in paragraph 4.6;
 - F.3.5 for the conditions described under paragraph 4.4.5, proportionally scaling demand in both parts of the system and setting *generating units* with their outputs such that their totals are as described in paragraphs F.4 and F.5 below such that the transfer between the two parts increases by: first, the full *boundary allowance* when considering the single *fault outages* in item 4.6.1; and second, half the *boundary allowance* for all other *secured events* in paragraph 4.6.
- F.4 Suppose that the two contiguous parts of the system in question are areas 1 and 2 and that area 1 exports to area 2. Let G_1 and G_2 be the total generation in areas 1 and 2 respectively and D_1 and D_2 be the total demand in areas 1 and 2 under the *planned transfer condition*. Let B be the transfer required in addition to that under the *planned transfer condition* (i.e. the value of B is equal to the *boundary allowance* or half the *boundary allowance* as specified in paragraphs F.3.4 and F.3.5).
- F.5 The additional transfer is proportionally divided between the generation and demand in the two areas as follows:
- the total demands after application of the *boundary allowance* or half *boundary allowance* in areas 1 and 2 are:

$$D_1' = k_{d1}D_1$$

$$D_2' = k_{d2}D_2$$

and the total amounts of generation in areas 1 and 2 are:

$$G_1' = k_{g1}G_1$$

$$G_2' = k_{g2}G_2$$

where:

$$k_{d1} = 1 - \frac{B}{D_1 + G_1}$$

$$k_{g1} = 1 + \frac{B}{D_1 + G_1}$$

and:

$$k_{d2} = 1 + \frac{B}{D_2 + G_2}$$

$$k_{g2} = 1 - \frac{B}{D_2 + G_2}$$




Figure F.1 Boundary allowance

Appendix G. Guidance on Economic Justification

G.1 These guidelines may be used to assist in the:

- G.1.1 economic justification of investment in transmission equipment and/or purchase of services such as reactive power in addition to that required to meet the planning criteria of Sections 2, 3, 4, 7 or 8.
- G.1.2 economic justification of the rearrangement of typical *planned outage* patterns and appropriate re-selection of *generating units*, for example through *balancing services*, from those expected to be available under the provisions of paragraph 2.13 in Section 2, paragraph 4.10 in Section 4 and 7.19 in Section 7; and
- G.1.3 evaluation of any expected additional operational costs or investments resulting from a proposed variation in connection design under the provisions of paragraphs 2.15 to 2.18 and/or paragraphs 3.12 to 3.15 and/or paragraphs 7.21 to 7.24.

G.2 Guidelines:

- G.2.1 additional investment in transmission equipment and/or the purchase of services would normally be justified if the net present value of the additional investment and/or service cost is less than the net present value of the expected operational or unreliability cost that would otherwise arise.
- G.2.2 the assessment of expected operational costs and the potential reliability implications shall normally require simulation of the expected operation of the *national electricity transmission system* in accordance with the operational criteria set out in Section 5 and Section 9 of the Standard.
- G.2.3 due regard should be given to the expected duration of an appropriate range of prevailing conditions and the relevant *secured events* under those conditions as defined in section 5 and Section 9.
- G.2.4 the operational costs to be considered shall normally include those arising from:
 - transmission power losses;
 - frequency response;
 - reserve;
 - reactive power requirements; and
 - system constraints,and may also include costs arising from:
 - rearrangement of transmission maintenance times; or
 - modified or additional contracts for other services.
- G.2.5 all costs should take account of future uncertainties
- G.2.6 the evaluation of unreliability costs expected from operation of the *national electricity transmission system* shall normally take account of the number and type of customers affected by supply interruptions and

use appropriate information available to facilitate a reasonable assessment of the economic consequences of such interruptions.

Appendix H. Frequency Risk and Control Report Methodology and Application

Introduction

- H.1 This appendix sets out the process for production of a periodic *Frequency Risk and Control Report* (FRCR), in accordance with an agreed process and which is regularly reviewed and updated in consultation with interested parties and is subject to approval by the *Authority*.
- H.2 The FRCR is required to provide a transparent and consulted assessment of the risk of unacceptable frequency conditions occurring, and their impact on Security of Supply inherent in the operation of the *National Electricity Transmission System*. It will set out which of these frequency risks the system should be secured against by the *ISOP* in their operation of the system to allow a balance to be struck between the consideration of risks, the benefit of avoiding these risks materialising, and the economic and efficient costs that will be incurred in ensuring the safe and secure operation of the system to do so.
- H.3 The methodology underpinning the FRCR process, along with how this will be approved, is set out in Part A of this appendix. The requirements for the publication of the periodic FRCR are outlined in Part B. Obligations on parties regarding the provision of information underpinning the FRCR process are described in Part C. Together these activities make up the FRCR process.

Part A: The Frequency Risk and Control Report (FRCR) methodology

- H.4 The *ISOP* shall initially and thereafter as required or as the *Authority* may direct, develop proposals for the FRCR methodology which will include the form and general expected content and structure of the FRCR. This will be carried out in consultation with interested parties. The consultation shall be of such a form and duration as to reasonably allow all interested parties to contribute.
- H.5 Following any consultation pursuant to paragraph H4, the *ISOP* must:
- (a) by 1 April 2021, or such other date as directed by the *Authority*, submit to the SQSS Panel an initial FRCR methodology and proposed form of the initial FRCR; and
 - (b) by such other date as directed by the *Authority* or as the *ISOP* may see fit, further submit to the SQSS Panel an updated FRCR methodology.
- H.6 The *ISOP* must make reasonable endeavours to ensure the FRCR methodology includes the information set out in paragraph H9. Where this has not been possible, the *ISOP* must explain the reasons and how it proposes to progress outstanding issues.
- H.7 Submissions made under paragraph H5 must include:
- (a) detailed explanation of the consultation process undertaken in the development of the FRCR methodology;
 - (b) a summary of the views received from interested parties as part of the consultation process and an explanation of how these were taken into account in the development of the FRCR methodology; and
 - (c) copies of any formal responses submitted as part of the consultation process.
- H.8 The *SQSS Panel* will on receipt of a submission under paragraph H5:

- (a) recommend that the proposed FRCR methodology be used in the subsequent production of a FRCR; or
- (b) give direction to the *ISOP* that the FRCR methodology requires further development.

In making its recommendation the SQSS Panel will give due regard to its expertise in the matters covered by the proposed FRCR methodology and will seek appropriate advice and guidance where required.

H.9 The FRCR methodology must be designed to facilitate the economic assessment of the risk of unacceptable frequency conditions occurring on the *National Electricity Transmission System* and which of these risks will be secured. The FRCR methodology must include (but need not be limited to):

- (a) the approach to be used to determine the circumstances for which unacceptable frequency conditions should not occur;
- (b) the approach to be used in clearly setting out each of the risks or categories of risk that are present in the operation of the system which will be used in the assessment of unacceptable frequency conditions, including specific events and the direct and indirect consequences of these, and as will be set out in the FRCR in accordance with the methodology and the specific requirements of paragraph H17;
- (c) how each of the risks identified in (b) will be assessed, including but not limited to:
 - (i) the approach used to assess the technical and economic impacts;
 - (ii) the approach used to assess the likelihood and consequence of each such risk occurring; and
 - (iii) the approach used to quantify the cost of mitigating each such risk.
 - (iv) the sources of information as used to perform the assessment.
- (d) the benefits to the consumer in mitigating risks to the secure operation of the system;
- (e) how the *ISOP* will engage with interested parties to share relevant information and how that information will be used to review and revise the FRCR methodology; and
- (f) detailed of the *ISOP*'s proposed timetable for updating and consulting on the FRCR methodology.

Part B: The Frequency Risk and Control Report (FRCR)

- H.10 The *ISOP* shall initially and at such other times as the *ISOP* may see fit or the *Authority* may direct, develop proposals for the FRCR in consultation with interested parties. The consultation shall be of such a form and duration as to reasonably allow all interested parties to contribute.
- H.11 Following any consultation pursuant to paragraph H10, the *ISOP* must:
- (a) produce an initial FRCR by 1 April 2021 or such other date as directed by the *Authority* and submit this to the SQSS Panel for their recommendation that this be onwards submitted to the *Authority* for approval. This must be based on and prepared in accordance with the draft initial methodology set out in part A.; and
 - (b) by such other date as directed by the *Authority* or as *The ISOP* may see fit, and as set out in paragraph H12, publish a revised FRCR.
- H.12 Following publication of the initial FRCR, the *ISOP* must:
- (a) review at least once in each financial year the FRCR prepared and published in the previous financial year and consider any improvements to better facilitate the economic and efficient operation of the National Electricity Transmission System; and
 - (b) at least annually, or at such date as directed by the *Authority*, publish an updated FRCR and submit this to the SQSS Panel for their recommendation that this be onwards submitted to the *Authority* for approval. This must be based on and prepared in accordance with the latest approved methodology set out in part A.
- H.13 The *ISOP* must make reasonable endeavours to ensure any FRCR submitted under paragraph H11 or H12 includes the information set out in paragraph H14. Where this has not been possible, the *ISOP* must explain the reasons and how it proposes to progress outstanding issues.
- H.14 Submissions made under paragraphs H11 or H12 must include:
- (a) a detailed explanation of the consultation process undertaken in the development of the FRCR;
 - (b) a summary of the views received from interested parties as part of the consultation process and an explanation of how these were taken into account in the development of the FRCR; and
 - (c) copies of any formal responses submitted to the *ISOP* as part of its consultation process.
- H.15 Following the approval of the FRCR under H19, the *ISOP* must publish the FRCR on its website in such readily accessible form and manner that it considers will best facilitate engagement with stakeholders, and provide a copy of the FRCR on request, and free of charge, to any person who asks for one.
- H.16 In complying with the requirements of paragraph H15, the *ISOP* must have due regard to the need for excluding from the published FRCR any information that could cause security concerns or that would or might seriously and prejudicially affect the commercial interests of the owner of that information if published or might be expected to be incompatible with any legislation, rule of law or licence condition and will take due regard of any representations made by owners of such data. *The ISOP* must provide to the SQSS Panel and the *Authority* its reasons for any omission of

information from the FRCR as published and where it is intended that this be different from the report as submitted for approval under H11 or H12.

H.17 Each FRCR (including the initial FRCR) prepared in accordance with the methodology set out in Part A must:

(a) set out:

- (i) those risks to the secure operation of the system considered under the FRCR;
 - (ii) the likelihood and consequence of each such risk occurring;
 - (iii) the likely cost of securing the system against such risks;
 - (iv) the benefits to the consumer in mitigating such risks;
- (b) include the *ISOP*'s assessment of continued effective operation of the system and their considered view of which risks should be secured representing the best value for money for consumers and balancing the likelihood of risks occurring and their consequence with the cost of mitigation.

H.18 The SQSS Panel will on receipt of a submission made by the *ISOP* under paragraph H11 or H12:

- (a) recommend that the proposed FRCR be onwards submitted to the *Authority* for approval; or
- (b) give direction to the *ISOP* that the FRCR requires further development.

In making its recommendation the SQSS Panel will give due regard to its expertise in the matters covered by the proposed FRCR and will seek appropriate advice and guidance where required.

H.19 The *Authority* will on receipt of a submission made by the *ISOP* under paragraph H11:

- (a) approve the proposed FRCR and in particular the recommendations as detailed in H17 (b) of which operational risks the *ISOP* will incur costs in securing the system against to avoid unacceptable frequency conditions; or
- (b) give direction to the *ISOP* that the FRCR requires further development, and the date by which the *ISOP* is required to submit a revised FRCR to the *Authority* for approval.

H.20 On approval by the *Authority* of the FRCR, the *ISOP* shall ensure that the risks set out in the FRCR to be mitigated in its operation of the system shall reasonably be secured until the subsequent approval by the *Authority* of any update of the FRCR.

Part C: Provision of information

- H.21 Based on the FRCR methodology set out in Part A, the *ISOP* must provide licenced electricity operators if reasonably requested to do so:
- (a) with information and analysis to support them in their decision-making on, for example, operation of their plant and equipment;
 - (b) with updated information and analysis to support submissions made to the *Authority* by the *ISOP* and in such form and within such timescales as reasonably requested; and
 - (c) In complying with the requirements of this paragraph, the *ISOP* must have due regard to the need to exclude from disclosure any information which would or might seriously and prejudicially affect the commercial interests of the owner of that information if disclosed or might be expected to be incompatible with any relevant legislation, code or licence condition. The *ISOP* must provide to the *Authority* its reasons for any nondisclosure of information.
- H.22 The *Authority* may direct the *ISOP* to submit additional information on any submissions made under this appendix within such timeframe as the *Authority* may require in order to carry out any of its functions in relation to the assessment of submissions.

Appendix I. System Restoration Requirements

- I.1 These key requirements apply to *onshore transmission systems*. In the case of *offshore transmission systems*, the requirements of this Appendix I would only be applied to those *offshore transmission systems* who had concluded design contracts for their assets on or after 05 February 2024.
 - I.1.1 Each *transmission system* shall be designed to facilitate participation in a *restoration plan* as appropriate including but not limited to the assessment of reactive gain and the ability for generation to energise sections of the *transmission system*.
 - I.1.2 In addition to the requirements of I1.1, each *transmission system* shall be designed to permit *power stations* to be subsequently synchronised to the *transmission system* and operated within their normal operational capability limits.
 - I.1.3 The no load gain between adjacent substations shall be designed to prevent system collapse during restoration.

Appendix J. Governance Framework

Interpretations

- J.1 Except as otherwise provided herein and unless the context otherwise admits, words and expressions used herein shall have the same meaning as defined in the SQSS.
- J.2 Words importing the singular only also include the plural and vice versa where the context requires.
- J.3 Headings and titles shall not be taken into consideration in the interpretation or construction of the words and expressions used in the SQSS

Introduction

- J.4 The Electricity Act 1989 requires *Licensees* to develop and maintain an efficient, co-ordinated and economical system of electricity transmission.
- J.5 The *transmission licences* place an obligation upon the *Licensees* to plan, develop and operate their systems in accordance with, amongst other things, the SQSS. In addition, the *ESO licence* places an obligation on the *ISOP* to coordinate and direct the flow of electricity onto and over the *national electricity transmission system*, in accordance with the SQSS, together with the *STC*, the *grid code* or such other standard of planning and operation as the *Authority* may approve from time to time, and with which the Licensee may be required to comply (following consultation, where appropriate, with any authorised electricity operator liable to be materially affected thereby).
- J.6 In order to facilitate these requirements, the SQSS may need, from time to time, to be revised to reflect changes in both the GB Electricity Supply Industry and technological advances.
- J.7 The *panel* is the co-ordinator, not a decision making body. The purpose of the *panel* is to consider developments to the SQSS and recommend SQSS changes to the *Authority*.
- J.8 The *governance framework* sets out:
 - J.8.1 arrangements for the establishment and composition of the *Panel*, to include a *Chairperson*; and
 - J.8.2 the procedure for proposing Modifications to the SQSS.
- J.9 The *governance framework* governs the industry led process for reviewing, and proposing modifications to, the SQSS. The *governance framework* is not intended to reflect upon the powers and decisions of the *Authority* in relation to the SQSS.

SQSS Objectives

- J.10 The *panel* shall endeavour at all times to perform its functions to ensure efficient discharge by each of the *Licensees* of the obligations imposed upon it under the *Electricity Act*, and by the *ISOP* of the obligations imposed upon it by the *Energy Act*, and their associated licences, specifically focusing on the following objectives:
 - (a) facilitate the planning, development and maintenance of an efficient, coordinated and economical system of electricity transmission, and the operation of that system in an efficient, economic and coordinated manner;

- (b) ensure an appropriate level of security and quality of supply and safe operation of the *National Electricity Transmission System*;
- (c) facilitate effective competition in the generation and supply of electricity, and (so far as consistent therewith) facilitating such competition in the distribution of electricity; and
- (d) facilitate *Licensees* to comply with any relevant obligations under *assimilated law*.

Establishment and Composition

Establishment

- J.11 *NESO* (as the *ISOP*), *NGET*, *SPT* and *SHET* shall establish the *panel* which shall be constituted in accordance with the further provisions of this Section 4.
- J.12 Subject as expressly provided in this *governance framework*, the *members* may regulate the conduct of and adjourn and convene *panel* meetings as they deem fit.

Functions of the Panel

- J.13 The *panel* shall consider all reasonable requests to modify the SQSS. Such requests may be made by any of the *members*, the *Authority* or any relevant interested person. SQSS modification proposals shall be raised via the *Secretary*.
- J.14 The functions of the *panel* shall be to:
 - J.14.1 keep the SQSS and its working under review;
 - J.14.2 evaluate and administrate modifications to the SQSS in accordance with procedures set out in the *governance framework*;
 - J.14.3 keep the *governance framework* and its working under review;
 - J.14.4 publish recommendations to modify the SQSS and the reasons for the recommendations;
 - J.14.5 recommend to the *Authority* any modifications of the SQSS; and
 - J.14.6 the *panel* shall endeavour at all times to perform its functions:
 - (a) in an efficient, economical and expeditious manner, taking account of the *prioritisation criteria* and the *prioritisation category* of a particular modification to the SQSS; and
 - (b) with a view to ensuring the SQSS facilitates achievement of its objectives.

Chairperson

- J.15 There shall be a *Chairperson* of the *panel* who shall be appointed every second year, by the agreement of all *members*, from 01 April 2012 or as otherwise agreed by the *members* and who shall, taking into account the functions set out in subparagraph J.16, carry out such activities as may be agreed between the *members* from time to time.
- J.16 The functions of the *Chairperson* include:
 - J.16.1 to ensure that meetings are conducted in a professional, proper, impartial and efficient manner;
 - J.16.2 to ensure that each *member*, any person invited to speak or any

representative of the *Authority* have been given a reasonable opportunity to speak on any matter contained in the agenda for the meeting.

- J.17 In the event that the *Chairperson* is not present within fifteen minutes of the scheduled start of any meeting and has not nominated another person to take the position of *Chairperson*, those *members* present shall appoint one of their number to act as *Chairperson*.

Secretary

- J.18 The *panel* shall be assisted by a *Secretary* who shall be a person appointed by the *ISOP*. The *ISOP* may remove and reappoint the *Secretary* by giving notice to the *Panel*.
- J.19 The *Secretary* shall carry out such activities as are specified in this *governance framework* and as are otherwise agreed between the *members* from time to time.

Authority

- J.20 A representative of the *Authority* shall be entitled to attend *panel* meetings as an observer and may speak at any meeting. The *Authority* shall from time to time notify the *Secretary* of the identity of the observer. For the avoidance of doubt the *Authority* representative shall not be considered a *member* of the *panel*.

Membership

- J.21 The *panel* shall consist of:-
- (a) a *Chairperson*;
 - (b) a *Secretary* appointed by the *ISOP*;
 - (c) a person appointed by the *Authority*; and
 - (d) the following *members*
 - (i) two persons representing the *ISOP*;
 - (ii) two persons representing *NGET*;
 - (iii) two persons representing *SHET*;
 - (iv) two persons representing *SPT*;
 - (v) two persons representing *offshore transmission owners*;
 - (vi) a person representing *generators*; and
 - (vii) a person representing *network operators*.

J.21.1 *ISOP members*

- J.21.1.1 The *ISOP* is entitled to nominate two *members* to attend *panel* meetings and may appoint, remove and reappoint their *members* by giving notice to the *Secretary*.

J.21.2 *NGET members*

- J.21.2.1 *NGET* is entitled to nominate two *members* to attend *panel* meetings and may appoint, remove and reappoint their

members by giving notice to the *Secretary*.

J.21.3 *SHET members*

J.21.3.1 *SHET* is entitled to nominate two *members* to attend *panel* meetings and may appoint, remove and reappoint their *members* by giving notice to the *Secretary*.

J.21.4 *SPT members*

J.21.4.1 *SPT* is entitled to nominate two members to attend panel meetings and may appoint, remove and reappoint their members by giving notice to the *Secretary*.

J.21.5 *Offshore transmission owner members*

J.21.5.1 *Offshore transmission owners* may appoint not more than two *members* and not more than two alternate *members* every second year from 01 April 2012 in accordance with Annex 1. Any person shall be eligible for reappointment on expiry of their term.

J.21.5.2 *Offshore transmission owner members* shall have the duty to impartially represent the views of the *offshore transmission owners* that they represent.

J.21.6 *Generator member*

J.21.6.1 The *panel* will agree on an appropriate representative body within the electricity industry to represent the interests of *generators*.

J.21.6.2 The agreed representative body is entitled to nominate a *member* to attend *panel* meetings. The agreed representative body may appoint, remove and reappoint their *member* by giving notice to the *Secretary*.

J.21.7 *Network operator member*

J.21.7.1 The *panel* will agree on an appropriate representative body within the electricity industry to represent the interests of *network operators*.

J.21.7.2 The agreed representative body is entitled to nominate a *member* to attend *panel* meetings. The agreed representative body may appoint, remove and reappoint their *member* by giving notice to the *Secretary*.

For the avoidance of doubt the *generator* and *network operator* representative bodies, the *ISOP*, *NGET*, *SHET* and *SPT* are not required to identify Alternate *members* as *members* are appointed, removed and reappointed by giving notice to the *Secretary*.

Meeting Frequency

J.22 All meetings shall be called by the *Secretary* giving notice to *Members* at least 15 *business days* before that date of the next meeting or such other shorter period as all the *members* may agree. The notice shall set out the date, time and place of the meeting.

- J.23 The *panel* shall hold a minimum of 4 meetings per calendar year at regular intervals as agreed by the *members*. Attendance at such meetings may be in person, by teleconference or video conference or in any alternative manner as all the *members* may agree and such *members* will be counted as present for the purposes of the quorum.

Meeting Administration

- J.24 The *Secretary* will make available to the *panel*, not less than 10 *business days* before the date of the meeting or such other shorter period as the *members* may agree, an agenda of the matters for consideration at the meeting and any supporting papers for discussion.
- J.25 An omission to send *panel* documents to a person entitled to receive them under paragraph J.28 shall not prevent a *panel* meeting from proceeding unless otherwise directed by the *Authority*.
- J.26 As soon as is practicable after each *panel* meeting, the *Secretary* shall prepare and send to the *members* and the *Authority* the minutes of such *panel* meeting, which shall be approved (or amended and approved) by the *panel* at the next *panel* meeting after they were so sent and, when approved, the *panel Secretary* shall publish the approved minutes (excluding any matter which it was agreed at such *panel* meeting was not appropriate for such publication) on the *ISOP* website.

Quorum

- J.27 Subject to paragraph J.29, no business shall be transacted at any *panel* meeting unless a quorum (as defined in paragraph J.28) is present.
- J.28 A quorum shall be constituted where there is at least one member representing each of the *ISOP*, *NGET*, *SHET*, *SPT* and the *OFTOs*, unless the *Secretary* and the *panel* has been notified in writing by a *member* representing the *ISOP*, *NGET*, *SHET*, *SPT* or the *OFTOs* that the matters to be discussed at such *panel* meeting do not materially affect it and in which case that *member* (with the consent of the other *members* forming the quorum) may waive their right to attend.
- J.29 Where a quorum is not present, the *Secretary* shall seek to adjourn the *panel* meeting to a later date unless it is the third consecutive *panel* meeting that has been required to be adjourned as a consequence of the failure to attend by a particular *member*, in which case, the *panel* meeting shall nonetheless proceed and subsequent ratification of decisions taken at the *panel* meeting by such non-attending *member* shall not be required unless the lack of attendance by such *member* (on any of the three occasions) was as a consequence of an omission to send such *member* the details of the *panel* meeting required pursuant to sub-paragraph J.28.

Attendance by Other Persons

- J.30 A *member* may, with the agreement of the other *members*, invite any person other than a person already entitled to attend under paragraph J.21 to attend any part of a *panel* meeting and to speak at such meeting, where that person so attends.

Removal from Office

- J.31 A person shall cease to hold office as a *member* or an Alternate *member*.
- (a) in the case of *offshore transmission owner members* only, upon expiry of their

- term of office unless re-appointed;
- (b) if they:
- (i) resign by notice delivered to the *Secretary*;
 - (ii) become bankrupt or make any arrangement or composition with their creditors generally;
 - (iii) are or may be suffering from a mental disorder and either are admitted to hospital in pursuance of an application under the Mental Health Act 1983 or the Mental Health (Scotland) Act 1960 or an order is made by a court having jurisdiction in matters concerning mental disorder for their detention or for the appointment of a receiver, *curator bonis* or other person with respect to their property or affairs;
 - (iv) become prohibited by law from being a director of a company under the Companies Act 1985;
 - (v) die; or
 - (vi) are convicted on an indictable offence; or
- (c) if the *panel* resolves (and the *Authority* does not veto such resolution by notice in writing to the *Secretary* within 15 *business days*) that they should cease to hold office on grounds of their serious misconduct.
- J.32 A *panel* resolution under paragraph J.31(c) shall, notwithstanding any other paragraph, require the vote in favour of at least all *members* less one (other than the *member* or Alternate *member* who is the subject of such resolution) and for these purposes an abstention shall count as a vote cast in favour of the resolution. A copy of any such resolution shall forthwith be sent to the *Authority* by the *Secretary*.
- J.33 A person shall not qualify for appointment as a *member* or Alternate *member* if at the time of the proposed appointment they would be required by the above paragraph to cease to hold that office.
- J.34 The *Secretary* shall give prompt notice by electronic means to all *members* and the *Authority* of the appointment or re-appointment of any *member* or Alternate *member* or of any *member* or Alternate *member* ceasing to hold office.

Modification of the SQSS

General

- J.35 Each *member* shall keep under review whether any possible change to the SQSS would better facilitate achievement of the SQSS objectives and shall, in accordance with J.35-84 and to the extent that such matter is not covered by a modification proposal, raise a modification proposal which, in the *member's* opinion, would do so.
- J.36 The *members* shall endeavour at all times to act pursuant to this J.35-84:
- (i) in an efficient, economical and expeditious manner taking account of the *prioritisation criteria* and the *prioritisation category* of a particular modification proposal; and
 - (ii) with a view to ensuring that the SQSS facilitates achievement of the SQSS objectives.
- J.37 The SQSS Modification process flow chart is shown in Annex 2. paragraph J.38-84

presents a more detailed account of the modification process.

The SQSS Modification Process

Modification Proposal

J.38 A modification proposal may be made by any of the following:

- (a) a *member*;
- (b) the *Authority*; or
- (c) relevant interested person

referred to in J.35-84 as the 'Proposer'.

J.39 A modification proposal made pursuant to paragraph J.38 shall be submitted to the *Secretary* in the form of Annex 3 which may be amended by the *panel* from time to time.

J.39A A Modification Proposal made pursuant to paragraph J.38 shall also contain an assessment by the Proposer of the Modification Proposal against the *prioritisation criteria*.

J.40 If a modification proposal fails to contain any information required under paragraph J.39, the *Secretary* shall notify the Proposer, who may submit a revised request in compliance with this paragraph J.39.

J.41 Upon receipt of a modification proposal made pursuant to and in compliance with paragraph J.39, the *Secretary* shall as soon as reasonably practicable:

- (a) make a copy of the modification proposal available to the *members*, the *Authority* and any relevant interested person, such as by publishing it on the Licensee's website; subject to the provisions of paragraph J.24-26, put the request on the agenda for the next *panel* meeting; and
- (b) add the new modification proposal to the SQSS modification register ("modification register") as further provided for and defined in paragraph J.80-84.

J.42 It shall be a condition to the right to raise an SQSS modification proposal under this paragraph J.38-43 that the Proposer:

- (a) grants a non-exclusive royalty-free licence to all Parties who request the same covering all present and future rights, Intellectual Property Rights and moral rights it may have in such request (as regards use or application in *Great Britain* and its *offshore waters*); and
- (b) warrants that, to the best of its knowledge, information and belief, no other person has asserted to the Proposer that such person has any Intellectual Property Rights or moral rights or rights of confidence in such proposal inconsistent with the Parties' rights to make, publish or use such request, and, in making a request, a shall be deemed to have granted the licence and given the warranty contained in paragraphs (a) and (b) above respectively.

J.43 The Proposer may withdraw its modification proposal on notice to the *Secretary* at any time, in which case, the *Secretary* shall promptly notify the *members* and the *Authority* and then, 5 *business days* after issue of such notice by the *Secretary*, shall:

- (a) revise the modification register; and

- (b) remove the modification proposal from the agenda of the next *panel* meeting (as relevant);

Review of Modification Proposals at Panel Meetings

- J.44 The *panel* shall consider a modification proposal (if compliant with paragraph J.39 and not withdrawn under paragraph J.43) at the next *panel* meeting and at such meeting shall use all reasonable endeavours to decide (as and where relevant) whether:
- (a) the *members* require additional information in order to assess whether the request would better facilitate achievement of the SQSS Objectives; or
 - (b) pursuant to paragraph J.48, to amalgamate the request with any other proposed modification; and
 - (c) having assessed the Modification Proposal against the *prioritisation criteria*, as compared with other modification proposals, taking into account the Proposer's opinion provided pursuant to paragraph J.39A, the Modification Proposal should be accorded a relevant *prioritisation category*.
- J.45 Where, pursuant to paragraph J.44 (a) above, the *panel* decides not to take the modification proposal further, the *Secretary* shall notify the Proposer explaining why the proposal has been rejected. The *Secretary* shall also amend the modification register as appropriate.
- J.46 Where, pursuant to paragraph J.44 (a) above, the *panel* decides that additional information is required or the *panel* cannot reach a decision on such matters, the *panel* shall refer the modification proposal to a workgroup to carryout such analysis as set out under paragraph J.50-64.
- J.47 Where, pursuant to paragraph J.44 (a) above, the *panel* decides that additional information is not required, the *panel* shall proceed directly to industry consultation under paragraphs J.65-66.
- J.48 The *panel* may decide to amalgamate a modification proposal with one or more other modification proposal(s) where the subject matter is sufficiently proximate to justify amalgamation on the grounds of efficiency and/or where such modification proposal(s) are logically dependent on each other.
- J.49 Where modification proposals are amalgamated pursuant to paragraph J.44:
- (a) such modification proposals shall be treated as a single modification proposal;
 - (b) references in J.35-84 to a modification proposal shall include and apply to a group of two or more modification proposals so amalgamated;
 - (c) the Proposers of each such amalgamated modification proposal shall cooperate in deciding which of them shall constitute the Proposer of such amalgamated modification proposals, failing which agreement, the modification proposals shall continue separately as before; and
 - (d) the Panel shall determine the amalgamated Modification Proposal to have a single *prioritisation category*. When determining a *prioritisation category* for an amalgamated Modification Proposal, the Panel shall consider the *prioritisation categories*, and the relevant assessments undertaken in determining these *prioritisation categories*, accorded to the original Modification Proposals that have been amalgamated.

Evaluation and Assessment by a Workgroup

- J.50 Following referral of a modification proposal, pursuant to paragraph J.46, to a workgroup, the *panel* shall invite representations or commission such studies, convene industry workshops and other evaluation as it deems appropriate in order that the *panel* is provided with sufficient information such that it can assess whether the modification proposal would better facilitate achievement of the SQSS Objectives.
- J.51 The *panel* shall use its reasonable endeavours in order to ensure that evaluation and assessment by a workgroup takes no longer than 6 months from its referral under paragraph J.46 up to the submission of the workgroup report to the *panel* under paragraph J.62 unless otherwise agreed by the *panel*.
- J.52 A workgroup shall comprise at least 5 persons (who may be *panel members*) “workgroup Quorum” or any such number of persons agreed by the *panel*.
- J.53 In addition to the workgroup Quorum the *panel* shall appoint a workgroup *Chairperson* who will ensure that meetings are conducted in a professional, proper, impartial and efficient manner.
- J.54 The workgroup shall be assisted by a *Secretary* who shall be appointed by the *panel*. As soon as is practicable after each workgroup meeting, the *Secretary* shall prepare and send to the workgroup *members* the minutes of such workgroup meeting, which shall be approved (or amended and approved) by the workgroup at the next workgroup meeting after they were so sent and, when approved, the *Secretary* shall publish the approved minutes (excluding any matter which it was agreed at such workgroup meeting was not appropriate for such publication) on the *ISOP* website.
- J.55 A representative of the *Authority* may attend any meeting of a workgroup as an observer and may speak at any such meeting.
- J.56 The *panel* shall determine the terms of reference of each workgroup and may change those terms of reference from time to time as it sees fit.
- J.57 The terms of reference for a workgroup must include provision in respect of the following matters:
- (a) detail the workgroup’s responsibilities for assisting the *panel* in the evaluation of the modification proposal and consider whether it better facilitates achievement of the SQSS Objectives and to provide additional information to the *panel*;
 - (b) detail the modification proposal;
 - (c) detail the work to be undertaken by the workgroup to assist the *panel* in the evaluation of the modification proposal;
 - (d) specify any matters which the workgroup should address in its report;
 - (e) the timetable for the work to be done by the workgroup;
 - (f) specify if the workgroup is to comment upon any legal text.
- J.58 Unless otherwise determined by the *panel* the workgroup shall develop and adopt its own internal working procedures for the conduct of its business.
- J.59 A workgroup report will be submitted to the *panel* responding to the matters detailed in the terms of reference and in accordance with the timetable set out in the terms of reference and will indicate the issues and views which arose in the workgroup

discussions and any recommendations made.

- J.60 If a workgroup is unable to reach agreement on any such matter, the workgroup report must reflect the views of the members of the workgroup.
- J.61 The workgroup report will be circulated in draft form to the workgroup members for a period of not less than 5 *business days* for comment. Any unresolved comments made shall be reflected in the final workgroup report.
- J.62 The final workgroup report shall be submitted to the *panel*. Upon receipt of the workgroup report, the *Secretary* shall as soon as reasonably practicable:
- (a) send a copy of the workgroup report to the *members* and the *Authority*; and
 - (b) subject to the provisions of paragraph J.24-26 put the workgroup report on the agenda for the next *panel* meeting;
- J.63 The workgroup *Chairperson* or another person (nominated by the workgroup *Chairperson*) shall be present at the *panel* meeting at which that workgroup report is to be discussed and may be invited to present the findings and/or answer the questions of *panel members*.
- J.64 Following receipt of any representations, study, workgroup report or other evaluation pursuant to paragraph J.50, the *panel* shall consider whether the information provided is sufficient to form a view as to whether the modification proposal better facilitates achievement of the SQSS Objectives and may invite such further representations, studies, and other evaluation including sending matters back to the workgroup as it deems appropriate until the *panel* considers that the information provided is sufficient.

Industry Consultation

- J.65 Following completion of the steps set out in paragraphs J.50-64 above (where relevant), the *Secretary* shall prepare a consultation document ("Consultation Document") setting out:
- (a) the modification proposal;
 - (b) the views and recommendations of the *panel* as to whether the changes proposed in the modification proposal(s) should be made, including the analysis of whether (and, if so, to what extent) the modification proposal(s) would better facilitate achievement of the SQSS Objectives and the views and rationale in respect thereof;
 - (c) an analysis and impact assessment ("assessment") which shall identify the likely effect of the modification proposal(s) on the assets and systems of *panel members*, including a description of any works necessary to implement the change and an estimate of the development, capital and operating costs associated with implementing the changes to the SQSS;
 - (d) the proposed implementation date of the modification proposal(s) as agreed by the *panel*, failing which, as shall be proposed by the Proposer and, in the later case, accompanied by the written representations of the other *members* giving their own opinion as to what the implementation date should be; and
 - (e) any proposed text to modify the SQSS;
 - (f) (to the extent that such matters are not included pursuant to subparagraph (c)), an analysis of:

- (i) the impact of the modification proposal(s) on the *core industry documents*;
- (ii) the changes which would be required to give effect to the modification proposal(s) in relation to the *core industry documents*;
- (iii) the mechanism and likely timescale for making the changes referred to in paragraph (ii);
- (iv) the changes or developments which would be required to central computer systems and, if practicable, processes used in connection with the operation of arrangements established under the *core industry documents*;
- (v) the mechanism and likely timescale for making the changes referred to in paragraph (iv); or
- (vi) an estimate of the costs associated with making and delivering the changes referred to in paragraphs (ii) and (iv), such costs being expected to relate to: for (ii), the costs of implementing Modifications to the Industry Framework Document(s), and for (iv), the costs of changes to computer systems and possibly processes which are established for the operation of the *core industry documents*,
- (g) details of the analysis carried out, pursuant to paragraph J.44 (c), by the Panel to determine the *prioritisation category* of the Modification Proposal, and the *prioritisation category* that has been determined, where this determination has been carried out.

together with a summary of representations of the *panel* in relation to such matters,

J.66 Pursuant to paragraph J.65, the *Secretary* shall:

- (a) circulate the Consultation Document to each of the *members* and such persons or bodies as have responsibility for progressing changes to the *core industry documents* and publish it on the *ISOP* website or otherwise in such manner as may be deemed appropriate by the *members* to bring it to the attention of other persons who may have a relevant interest in the modification proposal;
- (b) invite representations in relation to the Consultation Document within 20 *business days* or such other period as the *panel* shall determine; and
- (c) on receipt of representations pursuant to paragraph (b), prepare a summary of such representations.

The Modification Report

- J.67 Pursuant to paragraph J.66, the *panel* shall consider the representations made in response to the Consultation Document and shall instruct the *Secretary* to prepare a report as in paragraph J.65 incorporating comments from the Consultation Document respondents and recommendations in light of those comments. This report shall form the “modification report”
- J.68 If *members* agree that modification to the SQSS is not required, the *panel* shall instruct the *Secretary* to prepare the modification report and send it to the *Authority*. The *Secretary* shall also update the modification register and publish the modification report on the *ISOP* website.
- J.69 If *members* agree that modification to the SQSS is required, the *Panel* shall instruct

the *Secretary* to prepare the modification report and send it to the *Authority*. Each *Licensee member* will individually send a licence change request to the *Authority* based on the modification report. The *Secretary* shall also update the modification register and publish the modification report on the *ISOP* website.

- J.70 If not all *members* agree that modification to the SQSS is needed, the *Secretary* shall record the range of recommendations which shall be incorporated into the modification report. The *panel* shall instruct the *Secretary* or workgroup *Chairperson* to prepare the modification report for subsequent submission to the *Authority*. Those *Licensee members* that recommend modification to the SQSS may send licence change requests to the *Authority*. The *Secretary* shall also update the modification register and publish the modification report on the *ISOP* website.
- J.71 None of the facts, opinions or statements contained in the modification report may be relied upon by any other person.
- J.72 The Modification Report shall contain details of the analysis carried out, pursuant to paragraph J.44 (c), by the Panel to determine the *prioritisation category* of the Modification Proposal, and the *prioritisation category* that has been determined, where this determination has been carried out.

Further versions of SQSS

- J.73 If the *Authority* directs a change to the SQSS the *Licensee* shall provide a revised version of the SQSS in accordance with the terms of such notice, update the modification register and publish the revised SQSS on the *ISOP* website. No change shall be made to the SQSS without prior consent of the *Authority*.
- J.74 A modification to the SQSS shall take effect from the date and time as specified in the direction referred to in paragraph J.73.
- J.75 The relevant *members* shall be responsible for implementing any changes to their relevant computer systems and processes as necessary to effect the approved modification in accordance with this paragraph J.73-79.
- J.76 Following implementation of licence changes by the *Authority* in relation to approved modifications, each relevant *member* shall:
- (a) use its reasonable endeavours to progress changes made to the *core industry documents* (to the extent that it is a party to them) in order to give full and timely effect to a modification to the SQSS by the implementation date;
 - (b) do what is required to those of its systems and processes which support the operation of the SQSS as may be necessary in order to give full and timely effect to a Modification to the SQSS by the implementation date; and
 - (c) keep the *Panel* informed of any matter that may affect the ability for the implementation date to be met.
- J.77 Without prejudice to the obligations of the *members* under this paragraph J.73-79, the implementation date may be extended or shortened with the prior approval of, or at the direction of, the *Authority*.
- J.78 Any relevant *member* shall apply to the *Authority* for an extension of the implementation date if it becomes aware of any circumstances that are likely to cause a delay in the implementation of an approved modification.
- J.79 A modification made pursuant to and in accordance with this paragraph J.38-84 shall

not be impaired or invalidated in any way by any inadvertent failure to comply with or give effect to this paragraph J.73-79.

The Modification Register

- J.80 The *Secretary* shall establish and maintain a register (the "modification register") which shall record, in such form as the *panel* may determine, the matters set out in paragraph J.82.
- J.81 The purpose of the modification register shall be to assist the *panel* in the operation of the modification process under this *governance framework* and to enable the *members* and other interested third parties to be reasonably informed of the progress of modification proposals and approved modifications from time to time.
- J.82 The modification register shall record:
- (a) details of each modification proposal (including the name of the Proposer, the date raised and a brief description of the modification proposal);
 - (b) the current status and progress of each modification proposal and the anticipated date for reporting to the *Authority* in respect thereof;
 - (c) the current status and progress of each approved modification to the SQSS;
 - (d) such other matters as the *Panel* may consider appropriate from time to time in order to achieve the purposes set out in subparagraph J.81.
 - (e) the *prioritisation category* attached to the Modification Proposal, and the reasons for the Panel's determinations where they have been made in regard to the *prioritisation category* of the Modification Proposal; and
 - (f) where the *prioritisation category* of a Modification Proposal has been changed, details of and the reasons for its change.
- J.83 The modification register shall, in addition to those matters set out in subparagraphs J.82, also include details of:
- (a) each modification proposal which has been withdrawn pursuant to paragraph J.43 or rejected by the *panel*; and
 - (b) each modification to the SQSS which has been implemented pursuant to paragraph J.80-84,
- for a period of 6 months after such withdrawal, rejection or implementation, or such longer period as the *panel* may determine.
- J.84 The *Secretary* shall publish the modification register (as updated from time to time and indicating the revisions since the previous issue) on the *ISOP* website with such frequency as the *panel* may agree, in order to bring it to the attention of interested third parties.

Review of Prioritisation Category of Modification Proposals

- J.85 The Panel shall review the *prioritisation category* of Modification Proposals on a bi-annual basis and adjust the relevant modification timetable for each Modification Proposal accordingly.

Appendix J, Annex 1 - Offshore Transmission Owner Election Process

General

Introduction

- J.A1.1 This Annex 1 sets out the basis for election of *offshore transmission owner members* and *offshore transmission owner Alternate members* which will apply except to the extent that the conditions in J.A1.5 are met.
- J.A1.2 This Annex 1 shall apply:
- (a) in relation to each year (the “election year”) in which the term of office of *offshore transmission owner members* and *offshore transmission owner Alternate members* expires, for the purposes of electing *offshore transmission owner members* and *offshore transmission owner Alternate members* to hold office with effect from 01 April in that year;
 - (b) subject to and in accordance with paragraph J.A1.34-49, upon a *offshore transmission owner member* and/or *offshore transmission owner Alternate member* ceasing to hold office before the expiry of their term of office.
- J.A1.3 For the purposes of an election under paragraph J.A1.2(a) references to *offshore transmission owner* are to persons who are an *offshore transmission owner* as at 01 January in the election year.
- J.A1.4 The *Secretary* shall administer each election of *offshore transmission owner members* and *offshore transmission owner Alternate members* pursuant to this Annex.
- J.A1.5 Where the following conditions (a) and (b) in this paragraph J.A1.5 are met, the *offshore transmission owner member(s)* and/or *offshore transmission owner Alternate member(s)* will be those notified to the *Secretary* as set out below:
- (a) each *Offshore Transmission Owner Member* as at 01 January in the relevant election year, has confirmed in writing to the *Secretary* that the *offshore transmission owner member(s)* and/or *offshore transmission owner Alternate member(s)* will be elected in accordance with a process other than that set out in Annex 1 (“alternative OFTO election process”); and
 - (b) each *offshore transmission owner member* as at 01 January in the relevant election year, has notified the *Secretary* in writing by 25 January of the relevant election year of the identity of the *offshore transmission owner member(s)* and/or *offshore transmission owner Alternate member(s)* elected through the alternative OFTO election process, and each notification identifies the same individual(s).

Upon receipt of such notifications in accordance with the above, the provisions of this Annex 1, with exception of paragraph J.A1.4, shall not apply until the following election year.

Election timetable

- J.A1.6 The *Secretary* shall not later than 01 February in the election year prepare and circulate to all *offshore transmission owners* (by publication on the *ISOP* website and, where relevant details are supplied, by electronic mail), with a copy to the *Authority*, an invitation to nominate candidates who must be willing to be either an *offshore transmission owner member* or an *Alternate member* and a timetable for

the election (the “election timetable”), setting out:

- (a) the date by which nominations of candidates are to be received, which shall not be less than three (3) weeks after the timetable is circulated;
- (b) the date by which the *Secretary* shall circulate a list of candidates and voting papers;
- (c) the date by which voting papers are to be submitted, which shall not be less than three (3) weeks after the date for circulating voting papers;
- (d) the date by which the results of the election will be made known, which shall not be later than 18 March in the election year.

J.A1.7 If for any reason it is not practicable to establish an election timetable in accordance with paragraph J.A1.6 or to proceed on the basis of an election timetable which has been established, the *Secretary* may establish a different timetable, or revise the election timetable, by notice to all *offshore transmission owners*, the *panel* and the *Authority*, provided that such timetable or revised timetable shall provide for the election to be completed before 01 April in the election year.

J.A1.8 A nomination or voting paper received by the *Secretary* later than the respective required date under the election timetable (subject to any revision under paragraph J.A1.7) shall be disregarded in the election.

CANDIDATES

Nominations

J.A1.9 Nominations for candidates shall be made in accordance with the election timetable.

J.A1.10 Subject to paragraph J.A1.3, each *offshore transmission owner* may nominate one candidate for election by giving notice to the *Secretary*.

List of candidates

J.A1.11 The *Secretary* shall draw up a list of the nominated candidates and circulate the list to all *offshore transmission owners* by the date specified in the election timetable.

J.A1.12 The list shall specify the *offshore transmission owner* by whom each candidate was nominated and any affiliations which the candidate may wish to have drawn to the attention of *offshore transmission owners*.

J.A1.13 Except where paragraphs J.A1.40-44 or J.A1.45-49 apply, if two (2) or fewer candidates are nominated no further steps in the election shall take place and such candidate(s) shall be treated as elected as *offshore transmission owner members* and paragraph J.A1.21 shall apply in relation to such candidate(s).

J.A1.14 Where paragraph J.A1.40-44 applies, if only one (1) candidate is nominated, no further steps in the election shall take place and such candidate shall be treated as elected as a *member* and paragraph J.A1.21 shall apply in relation to such candidate.

J.A1.15 Where paragraph J.A1.45-49 applies, if two (2) or fewer candidates are nominated, no further steps in the election shall take place and such candidate(s) shall be treated as elected as *Alternate members* and paragraph J.A1.21 shall apply in relation to such candidate(s).

VOTING

Voting papers

J.A1.16 Voting papers shall be submitted in accordance with the election timetable.

J.A1.17 Each *offshore transmission owner* may submit one voting paper.

Preference votes and voting rounds

J.A1.18 Each *offshore transmission owner* submitting a voting paper shall vote by indicating on the voting paper a first, second and third preference ("Preference Votes") among the candidates.

J.A1.19 A voting paper need not indicate a second, or a third, preference, but the same candidate may not receive more than one Preference Vote in a voting paper.

J.A1.20 Candidates shall be elected in three voting rounds (together where necessary with a further round under paragraph J.A1.30) in accordance with the further provisions of this paragraph J.A1.16-33.

J.A1.21 The *Secretary* shall determine which candidates are elected and announce (to the *Authority* and all *offshore transmission owners*) the results of the election in accordance with the election timetable.

J.A1.22 The *Secretary* shall not disclose the Preference Votes cast by *offshore transmission owners* or received by candidates; but an *offshore transmission owner* may request that the *Authority* scrutinise the conduct of the election, provided that such *offshore transmission owner* shall bear the costs incurred by the *Authority* in doing so unless the *Authority* recommends that the election results should be annulled.

J.A1.23 Further references to voting papers in this paragraph J.A1.16-33 do not include voting papers which are invalid or are to be disregarded (i.e. voting papers not made or submitted in accordance with this Annex 1).

First voting round

J.A1.24 In the first voting round:

(a) the number of first Preference Votes allocated under all voting papers to each candidate shall be determined.

(b) the first round qualifying total shall be: $(T / N) + 1$

where:

T is the total number of first Preference Votes in all voting papers;

N is the number of *offshore transmission owners' members*

and/or Alternate *members* to be elected.

J.A1.25 If the number of first Preference Votes allocated to any candidate is equal to or greater than the first round qualifying total, that candidate shall be elected.

Second voting round

J.A1.26 In the second voting round:

(a) the remaining candidates are those which were not elected in the first voting round;

(b) the remaining voting papers are voting papers other than those under which

- the first Preference Votes were for candidates elected in the first voting round;
- (c) the number of first and second Preference Votes allocated under all remaining voting papers to each remaining candidate shall be determined;
- (d) the second round qualifying total shall be $(T' / N') + 1$

where:

T' is the total number of first Preference Votes and second Preference Votes allocated under all remaining voting papers;

N' is the number of *members* and/or Alternate *members* remaining to be elected after the first voting round.

J.A1.27 If the number of first and second Preference Votes allocated to any remaining candidate is equal to or greater than the second round qualifying total, that candidate shall be elected.

Third voting round

J.A1.28 In the third voting round:

- (a) the remaining candidates are those which were not elected in the first or second voting rounds;
- (b) the remaining voting papers are voting papers other than those under which the first or second Preference Votes were for candidates elected in the first or second voting rounds;
- (c) the number of first, second and third Preference Votes allocated under all remaining voting papers to each remaining candidate shall be determined;
- (d) the third round qualifying total shall be $(T'' / N'') + 1$

where:

T'' is the total number of first Preference Votes, second Preference Votes and third Preference Votes allocated under all remaining voting papers;

N'' is the number of *members* remaining to be elected after the first and second voting rounds.

J.A1.29 If the number of first, second and third Preference Votes allocated to any remaining candidate is equal to or greater than the third round qualifying total, that candidate shall be elected.

Further provisions

J.A1.30 If after any voting round the number of candidates achieving the required Preference Votes threshold exceeds the number of persons remaining to be elected, the following tie-break provisions shall apply between the tied candidates. In addition, if after the third voting round any *member(s)* or Alternate *member(s)* remain to be elected the following tie-break provisions shall apply between the remaining candidates:

- (a) the tied or remaining candidates (as applicable) shall be ranked in order of the number of first Preference Votes allocated to them, and the candidate(s) with the greatest number of such votes shall be elected;
- (b) in the event of a tie between two or more candidates within paragraph (a),

the candidate(s) (among those tied) with the greatest number of second Preference Votes shall be elected;

- (c) in the event of a tie between two or more candidates within paragraph (b), the *Secretary* shall select the candidate(s) (among those tied) to be elected by drawing lots.

Members and Alternate Members

J.A1.31 Except where paragraphs J.A1.40-44 or J.A1.44-49 apply, the two (2) candidates receiving the greatest number of votes shall be elected as *offshore transmission owners' members* and the next two (2) shall be elected as *offshore transmission owners' Alternate members*.

J.A1.32 Where paragraph J.A1.40-44 applies the number of candidate(s) up to and including the number of Member Interim Vacancies receiving the greatest number of votes pursuant to the Interim *panel* and Alternate Election Process shall be elected as *offshore transmission owners' member(s)* and the remaining candidates up to and including the number of Alternate *member* Interim Vacancies receiving the greatest number of votes shall be elected as Alternate *member(s)*.

J.A1.33 Where paragraph J.A1.45-49 applies the two (2) candidates receiving the greatest number of votes pursuant to the Alternate Election Process shall be elected as Alternate *members*.

VACANCIES

General

J.A1.34 If a *member* ceases to hold office pursuant to paragraph J.31 (b) (i) then paragraph J.A1.38-39 shall apply.

J.A1.35 If a *member* ceases to hold office pursuant to paragraph J.31 (a), J.31 (b) (ii) to (vi) (inclusive) or J.31 (c) then paragraph J.A1.40-44 shall apply.

J.A1.36 If an Alternate *member* ceases to hold office pursuant to paragraph J.31 (the "Resigning" Alternate *member*) then paragraph J.A1.45-49 shall apply.

J.A1.37 The provisions of paragraph J.A1.10 shall apply, mutatis mutandis, to any replacement *member* or any replacement Alternate *member* under this paragraph J.A1.34-39.

Replacement of a *member* who ceases to hold office pursuant to paragraph J.31 (b)(i)

J.A1.38 Where this paragraph J.A1.38-39 applies, and in accordance with the duties set out in paragraph J.13-14, such *member* may appoint a replacement *member* (subject to paragraph J.A1.39) for the remainder of the term of office of such *member* and shall notify the *Secretary* of a replacement *member* at the same time as they resign. If such *member* does not appoint a replacement at the time of notifying the *Secretary* of their resignation then such *member* will be replaced in accordance with paragraph J.A1.40-44 and this paragraph J.A1.38 shall no longer apply.

J.A1.39 A *member* shall only appoint an Alternate *member* to be their replacement pursuant to paragraph J.A1.39 and such Alternate *member* chosen to be a *member* shall then become a Resigning Alternate *member* and be replaced in accordance with paragraph J.A1.45-49.

Replacement of a *member* who ceases to hold office pursuant to paragraph J.31 (a), J.31 (b) (ii) to (vi) or J.31 (c)

J.A1.40 Subject to paragraph J.A1.41, such *member* shall, where one or more Alternate *member(s)* hold office, be replaced by the Alternate *member* who previously received the highest number of cumulative Preference Votes but if there were a tie-break in relation to such Preference Votes then the tie-break provisions set out in paragraph J.A1.30 shall apply, in either circumstance such Alternate *member* selected to be a *member* shall then become a Resigning Alternate *member* and be replaced in accordance with paragraph J.A1.45-49.

J.A1.41 If there are no Alternate *members* in office upon a *member* ceasing to hold office then:

- (a) Where there are not less than six (6) months remaining until the next full election further *members* shall be elected in accordance with paragraphs J.A1.9-33 and subject to the following paragraphs J.A1.42-44 (the “Interim *Panel* and Alternate Election Process”).
- (b) Where there are less than six (6) months remaining until the next full election no further *members* or Alternate *members* shall be elected pursuant to this paragraph J.A1.40-44 and the positions shall remain vacant until the next full election.

J.A1.42 Where this paragraph J.A1.42 applies the *Secretary* shall indicate in the invitation referred to at paragraph J.A1.6 the number of vacancies for both *member(s)* (“*member* Interim Vacancies”) and Alternate *member(s)* (“Alternate *member* Interim Vacancies”) for which the Interim *panel* and Alternate Election Process is being held.

J.A1.43 Any *member(s)* or Alternate *member(s)* elected pursuant to the Interim *panel* and Alternate Election Process shall cease to hold office at the next full election.

J.A1.44 The timetable for the Interim *panel* and Alternate Election Process shall be expedited and the *Secretary* shall prepare a timetable accordingly.

Replacement of a Resigning Alternate Member

J.A1.45 Subject to paragraph J.A1.46 a Resigning Alternate *member* shall not be replaced.

J.A1.46 If there are no Alternate *members* remaining in office following the resignation of an Alternate *member* or their appointment as a *member* in accordance with J.A1.38-39 or J.A1.40-44 then:

- (a) Where there are not less than six (6) months remaining until the next full election further Alternate *members* shall be elected in accordance with paragraphs J.A1.38-44 and subject to the following paragraphs J.A1.47-49 (the “Alternate Election Process”).
- (b) Where there are less than six (6) months remaining until the next full election no further Alternate *members* shall be elected and the positions shall remain vacant until the next full election.


J.A1.47 Where this paragraph J.A1.47 applies, a reference in paragraphs J.A1.9-33 to an *offshore transmission owners’ member* shall not apply except in the case of paragraph J.A1.28(d) where the reference to “*members*” shall be read and construed as a reference to “Alternate *members*”.


J.A1.48 Any Alternate *member(s)* elected pursuant to the Alternate Election Process shall

cease to hold office at the next full election.

J.A1.49 The timetable for the Alternate Election Process shall be expedited and the *Secretary* shall prepare a timetable accordingly.

Appendix J, Annex 2 - SQSS Modification Process Flow Chart





Appendix J, Annex 3 - Modification Proposal Form

A copy of the modification proposal form can be found electronically on the *ISOP* website at:

[Modification Proposal Form](#)