

Public

Code Administrator Consultation Response Proforma

GSR036: System Access Reform: Review of the voltage limits

Industry parties are invited to respond to this consultation expressing their views and supplying the rationale for those views, particularly in respect of any specific questions detailed below.

Please send your responses to box.sqss@neso.energy by **5pm** on **03 July 2026**.

Please note that any responses received after the deadline or sent to a different email address may not receive due consideration.

If you have any queries on the content of this consultation, please contact box.sqss@neso.energy

Respondent details	Please enter your details	
Respondent name:	Alan Creighton	
Company name:	Northern Powergrid	
Email address:	Alan.creighton@northernpowergrid.com	
Phone number:	07850 015515	
Which best describes your organisation?	☐ Consumer body ☐ Demand ☒ Distribution Network Operator ☐ Generator ☐ Industry body ☐ Interconnector	☐ Storage ☐ Supplier ☐ System Operator ☐ Transmission Owner ☐ Virtual Lead Party ☐ Other

Public

I wish my response to be:

(Please mark the relevant box)	☒ Non-Confidential (<i>this <u>will be shared</u> with industry and the Panel for further consideration</i>)
	☐ Confidential (<i>this will be disclosed to the Authority in full but, unless specified, <u>will not be shared</u> with the Panel or the industry for further consideration</i>)

For reference the Applicable SQSS Objectives are:

- a) *facilitate the planning, development and maintenance of an efficient, coordinated and economical system of electricity transmission, and the operation of that system in an efficient, economic and coordinated manner;*
- b) *ensure an appropriate level of security and quality of supply and safe operation of the National Electricity Transmission System;*
- c) *facilitate effective competition in the generation and supply of electricity, and (so far as consistent therewith) facilitating such competition in the distribution of electricity; and*
- d) *facilitate Licensees to comply with any relevant obligations under Assimilated law.*

Public

Please express your views in the right-hand side of the table below, including your rationale.

Standard Code Administrator Consultation questions		
1	Please provide your assessment for the proposed solution against the Applicable Objectives against the current baseline.	Mark the Objectives which you believe the proposed solution better facilitates than the current baseline:
		Original ☒ (a) ☒ (b) ☐ (c) ☐ (d) ☐ None
		Click or tap here to enter text.
2	Do you support the proposed implementation approach?	☒ Yes ☐ No
		Click or tap here to enter text.
3	Do you have any other comments?	We have made some minor editorial suggestions embedded in a marked version of the draft SQSS which forms part of our consultation response. In terms of implementation, do NESO intend to advise users that they might need to review their alarm and protection settings as suggested on page 11 of the CAC report? If so would any such reviews need to be completed

Public

		before the relaxed voltage limits could be applied.
--	--	---